

Consumers Power Company

Palisades Plant - Docket 50-255

1982 RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT  
(ADDITIONAL INFORMATION)

Tables RSD-E-03A and RSD-E-03D

8305240410 830518  
PDR ADOCK 05000255  
R PDR

2 Pages

OC0583-0019B-NL02

DMB



Consumers Power Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

PRINCIPAL STAFF	
RA	ENF
D/RA	SCS
A/RA	PAO
DPRP	SLO
DEMA	RC
DRMSP	
DE	
ML	
OL	FILE 11/10/82

enig + 2

May 18, 1983

James G Keppler, Administrator  
 Region III  
 US Nuclear Regulatory Commission  
 799 Roosevelt Road  
 Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -  
 PALISADES PLANT - 1982 RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT  
 (ADDITIONAL INFORMATION)

Consumers Power Company submittal dated March 29, 1983 and entitled 1982 Radiological Environmental Monitoring Report requires a revision to tables RSD-E-03A and RSD-E-03D. The changes, necessitated by review of the report are on the unit of measure for air sample. The revised tables are attached with the change noted by a line in the right margin.

Brian D Johnson  
 Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation  
 Director, Office of Inspection and Enforcement  
 NRC Resident Inspector - Palisades

Attachments

MAY 20 1983

OC0583-0019C-NL02

1E:25

TABLE RSD-E-03A

Environmental Radiological Monitoring Program Summary  
 Palisades Nuclear Plant, Docket DPR-20  
 Van Buren County, Michigan, January 1, 1982 to December 31, 1982

Medium or Pathway Sampled Unit of Measurement	Analysis and Total Number of Analyses Performed		Lower Limit of Detection(a)	All Indicator Locations	Location with Highest Annual Mean		All Control Locations	Nonroutine Reported Measurements(c)
			LLD	Mean(b) Range(b)	Name Distance & Direction	Mean(b) Range(b)	Mean(b) Range(b)	
Air ( $10^{-2}$ pCi/m <sup>3</sup> )	Gross Beta	622	1.0	(454/463) 3.3 (<1-25)	KZ 35 mi SE	3.8 (1-7)	(156/159) 3.7 (<1-10)	None
	I-131	622	2.0	LLD all	N/A			None
Lake Water (pCi/l)	Gross Alpha	24	1.0	(1/24) 1.2 (<1-5)	Discharge	1.3 (<1-5)	None	None
	Gross Beta	36	1.0	(24/24) 3.8 (1-7)	Discharge	4.2 (2-7)	(11/12) 3.6(<1-8)	None
	Tritium	36	100.0	(17/24) 1202 (<100-5900)	Discharge	2200 (<100-5900)	(7/12) 158 (<100-290)	None None
Drinking Water (pCi/l)	Gross Beta		1.0		Control lake water and well water are drinking water supplies.			
	Tritium		100.0					
Well Water (pCi/l)	Gross Beta	36	1.0	(9/12) 3.5 (<1-9)	State Park (1 mi N)	5.3 (<1-16)	(18/24) 4.0 (<1-16)	None

- a. Nominal Lower Limit of Detection (LLD) as defined in HASL-300 (Rev 8/73), pages D-08-01, 02, and 03.
- b. Mean and range include nondetectable measurements only. Fraction of detectable measurements at specified locations is indicated in parenthesis.
- c. Nonroutine reported measurements are defined in the Palisades Technical Specifications, Section 6.9.3.2.

TABLE RSD-E-03DHIGH, LOW AND AVERAGE CONCENTRATIONS FOR HIGHEST AVERAGE SAMPLING LOCATIONPALISADES NUCLEAR PLANT

JANUARY 1, 1982 to December 31, 1982

<u>Medium</u>	<u>Type of Analysis(1)</u>	<u>Location</u>	<u>High</u>	<u>Low</u>	<u>Average</u>
Air	Gross Beta	KZ Kalamazoo 35 mi E	$7.0 \cdot 10^{-2}$ pCi/m <sup>3</sup>	$1 \cdot 10^{-2}$ pCi/m <sup>3</sup>	$3.80 \cdot 10^{-2}$ pCi/m <sup>3</sup>
	I-131	LLD	-	-	-
Lake Water	Gross Beta	Discharge	7 pCi/1	2 pCi/1	4.2 pCi/1
	Gross Alpha	Discharge	5 pCi/1	1 pCi/1	1.3 pCi/1
	Tritium	Discharge	5900 pCi/1	100 pCi/1	2200 pCi/c
Drinking Water	Gross Beta	See note on Table RSD-E-03A			
	Tritium	See note on Table RSD-E-03A			
Well Water	Gross Beta	State Park (1 mi n)	16 pCi/1	1 pCi/1	5.3 pCi/1

(1)Minimum detectable level (MDL) = air, gross beta 0.01 pCi/m<sup>3</sup>, I-131 0.02 pCi/m<sup>3</sup>; water, gross beta 1.0 pCi/1, gross alpha 1.0 pCi/1, H-3 100 pCi/1; milk, I-131 0.5 pCi/1, Sr-89 5.0 pCi/1, gamma isotopic 1.0 pCi/1; crops and sediment, gross beta 1.0 pCi/g, Sr-89 0.025 pCi/g, Sr-90 0.005 pCi/g, gamma isotopic 0.05 pCi/g; some samples may have higher MDLs due to sample size.

(2)Samples collected monthly in season.

(3)Two samples per location.

(4)Includes transit dose which averages approximately 6.4 mR/round trip.