

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

June 15, 1984

Dennis M Crutchfield, Chief Operating Reactor Branch No 5 Nuclear Reactor Regulation US Nuclear Regulatory Commission Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 PALISADES PLANT - ENVIRONMENTAL QUALIFICATION OF EQUIPMENT IMPORTANT TO
SAFETY, RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

NRC letter dated May 9, 1984 requested Consumers Power Company to submit additional information regarding Environmental Qualification of Equipment Important to Safety in order to complete the review of that subject. The requests from the May 9, 1984 letter and Consumers Power Company's responses are as follows:

1. Submit all applicable JCO's that are currently being relied upon and certify the following for each JCO associated with equipment that is assumed to fail:

No significant degradation of any safety function or misleading information to the operator as a result of failure of equipment under the accident environment resulting from a design basis event will occur.

Consumers Power Company letter dated February 14, 1984, Attachment 2 provides the list of equipment that Consumers Power Company considers safety related for equipment qualification purposes. This table has been revised to reflect recently replaced equipment and is provided here as Attachment 1. The right hand "status" column of this table states that each piece of equipment is either qualified or it has been scheduled for replacement. Each piece of equipment which is to be replaced has a current JCO associated with it. Each of these JCO's is detailed in Attached 2 to this letter. Consumers Power Company can certify that the failure of equipment will not adversely mislead the operator because he has an alternate qualified means of obtaining the necessary information in order to perform the appropriate safety function.

2. The licensee should certify that in performing its review of the methodology to identify equipment within the scope of 10 CFR 50.49(b)(2) that the following steps have been addressed:



DMCrutchfield, Chief Palisades Plant EEQ - ADDITIONAL INFO June 15, 1984

a. A list was generated of safety-related electric equipment as defined in paragraph (b)(1) of 10 CFR 50.49 required to remain functional during or following design-basis Loss-of-Coolant Accident (LOCA) or High Energy Line Break (HELB) Accidents. The LOCA/HELB accidents are the only design-basis accidents which result in significantly adverse environments to electrical equipment which is required for safe shutdown or accident mitigation. The list was based on reviews of the Final Safety Analysis Report (FSAR), Technical Specifications, Emergency Operating Procedures, Piping and Instrumentation Diagrams (P&IDs), and electrical distribution diagrams;

The table provided in Attachment 1 is the list of safety-related equipment that was generated as defined in paragraph (b)(1) of 10 CFR 50.49. The list was based on reviews of the FSAR, Technical Specifications, Emergency Operating Procedures, P&IDs and numerous other procedures and design documents including the Plant Q-list. The original list has been revised several times to incorporate and delete equipment which resulted from plant modifications for TMI and other reasons.

b. The elementary wiring diagrams of the safety-related electrical equipment identified in Step a were reviewed to identify any auxiliary devices electrically connected directly into the control or power circuitry of the safety-related equipment (e.g., automatic trips) whose failure due to postulated environmental conditions could prevent required operation of the safety-related equipment;

A review of all wiring diagrams of electrical components environmentally qualified was completed by Consumers Power Company for the Palisades Plant. Five schemes were identified containing a combination of qualified and not qualified components served off the same fuse. Each of these schemes involves solenoid valve operators and valve position switches. During the present refueling outage Consumers Power Company modified each of the identified circuits to provide primary and secondary protection of the qualified circuits from unqualified device failure. This was achieved by separately fusing all unqualified devices. These fuses have been sized to clear any faults prior to losing the common supply fuse or breaker.

c. The operation of the safety-related systems and equipment were reviewed to identify any directly mechanically connected auxiliary systems with electrical components which are necessary for the required operation of the safety-related equipment (e.g., cooling water or lubricating systems).

The operation of all support systems and equipment either directly or indirectly connected were reviewed and the equipment was included on the qualification list as appropriate. This included room ventilation, component cooling, etc.

DMCrutchfield, Chief Palisades Plant EEQ - ADDITIONAL INFO June 15, 1984

> d. Nonsafety-related electrical circuits indirectly associated with the electrically equipment identified in Step a by common power supply or physical proximity were considered by a review of the electrical design including the use of applicable industry standards (e.g., IEEE, NEMA, ANSI, UL, and NEC) and the use of properly coordinated protective relays, circuit breakers, and fuses for electrical fault protection.

All safety-related qualified equipment is electrically isolated via properly coordinated protective relays, circuit breakers, and/or fuses in accordance with applicable industry standards and NRC regulations.

3. Provide certification that all design basis events which could potentially result in a harsh environment, including flooding outside containment, were addressed in identifying safety-related electrical equipment within the scope of 10 CFR 50.49(b)(1).

The following is a quote from page 2 of the Consumers Power Company submittal to the NRC dated February 14, 1984.

The NRC staff requested that Consumers Power Company confirm that all design basis events at the Palisades Plant which could result in a potentially harsh environment, including flooding outside containment, were addressed in identifying safety-related electrical equipment which has to be environmentally qualified.

Consumers Power Company Equipment Qualification submittal dated September 1, 1981 provided a detailed summary of the design basis events that were considered in the selection of safety-related electrical equipment which has to be environmentally qualified. The following design-basis accidents were considered in the equipment selection: LOCA and MSLB inside containment (reference FSAR Chapter 14 and SEP Topic VI-3 "Containment Pressure and Heat Removal Capability"), MSLB outside containment (reference Special Report No 6 "Analysis of Postulated High Energy Line Breaks Outside of Containment", June 30, 1975) and flooding outside containment (reference SEP Topic IX-3 "Station Service and Cooling Water Systems - SER dated February 22, 1982").

Brian D Johnson

Staff Licensing Engineer

CC Administrator, Region III, USNRC NRC Resident Inspector - Palisades

Attachment

ATTACHMENT 1
CONSUMERS POWER COMPANY
PALISADES PLANT - DOCKET 50-255
EEQ ADDITIONAL INFORMATION
LIST OF EQUIPMENT AND REFERENCES

ELECTRICAL EQUIPMENT QUALIFICATION - PALISADES Response to NRC Safety Evaluation Report - Enclosure 2

Table 2.1 - List of Equipment and References

Qualification Specification	Revision	Manufacturer	Model/Type	Equipment ID	Status(3)
<u>Cable</u>					
E-48 CABLE-1	2	GE	XLPE, PVC	Z62,Z63 Z62,Z63,Z66	Qualified Qualified
E-48 CABLE-2	3	GE	XLPE, Neoprene	143,147,149, P10,P12	Qualified
				214,143,147,149, P10,P12,092	Qualified
				142,145	Qualified
E-48 CABLE-3	1	GE	Butyl, PVC	S04	Qualified
E-48 CABLE-4	1	Okonite	0ko lon	P08, P09	Qualified
E-48 CABLE-5	2	Okonite	Neoprene	L01,P10	Qualified
				214,314,514	Qualified
E-48 CABLE-6					Delete (Note 13)
E-48 CABLE-7	1	Anaconda	EPR	214,314,514	`Qualified
E-48 CABLE-8	2	Rockbestos	Firewall III	214	Qualified
			XLPE, Neoprene	214	Qualified
E-48 CABLE-9	1	Rockbestos	Firewall III XLPE,Neoprene	191	Qualified
E-48 CABLE-10					Delete (Note 13)
E-48 CABLE-11	2	Rome	XLPE, PVC	142,145	Qualified
				143,147,149	Qualified
				143,147,149, 092,152	Qualified
				X21-X25	Qualified
E-48 CABLE-12	2	Times Wire	Polyethylene, PVC	ZCX	Qualified

Qualification Specification	Revision	Manufacturer	Mode!/Type	Equipment ID	Status(3)
E-48 CABLE-13	2	Moore	1890-9	T26	Qualified
E-48 CABLE-15					Delete (Note 13)
E-48 CABLE-16	1	Boston Ins Wire	EP/CSPE	126	
E-48 CABLE-17	1	Anaconda- Ericcson	FR-EP/CPE Power, Control and Instrument Cable	P10,345,184	Qualified
E-48 CABLE-18	1	Rockbestos	600 V Power Control XLPolyolefin Neo Jkt	122,245,P10	Qualified
E-48 CABLE-19	1	Samuel Moore	EPDM/Hypalon Instrument Cable		Qualified
E-48 CABLE-20	1	Rockbestos	600 V Power Control and Instrument Cable XLPoly Ins Neo Jkt	For Celmark Connectors	Qualified
E-48 CABLE-21	2	Brand-Rex	RG-59 B/U CS 75146		Qualified 1
E-48 CABLE-22	3	Anaconda Co	FR-EP/CPE		Qualified 1
E-48 CABLE-23	0	Boston Ins Wire	Shielded Multi- Conductor Cable		Qualified 1
2400 V Motors					
E-48 EMA-1	0	Louis-Allis	COGX	EMA-1208,1116, 1109(CCW)	Qualified
E-48 EMA-2	0	Louis-Allis	COGX	EMA-1210,1112, 1114(CS)	Qualified
E-48 EMA-3	0	Westinghouse	68F13512	EMA-1113,1207 (HPSI) 1209 (Aux Fd)	Qualified
E-48 EMA-4	0	GE	5K818847A100	EMA-1111 (LPSI)	Qualified
E-48 EMA-5	0	GE	5K818849C56	EMA-1206 (LPSI)	Qualified

Qualification Specification	<u>Revision</u>		Model/Type	Equipment ID	Status(3)
480 V Motors					
E-48 EMB-1	1	GE	5K405YK232	EMB-1208,1209, 1210,1108 (Containment Air Coolers)	Qualified
E-48 EMB-2	0	GE	5K256YK161	EMB-0131,0133,0211, 0221 (ESF Air Coolers)	Qualified
E-48 EMB-3					Delete (Note 17)
E-48 EMB-4	0	Reliance	11F06	EMB-2123,2423 (H2 Monitor Pumps)	Qualified
Electrical <u>Penetrations</u>					
E-48 EZ-1	1	Viking Ind	5 kV (Unpotted Non-1E Con- nectors)	P1, P2	Qualified
E-48 EZ-2	1	Viking Ind	600 V (Potted 1E Connectors Silicone Rubber Cable Ins)	P4, P5, P6, I1, I3, C1	Qualified
E-48 EZ-3	1	Viking Ind	600 V (Unpotted Non-1E Con- nectors)	P3, P4, P5, P6, C1, C2, I1, I2, I3, N1	Qualified
E-48 EZ-4	0	Viking Ind	600 V (Potted 1E Connectors, Polyethylene Rubber Cable Ins)	N1	Qualified
E-48 EZ-5	1	Viking Ind	600 V (Unpotted	C1,C2	Qualified
			1E Connectors)	11,13	Qualified
				` N1	Qualified
Miscellaneous Electrical					
E-48 MISC-1					Delete (Note 14)
E-48 MISC-2					Delete (Note 8)
E-48 MISC-3	0	Westinghouse	Α	M69A,B (H2 Recombiner)	Qualified

Qualification Specification	Revision	<u>Manufacturer</u>	Model/Type	Equipment ID	Status(3)
E-48 MISC-4	1	Celmark	21-0006-3012 21-0006-1916 21-0006-1912 21-0006-8016		Qualified 1
E-48 MISC-5	0	Conax	N-11003		Qualified 1
E-48 MISC-6	1	Control Products Division	Buchanan Type NQB		Qualified 1
E-48 MISC-7	1	States Co	ZWM		Qualified 1
E-48 MISC-8		-			Delete (Note 11)
E-48 MISC-9	0	Raychem			Qualified 1
E-48 MISC-10	2	Comsip, Inc	Deiphi, K-III		Qualified 1
E-48 MISC-11	0	Raychem	WCSF-70-6N, WCSF-115-6N		Qualified
E-48 MISC-12	0	Delphi Inst	B-5	AE-2401L,R	Qualified
E-48 MISC-13	0 .	Comsip	CD-9004-1	ASH-2401L,R	Qualified
E-48 MISC-14	0	Comsip	CD-2004-1	ASHH-2401L,R, ASL-2401L,R	Qualified
E-48 MISC-15	0	Nelson Elec	Catalog Number QA838K01207	Heat Trace Cable	Qualified
Solenoid Valves					
E-48 SV-1	1	ASC0	206-381-3RF	SV-0947,0948, 0949,0950,0951	Qualified 1
E-48. SV-2	2	ASCO .	206-381-3RF	SV-0879,0880, 0913	Qualified 1
E-48 SV-3	1	ASCO	206-381 - 3RF	SV-0738,0739, 0767,0768, 0770,0771	Qualified 1
E-48 SV-4	3	ASCO	NP 831654E	SV-0861,0862, 0864,0865,0867, 0869,0870,0873	Qualified
E-48 SV-5	2	ASCO	X206-381-3VF	SV-2113,2115	Qualified 1
			NP8320A185V ,	SV-2117	Qualified 1

Qualification Specification	Revision	<u> Manufacturer</u>	<u>Model/Type</u>	Equipment ID	Status(3)
E-48 SV-6	1	ASC0	NPX831654E	SV-0847,0937, 0938,0944A, 0910,0911,0940, 0945,0946	Qualified 1
			206-381-3RF	SV-1038,1044, 1045	Qualified 1
				SV-0155,0825, 0878,0939,1001, 1004,1064,1065, 1002,1007,1036, 1101,1102,1103, 1104,1358,1501, 1502,1503,2009, 2083	
	1	ASCO	X206-381-3RF	SV-1037,1001,1004, 1064,1065	Qualified 1
E-48 SV-7	2	ASCO	NPX831654E	SV-0845,0876,0877, 0844,0857	Qualified 1
			NPX831654E	SV-0846	Qualified 1
E-48 SV-8	1	ASC0	NPX8320A185V	SV-3001,3002	Qualified 1
			NP8316A74E	SV-3030B	Qualified 1
			NPX8316A74E	SV-3018,3036, 3059,3070, 3071,3212B	Qualified 1
			NPX8316A76E	SV-3027B,3057B	Qualified 1
			NP8316E34E	SV-3029B	Qualified 1
		-	NPX8316E34E	SV-3031A,3037, 3055B,3056B 3057A,3213A, 3223A,3224B	Qualified 1
			NP8316E36E	SV-3027A,3029A, 3030A,3031B, 3055A,3056A, 3212A,3213B, 3224A	Qualified 1
			NPX8316E36E	SV~3223B	Qualified 1
E-48 SV-9	2	ASCO	NPX831654E	SV-0824	Qualified 1
E-48 SV-10	2	ASCO	NPX8320A183E	SV-0522A	Qualified 1

Qualification Specification	Revision	Manufacturer	Model/Type	Equipment ID	Status(3)
E-48 SV-11	1	ASCO _	NP8320A185V	SV-0438A,0438B	Qualified 1
E-48 SV-12	1	ASC0	NPX8320A184E	SV-1910,1911	Qualified 1
E-48 SV-13	1	ASCO	NPX8320A184E	SV-1901,1902, 1903,1904,1905	Qualified 1
E-48 SV-14	1	ASCO	206-381-3RF	SV-3069,0338, 0342,0346,0347	Qualified 1
E-48 SV-15					Delete (Note 12)
E-48 SV-16	0	Target Rock	81QQ-001	SV-2412A,B, SV-2413A,B, 2414A,B 2415A,B	Qualified 1
E-48 SV-17	2	ASC0	NP8321A6E	SV-1813,1814	Qualified
E-48 SV-18	2	ASCO	NP831655E	SV-1805,1806, 1807,1808	Qualified 1
E-48 SV-19	· 1	ASC0	NP8320A185V	SV-3084,3085	Qualified 1
E-48 SV-20	0	Target Rock	80B-001 - 5	PRV-1067,1068,1069, 1070,1071,1072	Qualified 1
E-48 SV-21	0	ASCO	THT-8262C7N	SV-2418L,R, SV-2419L,R	Qualified
E-48 SV-22	. 0	ASCO	THT-8262A138N	SV-2420L,R	Qualified
E-48 SV-23	0	Target Rock	81QQ-002	SV-2424A,B	Qualified
Motor- Operated Valves					
E-48 MOV-1	2	Limitorque	SMB-00-15	MO-3007,3009, 3011,3013, 3062,3064, 3066,3068	Qualified
E-48 MOV-1	2	Limitorque	SMB-3-100	MO-3012,3010, 3014	Qualified
			SMB-3-100	MO-3008	Qualified
			SMB-2-60	MO-3015,3016	Qualified
E-48 MOV-2	1	Limitorque	SMB-0-25	MO-3189,3190, 3198,3199	Qualified 1
E-48 MOV-3	2	Limitorque	SMB-0-025	MO-3080,3081	Qualified 1

Qualification				•	
Specification	Revision	<u>Manufacturer</u>	Model/Type	Equipment ID	Status(3)
E-48 MOV-4	2	Limitorque	SMB-00-10	MO-3032,3083	Qualified 1
E-48 MOV-5	0	Limitorque	SMB-00-10	MO-0743,0753, 0760,0798	Qualified
E-48 MOV-6	0	Limitorque	SMB-00-10	MO-0748,0754, 0755,0759	Qualified
Electropneumatic Converters					
J-48 E/P-2	2	Fischer Controls	E/P-546	E/P-1057,1059	Qualified
J-48 E/P-3	1	Masoneilan	8012	E/P-3025	Qualified
J-48 E/P-4	1	Fisher Controls	E/P-546	E/P-0736A,0737A	Qualified
Flow Transmitters					
J-48 FT-1	1	Rosemount	1153HA7	FT-0316,0317	Qualified 1
J-48 FT-2	3	Rosemount	1152-DP4 A22PB	FT-0736A, FT-0737A	Qualified 1
J-48 FT-3	1	Rosemount	1152-DP4 A22	FT-0736,0737	Qualified 1
J-48 FT-3	0	Rosemount	1153DB5	FT-0727,0727A 0749,0749A	Qualified
Current Converters		·			
J-48 I/P-1	0	ITT/Conflow	GT25CA1826	1/P-0727,0749	Qualified
J-48 1/P-2	0	ITT/Conflow	GT25CA1826	I/P-0736A,0737A	Qualified
Level Elements					
J-48 LE-1	1	Transamerica	XM-54852A	LE-0446A,0446B	Qualified 1
<u>Level Switches</u>					
J-48 LS-1					Delete (Note 17)
<u>Level Transmitters</u>					
J-48 LT-1					Delete (Note 10)
J-48 LT-2				ı	Delete (Note 9)
J-48 LT-3	1	Foxboro	613DM	LT-0751A,B,C,D, 0752A,B,C,D	Replace-1

Qualification Specification	<u>Revision</u>	Manufacturer	Model/Type	Equipment ID	Status(3)
J-48 LT-4	1	Fo×boro	613HM	LT-0103	Replace-1
J-48 LT-5	1	Fischer & Porter	13D2465BA	LT-0701,0702, 0703,0704	Replace-1
J-48 LT-6	2	Rosemount	1152DP4A22	LT-0383,0382	Qualified 1
J-48 LT-7	0	Rosemount	1153DD5	LT-0757A, B 0758A, B	Qualified :
Neutron Detectors					
J-48 NI-1					Delete (Note 14)
Position and <u>Limit Switches</u>		·			
J-48 POS-1	0	Namco	EA-080-11100	POS-0522A	Qualified
J-48 POS-2	1	Namco	EA-170-31100	POS-0438A,0438B	Qualified
J-48 POS-3	1	Honeywell	OP-AR	POS-0824	Qualified k
J-48 POS-4	0	Honeywell	BZE-2RN	POS-1103,1104	Qualified
J-48 POS-5					Delete (Note 15)
J-48 POS-6	0	Honeywell	BZE-2RN,EXD-Q OPD-AR,BZE-2RN BZE-2RN,EXD-Q BZE-2RN,OPD-AR BZE-2RN,OPD-AR	POS-1036 POS-1002,1007 POS-1038 POS-1044 POS-1045	Qualified (Note 15)
J-48 POS-7	0	Honeywell	LSQ-051	POS-3027A, 3056A	Qualified
J-48 POS-8	0	Honeywell	BZE-2RN	POS-3031A,3057B, 3212A,3212B	Qualified
J-48 POS-9	0	Namco	D2400-1SR	POS-3029A	Qualified
			D2400X-1SR	POS-3031B,3030B	Qualified
J-48 POS-10	0	Namco	EA-170-31100	POS-0437A,B	Qualified
J-48 POS-11	0	Honeywell	OP-AR	POS-0847	Qualified
J-48 POS-12	0	Honeywell	OP-AR	POS-0823,0826	Qualified
J-48 POS-13	0	Honeywell	OP-AR	POS-0879,0880	Qualified
J-48 POS-14	0	Honeywell	OP-AR	POS-0844,0845,0846, 0857,0876,0877	Qualified

Qualification Specification	Revision	Manufacturer	Model/Type	Equipment ID	Status(3)
J-48 POS-15	0	Honeywell	BZE-2RN	POS-0738,0739,0767,	Qualified
			BZE6-2RN	0768,0771 POS-0770	·
J-48 POS-16	0	Honeywell	1LS1	POS-3018,3036,3037, 3059,3027B,3056B	Replace
J-48 POS-17	0 .	Honeywell	BZE6-2RN	POS-3070,3071,3213A, 3213B,3223A,3223B, 3224A,3224B,3030A, 3029B,3055A,3055B	Qualified
J-48 POS-18	1	Honeywell	OPD-AR	POS-3057A	Qualified
J-48 POS-19	0	Honeywell	OP-AR	POS-2117,2113,2115, 0861,0862,0864,0865, 0867,0869,0870,0873	Replace
J-48 POS-20	0	Namco	EA-170-31302	POS-1805,1806,1807, 1808	Qualified
J-48 POS-21	0	Honeywell	OP-AR BZE-2RN OP-AR	POS-0825,0878,0910 0911,0940,0913 POS-0939 POS-0944A,0945,0946, 0937,0938	Qualified
J-48 POS-22	0	Honeywell	OP-AR	POS-0947,0948,0949, 0950,0951,0977B	Qualified
J-48 POS-23	0	Namco	EA-180-11302 EA-180-12302	POS-0727,0749	Qualified
J-48 POS-24	0	Namco	EA-180-11302 EA-180-12302	POS-0736A,0737A	Qualified
Pressure Switches					
J-48 PS-1	1	United Electric	J-302-553	PS-1801,01A,02, 02A,03,03A,04,04A	Qualified
J-48 PS-2	0	Static-O-Ring	4N3-K5-MX-C1A	PS-2401L,R 2402L,R	Qualified
J-48 PS-3	0	Static-O-Ring	54N3-K411-MX-C1A	PS-2403L,R	Qualified
J-48 PS-4	0	Bailey Controls	745210AAAN2	PS-0762A,B,C	Qualified
Pressure <u>Transmitters</u>		·	•		
J-48 PT-1	1	Fischer & Porter	50EP1072A	PT-0306	Replace-1

Qualification Specification	<u>Revision</u>	Manufacturer	Model/Type	Equipment ID	Status(3)
J-48 PT-2	1	Fischer & Porter	50EP1021ACX 50EP1071ACX	PT-1812,1815 PT-1805,1814	Qualified Qualified
J-48 PT-3					Delete (Note 16)
J-48 PT-4	3	Rosemount	1153GD9PA	PT-0102A,B,C,D	Qualified
J-48 PT-5	0	Foxboro	611GM	PT-0752A,B,C,D, 0751A,B,C,D	Replace-1
J-48 PT-6	1	Rosemount	1153GA9	PT-0105A,B	Qualified
J-48 PT-7	1	Rosemount	1153GA9	PT-0377	Qualified 1
J-48 PT-8	1	Rosemount	1152AP7A22	PT-1812A,1805A	Qualified 1
J-48 PT-9	0	Rosemount	1153AB5	PT-0762A,B,C	Qualified
J-48 PT-10	0	Rosemount	1153GB9	PT-0750	Qualified
Radiation <u>Monitors</u>					
J-48 RE-1	2	Victoreen	847-1	RE-1805,1806, 1807,1808	Replace-1
J-48 RE-2	1	Victoreen	877-1	RE-2321,2322	Qualified 1
Temperature <u>Elements</u>					
J-48 TE-1	1	Rosemount	104-VCX	TE-0112,0122CA, CB,CC,CD,HA,HB, HC,HD TE-0111,A,B,H TE-0121,A,B,H	Replace-1
Temperature Switches					
J - 48 TS-1	0	Johnson	T-7170	TS-1849,1850, 1851,1852,1856, 1857,1858,1859	Replace-1
J-48 TS-2	0	Fenwell	22000	TS-2401L,R	Qualified
J-48 TS-3	0	Nelson/ United Electric	TH-4X65	TS-2401A,B, 2402A,B, 2403,2404	Qualified

⁽¹⁾ Technical Evaluation Report, Equipment Environmental Qualification, Consumers Power Company Palisades Plant, Franklin Research Center, December 30,1982.

- (2) Environmental Qualification of Safety-Related Electrical Equipment, Palisades Plant, September 1980. Transmitted to the NRC October 7, 1980 and revised October 30, 1980 and June 11, 1981.
- (3) Qualified: Qualified under DORGR subject to applicable surveillance and preventive maintenance to detect and correct possible aging. Entire component or parts may be replaced as part of the preventive maintenance program.
 - Qualified 1: New equipment installed at the plant as a result of the TMI action plan, qualification commitment or plant replacement program. This equipment has not been reviewed in the SER or TER.
 - Replace-1: Consumers Power Company committed to replace in the October 7, 1980 submittal. Continued operation is justified.
 - Replace-2: Consumers Power Company committed to replace in the September 3, 1981 submittal. Continued operation is justified.
- (4) Controls to protect the safety injection tanks from overpressurization by leakage through the PCS and SI tank check valves. These were removed from the harsh environment list for reasons given on Page 399 of the 1980 Equipment Qualification Report. Failure of these controls following an accident would be of insignificant consequences.
- (5) Feedwater flow control instruments. The flow and pressure transmitters were removed from the list because the level transmitters are sufficient to prevent overfilling the steam generators. See J-48 LT-5.
- (8) The Westinghouse terminal blocks in J350, J355 and J521 were replaced with States Company terminal blocks type ZWM. See MISC-7 for qualification of ZWM terminal blocks. MISC-2 has been deleted.
- (9) Both LT-1107 and LT-1110 are located in Room 123 which experiences only MSLB. These LTs are used for LOCA only; therefore, they are in a mild environment and should be removed from this book.
- (10) The function of these transmitters, containment sump level, has been replaced by the equipment listed in LT-6 and LE-1. Therefore, LT-1 has been deleted.
- (11) The qualification of states, Control Products Div, Raychem and Rockbestos are adequately addressed by other specification numbers. Therefore, MISC-8 has been deleted. (12) This equipment is used only when it is in a mild environment. Therefore, it is being removed from the list.
- (12) This equipment is used only when it is in a mild environment. Therefore, it is being removed from the list.
- (13) An outage walkdown showed that none of qualified equipment is connected to this type of cable. Therefore, it is being removed from the list.
- (14) It has been determined that the neutron monitors (NI-1) and their connector (MISC-1) are not required to mitigate a LOCA or MSLB. Therefore, this equipment is being removed from the list.
- (15) POS-3001, 3002 (POS-5) and POS-1501, 1502, 1503, 2009, 2083, 1358, 1813, 1814, 0155, 1001, 1004, 1037, 1064, 1065, 1101, 1102, 1910, 1911, 0437A and 0437B (POS-6) are all located in a mild environment. Therefore, this equipment is being removed from the list.
- (16) The pressurizer wide-range pressure indicator was disconnected from PT-0103 and connected to PT-0105B (PT-6). Therefore, this equipment is being removed from the list.
- (17) The ESF room sump pumps and level switches have been deleted. See letter to NRC dated 4/30/84 concerning NUREG-0737, Item III.D.1.1 Integrity of Systems Outside Containment.

ATTACHMENT 2
CONSUMERS POWER COMPANY
PALISADES PLANT - DOCKET 50-255
EEQ ADDITIONAL INFORMATION
JUSTIFICATIONS FOR CONTINUED OPERATION (JCOs)

Justifications for Continued Operation for equipment identified in Attachment l as being replaced.

J-48 LT-3

Equipment ID: LT-0751A, B, C, D, 0752A, B, C, D

Function: Steam Generator Level/Reactor Trip

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A Criteria:

- 1. Redundant equipment is available to substitute for the unqualified equipment.
- 3. The unqualified equipment will have performed its primary function, reactor trip, prior to failure.

J-48 LT-4

Equipment ID: LT-0103

Function: Pressurizer Level

JCO: This transmitter does not perform a safety function required to mitigate the effects of an accident. It is used, however, to minimize the flow of charging water to the containment floor for MSLBs and small break LOCAs. This in turn will minimize cleanup efforts after an accident and in the case of MSLB will allow the PCS to remain intact at all times. Therefore, the existing transmitter does not have to be qualified and no JCO is required. However, Comsumers Power Company still intends to replace this transmitter with a new qualified one.

J-48 LT-5

Equipment ID: LT-0701, 0702, 0703, 0704

Function: Steam Generator Level/Feedwater Control

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

- 1. Redundant equipment is available to substitute for the unqualified equipment.
- 3. The unqualified equipment will have performed its primary function, feedwater trip, prior to failure.

J-48 POS-16

POS-3018, 3036, 3037, 3059, 3027B, 3056B Equipment ID:

Function: Position Indication-Safety Injection & Shutdown Cooling/SIRW Tank

Level Control

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

1. Redundant equipment is available to substitute for the unqualified equipment.

The unqualified equipment will have performed its primary 3. function prior to failure.

J-48 POS-19

Equipment ID: POS-2117, 2113, 2115, 0861, 0862, 0864, POS-0865, 0867, 0869, 0870, 0873

Position Indication-Pressurizer Spray Valve, Charging System Stop Function: Valve, Service Water for Containment Air Valve

JCO: POS-2113, 2115 - Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

Redundant equipment is available to substitute for the 1. unqualified equipment.

POS-2117 - Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

Redundant equipment is available to substitute for the 1. unqualified equipment.

POS-0861 thru 0873 - Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

3. The unqualified equipment will have performed its primary function prior to failure.

J-48 PT-1

Equipment ID: PT-0306

Function: Pressure Transmitter/Low-Pressure Safety Injection Discharge Pressure

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

2. Another system is capable of providing the required function of the system with unqualified equipment.

J-48 PT-5

Equipment ID:

PT-0751A,B,C,D, 0752A,B,C,D

Function:

Steam Generator Pressure/Reactor Trip

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

3. The unqualified equipment will have performed its primary function, reactor trip, prior to failure.

J-48 RE-1

Equipment ID:

RE-1805, 1806, 1807, 1808

Function:

Radiation Monitors/Containment Isolation

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

3. The unqualified equipment will have performed its primary function, containment isolation, prior to failure.

J-48 TE-1

Equipment ID:

TE-0112, 0122CA,CB,CC,CD,HA,HB,HC,HD

TE-0111A,B,H TE-0121A,B,H

Function:

Primary Coolant Temperature Elements

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

- Redundant equipment is available to substitute for the unqualified equipment.
- 3. The unqualified equipment will have performed its safety function prior to failure.

J-48 TS-1

Equipment ID:

TS-1849, 1850, 1851, 1852, 1856, 1857, 1858, 1859

Function:

ESF Room Air Cooler Thermostats

JCO: Interim operation is justified in lieu of qualified equipment based on the following FRC Appendix A criteria:

1. Redundant equipment is available to substitute for the unqualified equipment.