

Consumers Power Company

Palisades Plant - Docket 50-255

TECHNICAL SPECIFICATION CHANGE REQUEST

PROPOSED PAGE

8408100138 840806
PDR ADOCK 05000255
PDR

1 Page

TS0784-0001B-NL02

6.5.1.6 Responsibilities (Continued)

- i. Review of events requiring 24-hour written notification to the Commission.

PRC review may be performed through a routing of the item subject to the requirements of Specification 6.5.1.7.

6.5.1.7 Authority

The PRC shall:

- a. Recommend in writing to the Plant General Manager approval or disapproval of items considered under Specifications 6.5.1.6.a. through d. above.
- b. Render determinations in writing with regard to whether or not each item considered under specifications 6.5.1.6.a. through e. above constitutes an unreviewed safety question.
- c. Provide written notification within 24 hours to the Vice President - Nuclear operations and to the Vice Chairman of NSB of any disagreement between the PRC and the Plant General Manager; however, the Plant General Manager shall have responsibility for the resolution of such disagreements pursuant to Specification 6.1.1 above.

The PRC Chairman may recommend to the Plant General Manager approval of those items identified in Specifications 6.5.1.6 a. through d. above based on a routing review provided the following conditions are met: (1) at least five PRC members, including the Chairman and no more than 2 alternates, shall review the item, concur with determinations as to whether or not the item constitutes an unreviewed safety question, and provide written comments on the item; (2) all comments shall be resolved to the satisfaction of the reviewers providing the comments; and (3) if the PRC Chairman determines that the comments are significant, the item (including comments and resolutions) shall be recirculated to all reviewers for additional comments.

The item shall be reviewed at a PRC meeting in the event that: (1) comments are not resolved; or (2) the Plant General Manager overrides the recommendations of the PRC; or (3) a proposed change to the Technical Specifications involves a safety limit, a limiting safety system setting or a limiting condition of operation; or (4) the item was reportable to the NRC.