



General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550



FEBRUARY 13, 1985

James G Keppler, Administrator Region III US Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -PALISADES PLANT - REACTOR INTERNALS NOISE MONITORING TESTS

Palisades Plant Technical Specification 4.13.D.3 requires the results of the Reactor Internals Noise Monitoring Tests to be submitted to the NRC Region III office on an annual basis.

The results of the test demonstrates the reactor core barrel is tightly clamped with no other anomalous vibrations occurring during the testing period. The attached test fulfills the requirement of the subject Technical Specification.

Brian D Johnson

Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation Director, Office of Inspection and Enforcement NRC Resident Inspector - Palisades

FEB 1 9 1985 IEO/ 1