



**Consumers  
Power  
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

May 1, 1985

Director,  
Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 -  
PALISADES PLANT - SUPPLEMENTAL RESPONSE TO GENERIC LETTER 83-28 ISSUE 2.1 AND  
ISSUE 3.2

Consumers Power Company letter dated February 19, 1985 and entitled "Palisades Plant - Revised Schedule For Completion of Actions Required by Generic Letter 83-28" transmitted Consumers Power Company's plan and schedule for completion of the remaining open issues of Generic Letter 83-28. In that correspondence commitments were made to address the Equipment Classification portion of Issue 2.1 as well as Issue 3.2 regarding Post Maintenance Testing by May 1, 1985. Statements confirming the completion of these actions are provided herein.

Item 1

Issue 2.1 Equipment Classification and Vendor Interface  
(Reactor Trip System Components)

Consumers Power Company will conduct a review of the reactor trip system components to verify that each component is specifically identified as being safety related. A statement confirming the completion of this activity will be submitted by May 1, 1985.

Response

The identified activity has been completed as stated.

Item 2

Issue 3.2 Post Maintenance Testing (All Other Safety Related Components)

Palisades Plant Administrative Procedures will be revised to specifically require post maintenance operability testing of safety related equipment

8505060100	850501
PDR	ADOCK 05000255
P	PDR

OC0485-0009B-NL02

A055  
1/0

Director, NRR  
Palisades Plant  
Supplement to GL 83-28  
May 1, 1985

2

following any maintenance activity which has the potential to affect equipment operability. Additionally, test and maintenance procedures are currently reviewed at least every two years to ensure that appropriate content is maintained. This review process will be upgraded to specifically require a review of applicable vendor and engineering recommendations for inclusion in the procedures as appropriate. A statement confirming the completion of these activities will be submitted by May 1, 1985.

Response

The identified actions have been completed as stated.



Brian D Johnson  
Staff Licensing Engineer

CC Administrator, Region III, USNRC  
NRC Resident Inspector - Palisades