



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

April 30, 1985

Director,
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT -
PROPOSED TECHNICAL SPECIFICATION CHANGE REQUEST - PRIMARY
COOLANT SYSTEM LEAKAGE LIMIT

Attached are three (3) originals and thirty-seven (37) conformed copies of a Request for Change to the Palisades Technical Specifications. The attached proposed change to the Palisades Technical Specifications provides clarifications and deletions to existing Technical Specification 3.15. The proposed changes are consistent with Standard Technical Specifications in that a time period is provided to evaluate and identify the leakage. The intent of the change is to reduce unnecessary reporting requirements since the existing generic limiting condition for operation requires formal USNRC reporting within 1 hours. The change does not impact existing hot shutdown or cold shutdown requirements in the event that the leakage remains uncorrected. Specifications remain intact to require hot shutdown condition within 12 hours and cold shutdown condition within 24 hours.

Pursuant to 10CFR170.21, a check in the amount of \$150 is attached.

David J. Vandewalle
David J. Vandewalle
Director, Nuclear Licensing

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

Attachment

8505070127	850430
PDR	ADOCK 05000255
P	PDR

OC0485-0184A-NL04

*A001
3/37
Rec'd w/ check \$150.00
#462222*