


LIGHTED STANDBY SET UP PUSHBUTTON

CONTACTS (HANDLE END)	POSITIONS			
	CLOSE	NORM. AFTER CLOSE	AFTER TRIP	TRIP
1				X
2				X
3			X	
4	X		X	
5	X	X		
6	X	X		

CONTROL SWITCH 152-204 & 152-205
CS CS

G. E. TYPE SP4. SPRING RETURN * - NOT USED
LOCATION C08R



NOTES
1. SEE DWG. E-154 SH. 2 FOR ALARMS, BLOCK DIAGRAM & INTERLOCKS.

9	89	REVISED PER DWG. E-154 SH. 1	9/82						
---	----	------------------------------	------	--	--	--	--	--	--

INFORMATION ONLY

SERVICE WATER PUMP P7A
SCHEME A1204

ADAPTER TABLE

DESCRIPTION	ACB		SCHEME	LOAD SHED RELAY			SIS RELAY			DISCH. PRESS SW. INTERLOCK		BUS U.V. RELAY		SEQUENCERS				LOCATION	LTC REL. L20	P.S. JUNCTION BOX			
	NO.	LOC.		194-	CONT.	LOC.	SIS-	CONT.	LOC.	PS/	127X-	CONT.	08-34	NORM SHDN	TEST IND.	15-16	V16-				LOC.		
SERVICE WATER PUMP P7A	152-204	A12	A1204	211	1 & 2	A12	X6	5	C13R	1319	1320	21	1 & 2	21	34-6/3	204	2/3	2/7	C13R	C08R	M04	15	J14A & J14R
SERVICE WATER PUMP P7B	152-103	A11	A1103	108	3 & 4	A11	X7	1	C12L	1318	1325	11	3 & 4	1/9	34-5/3	103	1/3	1/7	C13L	C08L	M03	14	J14L

PALISADES PLANT
CONSUMERS POWER COMPANY

SCHEMATIC DIAGRAM
SERVICE WATER PUMPS

0950 8-E-154 SH. 1 9

8512090197