

April 22, 1986

Dec 016

Docket No. 50-255

Mr. Kenneth W. Berry
Director, Nuclear Licensing
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Dear Mr. Berry:

SUBJECT: GENERIC LETTER 83-28, ITEMS 3.1.3 AND 3.2.3
(POST MAINTENANCE TESTING) PALISADES PLANT

By letter dated July 26, 1985, you informed us that the Palisades Technical Specifications do not contain specific post-maintenance testing requirements and, therefore, the two subject items which relate to that issue are not applicable to Palisades. In previous submittals, you had informed us that the post maintenance testing at Palisades Plant was controlled by Administrative Procedures and you described your review of those procedures in response to the other parts of Items 3.1 and 3.2. We found that response acceptable and so informed you by letter dated August 15, 1985. Since you demonstrate post maintenance operability of components prior to returning them to service and the Technical Specifications do not require additional testing, we agree that these items are not applicable to Palisades Plant and are, therefore, satisfactorily closed.

Sincerely,

/s/

Thomas V. Wambach, Project Manager
PWR Project Directorate #8
Division of PWR Licensing-B

cc: See next page

Distribution:

Docket File	EJordan	ACRS 10
NRC & L PDRs	JPartlow	FMiraglia
Branch Files	BGrimes	ATHadani
TWambach	OELD	
PKreutzer		

AT

PWR#8
PKreutzer
4/21/86

PWR#8 *JVM*
TWambach;eh
4/21/86

PWR#8
ATHadani
4/21/86

8604290354	860422
PDR - ADOCK	05000255
P	PDR

Mr. Kenneth W. Berry
Consumers Power Company

Palisades Plant

cc:

M. I. Miller, Esquire
Isham, Lincoln & Beale
51st Floor
Three First National Plaza
Chicago, Illinois 60602

Nuclear Facilities and
Environmental Monitoring
Section Office
Division of Radiological
Health
P.O. Box 30035
Lansing, Michigan 48909

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Jerry Sarno
Township Supervisor
Covert Township
36197 M-140 Highway
Covert, Michigan 49043

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Palisades Plant
ATTN: Mr. Joseph F. Firlit
Plant General Manager
27780 Blue Star Memorial Hwy.
Covert, Michigan 49043

Resident Inspector
c/o U.S. NRC
Palisades Plant
27782 Blue Star Memorial Hwy.
Covert, Michigan 49043