

U. S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No. 50-255/87026(DRSS)

Docket No. 50-255

License No. DPR-20

Licensee: Consumers Power Company
212 West Michigan Avenue
Jackson, MI 49201

Facility Name: Palisades Nuclear Plant


Inspection At: Palisades Site, Covert, Michigan

Inspection Conducted: October 19-23, 1987


Date of Last Physical Security Inspection: April 21 through May 29, 1987

Type of Inspection: Unannounced Physical Security

Inspectors:



B. Drouin
Physical Security Inspector

11/10/87
Date


D. M. Galanti
Physical Security Inspector

Nov 10, 1987
Date

Approved By:


J. R. Creed, Chief
Safeguards Section

11/12/87
Date

Inspection Summary

Inspection on October 19-23, 1987 (Report No. 50-255/87026(DRSS))

Areas Inspected: Security Plan/Implementing Procedures; Management Effectiveness; Security Organization; Security Audit; Records and Reports; Physical Barriers - Protected and Vital Areas; Security System Power Supply; Lighting; Compensatory Measures; Assessment Aids; Access Control - Personnel, Packages and Vehicles; Detection Aids - Protected Area; Alarm Stations; Safeguards Contingency Plan; Protection of Safeguards Information and Licensee Action on Previous Findings.

Results: Seven of eight previous findings were closed. The licensee was in compliance with NRC requirements in 16 of 17 inspected areas. The exception is noted below:

Access Control Personnel: (a) Some visitors were improperly escorted;
(b) Some personnel improperly displayed badges.

8711230405 871118
PDR ADOCK 05000255
PDR
Q

Enclosure contains
SAFEGUARDS INFORMATION
Upon separation this
page is Decontrolled