

NOTICE OF DEVIATION

Consumers Power Company

Docket No. 50-255

Based on the results of the NRC inspection conducted on May 9-13, 18, 31, June 14, 29 and 30, 1988, certain of your activities appear to deviate from your written FSAR commitment to the Commission as indicated below:

Section 12.2.1.12 of the FSAR Update, Revision 3, dated October 30, 1987, states that, "Each Fire Brigade member should participate in each (quarterly) drill but must participate in at least two drills per year."

Contrary to the above, during fire brigade training record review, it was determined that one fire brigade member of shift three only attended one shift drill during calendar year 1987.


This is a Deviation (Supplement 1).

Please provide in writing within 30 days of the date of this Notice: (1) the reason for the deviation; (2) the corrective steps which have been taken and the results achieved; (3) the corrective steps which will be taken to avoid further deviations; and (4) the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

FOR THE NUCLEAR REGULATORY COMMISSION

AUG 8 1988

Dated _____



Hubert J. Miller, Director
Division of Reactor Safety