

Konnoth W Borry Director Nuclear Licensing

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-1636

August 25, 1988

Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT -WITHDRAWAL OF TECHNICAL SPECIFICATIONS CHANGE REQUEST - PRIMARY COOLANT PUMP UPPER FLYWHEEL EXAMINATION WAIVER

Consumers Power Company requests withdrawal of the Technical Specification Change Request concerning the Primary Coolant Pump Upper Flywheel Examination. Due to an administrative error, the subject change, submitted on August 19, 1988, was without the required concurrence by the Nuclear Safety Board Chairman. Subsequent to the submittal, our Nuclear Safety Board determined the change request lacked sufficient technical justification and the 10CFR50.59 evaluation did not properly address the margin of safety.

Although the issues are resolvable, we do not wish to pursue further action on this issue, at this time. We regret and apologize for any inconvenience we may have caused.

Keneth a Beny

Kenneth W Berry Director, Nuclear Licensing

CC Administrator, Region III, NRC NRC Resident Inspector - Palisades

880825