

NRR-DMPSPeM Resource

From: Archambo, Neil G <Neil.Archambo@duke-energy.com>
Sent: Tuesday, April 18, 2017 2:54 PM
To: Morton, Wendell; 'FREGONESE, Victor'; Rahn, David
Subject: [External_Sender] RE: List to Inform RIS Development

Agreed – We need to gain a good understanding and agreement of the scope of SSCs the RIS will apply to.

Neil

From: Morton, Wendell [<mailto:Wendell.Morton@nrc.gov>]
Sent: Tuesday, April 18, 2017 2:49 PM
To: 'FREGONESE, Victor'; Rahn, David; Archambo, Neil G
Subject: RE: List to Inform RIS Development

Vic, Neil,

Thanks for putting this together. I recommend that if its not a problem with either of you, that we have this discussion regarding these systems during Thursday's public meeting. Its important for the staff to get a firm understanding of the target(s) for this RIS clarification. We can always adjust the agenda.

Wendell Morton

Electronics Engineer
Instrumentation, Controls, and Electronics Engineering Branch (ICE)
Office of New Reactors(NRO)
U.S. Nuclear Regulatory Commission
301-415-1658(Office)
301-415-5160(Fax)
Mail Stop: T07-E18M
Wendell.Morton@nrc.gov

From: FREGONESE, Victor [<mailto:vxv@nei.org>]
Sent: Tuesday, April 18, 2017 1:14 PM
To: Morton, Wendell <Wendell.Morton@nrc.gov>; Rahn, David <David.Rahn@nrc.gov>; Neil.Archambo@duke-energy.com
Subject: [External_Sender] List to Inform RIS Development

Wendell and Dave,

Neil and I have been working with our industry team to assess areas where digital upgrades are likely to be performed under 50.59, or are already being performed under 50.59.

We are providing this to you to inform your efforts in developing the new 2017-xxx RIS.

We thought that providing you with this list would be more useful than trying to define a "scope" for the RIS. We believe the "applicability" of the RIS should be consistent with the applicability of the 50.59

process with regard to SSCs, which are those which have a UFSAR described design function (Important to Safety). So, the list below is provided in that context.

We would like to dialogue on this list in a future public meeting.

Systems subject to upgrades under 50.59:

- All SSCs traditionally classified as non-safety related in the UFSAR (Note: This applies to non-safety SSCs that have a UFSAR described design function)
- The following SSCs traditionally treated as Safety Related in the UFSAR
 - EDG controls (governor, voltage regulator, and support systems)
 - EDG Load Sequencers
 - Auxiliary/Emergency Feedwater System Controls
 - Charging/Safety Injection
 - Service Water Systems
 - Essential Bus Protective Relaying
 - Reactor Coolant Pump Under-Voltage/Under-Frequency Protective Relaying
 - Switchyard Protective Relaying (safety related at Ocone)
 - Breakers
 - Inverters
 - HVAC Systems
 - PAM Recorders/Indicators
 - Control Board Indicators
 - Limited Changes To RPS/ESFAS/SSPS (individual card/module changes, end actuating devices, field input devices, changes that fall under the EQIV change process)
 - Timing Relays
 - Pressure/Flow Transmitters
 - Nuclear Instrumentation (Source, Intermediate, and Power Range)
 - Radiation Monitors

This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in error, please notify the sender immediately by telephone or by electronic mail and permanently delete the original message. IRS Circular 230 disclosure: To ensure compliance with requirements imposed by the IRS and other taxing authorities, we inform you that any tax advice contained in this communication (including any attachments) is not intended or written to be used, and cannot be used, for the purpose of (i) avoiding penalties that may be imposed on any taxpayer or (ii) promoting, marketing or recommending to another party any transaction or matter addressed herein.

Sent through www.intermedia.com

Hearing Identifier: NRR_DMPS
Email Number: 204

Mail Envelope Properties (48CDF0E40BAC134B896462F436986B88BC561617)

Subject: [External_Sender] RE: List to Inform RIS Development
Sent Date: 4/18/2017 2:53:56 PM
Received Date: 4/18/2017 2:54:02 PM
From: Archambo, Neil G

Created By: Neil.Archambo@duke-energy.com

Recipients:

"Morton, Wendell" <Wendell.Morton@nrc.gov>
Tracking Status: None
"FREGONESE, Victor" <vxf@nei.org>
Tracking Status: None
"Rahn, David" <David.Rahn@nrc.gov>
Tracking Status: None

Post Office: IMCLTEXCP61.nam.ent.duke-energy.com

Files	Size	Date & Time
MESSAGE	4241	4/18/2017 2:54:02 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: