



Consumers
Power

**POWERING
MICHIGAN'S PROGRESS**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

November 28, 1989

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT -
RESPONSE TO GENERIC LETTER 89-21 STATUS OF UNRESOLVED ISSUE (USI) REQUIREMENTS

This letter provides Consumers Power Company's response to Generic Letter 89-21 for the Palisades Plant. Consumers Power Company has reviewed and reported on, the status of implementation of Unresolved Safety Issues for which a final technical resolution has been achieved and which are applicable to Palisades.

Brian D Johnson
Staff Licensing Engineer

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

Attachment

OC1189-0022-NL02

8912050309 891128
PDR ADOCK 05000255
P FDC

A CMS ENERGY COMPANY

A012
11

ATTACHMENT

Consumers Power Company
Palisades Plant
Docket 50-255

ENCLOSURE 1 FROM GENERIC LETTER 89-21 AND
REMARKS ON UNRESOLVED SAFETY ISSUE RESOLUTION

November 28, 1989

4 Pages

ENCLOSURE 1

UNRESOLVED SAFETY ISSUES FOR WHICH A FINAL TECHNICAL RESOLUTION HAS BEEN ACHIEVED

<u>USI/MPA NUMBER</u>	<u>TITLE</u>	<u>REF. DOCUMENT</u>	<u>APPLICABILITY</u>	<u>STATUS/DATE*</u>	<u>REMARKS</u>
A-1	Water Hammer	SECY 84-119 NUREG-0927, Rev. 1 NUREG-0993, Rev. 1 NUREG-0737 Item I.A.2.3 SRP revisions	All	C/11/88	Closed per NRC IR 89-09 dated 4/21/89.
A-2/ MPA D-10	Asymmetric Blowdown Loads on Reactor Primary Coolant Systems	NUREG-0609 GL 84-04, GDC-4	PWR	C/Oct 89	
A-3	Westinghouse Steam Generator Tube Integrity	NUREG-0844 SECY 86-97 SECY 88-272 GL 85-02 (No requirements)	W-PWR	NA	
A-4	CE Steam Generator Tube Integrity	NUREG-0844, SECY 86-97 SECY 88-272 GL 85-02 (No requirements)	CE-PWR	C/Mar 88	Revised Technical Specifications issued by the NRC.
A-5	B&W Steam Generator Tube Integrity	NUREG-0844, SECY 86-97 SECY 88-272 GL 85-02 (No Requirements)	B&W-PWR	NA	
A E A-6	Mark I Containment Short-Term Program	NUREG-0408	Mark I-BWR	NA	

* C - COMPLETE
NC - NO CHANGES NECESSARY
NA - NOT APPLICABLE
I - INCOMPLETE
E - EVALUATING ACTIONS REQUIRED

<u>USI/MPA NUMBER</u>	<u>TITLE</u>	<u>REF. DOCUMENT</u>	<u>APPLICABILITY</u>	<u>STATUS/DATE*</u>	<u>REMARKS</u>
A-7/ D-01	Mark I Long-Term Program	NUREG-0661 NUREG-0661 Suppl. 1 GL 79-57	Mark I-BWR	NA	
A-8	Mark II Containment Pool Dynamic Loads	NUREG-0808 NUREG-0487, Suppl. 1/2 NUREG-0802 SPP 6.2.1.1C GDC 16	Mark II-BWR	NA	
A-9	Anticipated Transients Without Scram	NUREG-0460, Vol. 4 10 CFR 50.62	All	I/90 REFOUT	Hardware Installation
A-10/ MPA B-25	BWR Feedwater Nozzle Cracking	NUREG-0619 Letter from DG Eisenhut dated 11/13/80 GL 81-11	BWR	NA	
A-11	Reactor Vessel Material Toughness	NUREG-0744, Rev. 1 10 CFR 50.60/ 82-26	All	I	Additional Information will be submitted.
A-12	Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports	NUREG-0577, Rev. 1 SRP Revision 5.3.4	PWP	NA	
A-17	Systems Interactions	Ltr: DeYoung to licensees - 9/72 NUREG-1174, NUREG-1229, NUREG/CR-3922, NUREG/CR-4261, NUREG/CR-4470, GL 89-18 (No requirements)	All	NC	
A-24/ MPA B-60	Qualification of Class 1E Safety-Related Equipment	NUREG-0588, Rev. 1 SRP 3.11 10 CFR 50.49 GL 82-09, GL 84-24 GL 85-15	All	C/Nov 85	

<u>USI/MPA NUMBER</u>	<u>TITLE</u>	<u>REF. DOCUMENT</u>	<u>APPLICABILITY</u>	<u>STATUS/DATE*</u>	<u>REMARKS</u>
A-26/ MPA B-04	Reactor Vessel Pressure Transient Protection	DOR Letters to Licensees 8/76 NUREG-0224 NUREG-0371 SRP 5.2 GL 88-11	PWR	I/	Submit Additional Analysis by 5/1/90 per CPCo letter dated 7/28/89.
A-31	Residual Heat Removal Shutdown Requirements	NUREG-0606 RG 1.113, RG 1.139 SRP 5.4.7	All OLS After 01/79.	NA	
A-36/ C-10, C-15	Control of Heavy Loads Near Spent Fuel	NUREG-0612 SRP 9.1.5 GL 81-07, GL 83-42, GL 85-11 Letter from DG Eisenhut dated 12/22/80	All	C/Nov 83	
A-39	Determination of SRV Pool Dynamic Loads and Pressure Transients	NUREG-0802 NUREGs-0763,0783,0802 NUREG-0661 SRP 6.2.1.1.C	BWR	NA	
A-40	Seismic Design Criteria	SRP Revisions, NUREG/ CR-4776, NUREG/CR-0054, NUREG/CR-3480, NUREG/ CR-1582, NUREG/CR-1161, NUREG-1233, NUREG-4776 NUREG/CR-3805 NUREG/CR-5347 NUREG/CR-3509	All	I/	Resolution in conjunction with SQUG activities.
A-42/ MPA B-05	Pipe Cracks in Boiling Water Reactors	NUREG-0313, Rev. 1 NUREG-0313, Rev. 2 GL 81-03, GL 88-01	BWR	NA	

<u>USI/MPA NUMBER</u>	<u>TITLE</u>	<u>REF. DOCUMENT</u>	<u>APPLICABILITY</u>	<u>STATUS/DATE*</u>	<u>REMARKS</u>
A-43	Containment Emergency Sump Performance	NUREG-0510, NUREG-0869, Rev. 1 NUREG-0897, R.G.1.82 (Rev. 0), SRP 6.2.2 GL 85-22 No Requirements	All	NC	
A-44	Station Blackout	RG 1.155 NUREG-1032 NUREG-1109 10 CFR 50.63	All	I/90 REFOUT	Hardware Installation
A-45	Shutdown Decay Heat Removal Requirements	SECY 88-260 NUREG-1289 NUREG/CR-5230 SECY 88-260 (No requirements)	All	NC	
A-46	Seismic Qualification of Equipment in Operating Plants	NUREG-1030 NUREG-1211/ GL 87-02, GL 87-03	All	I/90 REFOUT	
A-47	Safety Implication of Control Systems	NUREG-1217, NUREG-1218 GL 89-19	All	E	180 day response to 9/20/89 letter due March 1990.
A-48	Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment	10 CFR 50.44 SECY 89-122	All, except PWRs with large dry containments		
A-49	Pressurized Thermal Shock	RGs 1.154, 1.99 SECY 82-465 SECY 83-288 SECY 81-687 10 CFR 50.61/ GL 88-11	PWR	I/May 90	