

ATTACHMENT 1

Consumers Power Company
Palisades Plant
Docket 50-255

PAGE CHANGES

September 20, 1990

2 Pages

9010020432 900920
PDR ADOCK 05000255
P FDC

TABLE 3.6.1
CONTAINMENT PENETRATIONS AND VALVES

PEN NUMBER	SYSTEM NAME AND SERVICE LINE SIZE	VALVE ID NO	REMARKS
1A	PURGE AIR EXHAUST (8")	CV-1805 CV-1806	Auto isolation valve; required closure time = 25 seconds
1C	PURGE AIR EXHAUST (8")	CV-1807 CV-1808	Auto isolation valve; required closure time = 25 seconds
5	S/G (E-50A) BLOWDOWN (4")	CV-0767 CV-0771	Auto isolation valve; required closure time = 25 seconds
6	S/G (E-50B) BLOWDOWN (4")	CV-0768 CV-0770	Auto isolation valve; required closure time = 25 seconds
11	CONDENSATE TO SHIELD COOLING SURGE TANK (1 1/2")	CV-0939 CK-CD401	Auto isolation valve; required closure time = 25 seconds
14	COMPONENT COOLING WATER IN (10")	CV-0910 CK-CC0910	Auto isolation valve; required closure time = 25 seconds
15	COMPONENT COOLING WATER OUT (10")	CV-0911 CV-0940	Auto isolation valve; required closure time = 25 seconds
16	S/G (E-50A) RECIRCULATION (4")	CV-0739	Auto isolation valve; required closure time = 25 seconds

TABLE 3.6.1
CONTAINMENT PENETRATIONS AND VALVES

PEN NUMBER	SYSTEM NAME AND SERVICE LINE SIZE	VALVE ID NO	REMARKS
47	PRIMARY SYSTEM DRAIN TANK PUMP SUCTION (4")	CV-1002 CV-1007	Auto isolation valve; required closure time = 25 seconds
49	CLEAN WASTE RECEIVER TANK CIRCULATION PUMP SUCTION (3")	CV-1038 CV-1036	Auto isolation valve; required closure time = 25 seconds
52	CONTAINMENT SUMP DRAIN TO DIRTY WASTE TANK (4")	CV-1103 CV-1104	Auto isolation valve; required closure time = 25 seconds
55	S/G (E-50B) RECIRCULATION (4")	CV-0738	Auto isolation valve; required closure time = 25 seconds
67	CLEAN WASTE RECEIVER TANK PUMP RECIRC (3")	CV-1037 CK-CRW408	Auto isolation valve; required closure time = 25 seconds
68	AIR SUPPLY TO AIR ROOM (12")	CV-1813 CV-1814	Auto isolation valve; required closure time = 25 seconds
69	CLEAN WASTE RECEIVER TANK PUMP SUCTION (4")	CV-1045 CV-1044	Auto isolation valve; required closure time = 25 seconds

ATTACHMENT

Consumers Power Company
Palisades Plant
Docket 50-255

MARKED UP TECHNICAL SPECIFICATION PAGES

September 20, 1990

2 Pages

TABLE 3.6.1
CONTAINMENT PENETRATIONS AND VALVES

PEN NUMBER	SYSTEM NAME AND SERVICE LINE SIZE	VALVE ID NO	REMARKS
1A	PURGE AIR EXHAUST (8")	CV-1805 CV-1806	Auto isolation valve; required closure time = 25 seconds
1C	PURGE AIR EXHAUST (8")	CV-1807 CV-1808	Auto isolation valve; required closure time = 25 seconds
5	S/G (E-50A) REACTOR BLOWDOWN (2") (4")	CV-0767 CV-0771	Auto isolation valve; required closure time = 25 seconds
6	S/G (E-50B) REACTOR BLOWDOWN (2") (4")	CV-0768 CV-0770	Auto isolation valve; required closure time = 25 seconds
11	CONDENSATE TO SHIELD COOLING SURGE TANK (1 1/2")	CV-0939 CK-CD401	Auto isolation valve; required closure time = 25 seconds
14	COMPONENT COOLING WATER IN (10")	CV-0910 CK-CC0910	Auto isolation valve; required closure time = 25 seconds
15	COMPONENT COOLING WATER OUT (10")	CV-0911 CV-0940	Auto isolation valve; required closure time = 25 seconds
16	S/G (E-50A) SURFACE BLOWDOWN RECIRCULATION (2") (4")	CV-0739	Auto isolation valve; required closure time = 25 seconds

3-40b

Amendment No. 228,
September 5, 1989

TABLE 3.6.1
CONTAINMENT PENETRATIONS AND VALVES

PEN NUMBER	SYSTEM NAME AND SERVICE LINE SIZE	VALVE ID NO	REMARKS
47	PRIMARY SYSTEM DRAIN TANK PUMP SUCTION (4")	CV-1002 CV-1007	Auto isolation valve; required closure time = 25 seconds
49	CLEAN WASTE RECEIVER TANK CIRCULATION PUMP SUCTION (3")	CV-1038 CV-1036	Auto isolation valve; required closure time = 25 seconds
52	CONTAINMENT SUMP DRAIN TO DIRTY WASTE TANK (4")	CV-1103 CV-1104	Auto isolation valve; required closure time = 25 seconds
55	S/G (E-50B) SURFACE BLOWDOWN (2") RECIRCULATION (4")	CV-0738	Auto isolation valve; required closure time = 25 seconds
67	CLEAN WASTE RECEIVER TANK PUMP RECIRC (3")	CV-1037 CK-CRW408	Auto isolation valve; required closure time = 25 seconds
68	AIR SUPPLY TO AIR ROOM (12")	CV-1813 CV-1814	Auto isolation valve; required closure time = 25 seconds
69	CLEAN WASTE RECEIVER TANK PUMP SUCTION (4")	CV-1045 CV-1044	Auto isolation valve; required closure time = 25 seconds

3-40e

Amendment No. 128,
~~September 5, 1989~~