

NOTICE OF VIOLATION

Consumers Power Company
Palisades Nuclear Generating Plant

Docket No. 50-255
License No. DPR-20

As a result of the inspection conducted on June 25-27, 1991 and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, (1991) (Enforcement Policy) the following violation was identified:

Technical Specifications 6.8.1 and 6.8.1.a requires that written procedures shall be established, implemented and maintained for the applicable procedure recommended in Appendix A of Regulatory Guide 1.33.

Procedure HP 1.1, Sections 3.6 and 4.2, and Attachment 14, Item F require that radiation safety technicians shall successfully complete required classroom training prior to performing On-the-Job tasks and complete procedure training before being permitted to work independently.


Contrary to the above, on October 11, 13 and 16, 1990, a contract radiation safety technician performed On-the-Job tasks (radiological surveys) prior to completion of the required procedure qualification training.

This is a Severity Level IV violation (Supplement IV).

The inspection showed that steps had been taken to correct the identified violation and to prevent recurrence. Consequently, no reply to the violation is required and we have no further questions regarding this matter.

Dated

7/23/91


Charles E. Norelius, Director
Division of Radiation Safety
and Safeguards