

9110150269 910904
 PDR ADDCK 05000255
 PDR

REPORT MONTH AUGUST 1991

DOCKET NO 50-255
 UNIT Palisades
 DATE 10/04/91
 COMPLETED BY SMHandlovits
 TELEPHONE (616)764-8913

UNIT SHUTDOWNS AND POWER REDUCTIONS

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
06	910809			B	4	N/A	--	--	Derate to 60% for 'B' main feedwater pump (P1B) maintenance

- | | | | | |
|---------------------------------|--|---|---|-------------------------------|
| 1.
F: Forced
S: Scheduled | 2.
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License
Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain) | 3.
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain) | 4.
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File
(NUREG-0161) | 5.
Exhibit I - Same Source |
|---------------------------------|--|---|---|-------------------------------|