



Consumers
Power

POWERING

MICHIGAN'S PROGRESS

Palisades Nuclear Plant: 27780 Blue Star Memorial Highway, Covert, MI 49043

G B Slade
General Manager

December 10, 1991

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT -
SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE AND WASTE DISPOSAL REPORT - JANUARY
THROUGH JUNE 1991 - REVISION

Attached is a Revision to the Semi-Annual Radioactive Effluent Release and Waste Disposal report for the Palisades Plant covering the period from January through June 1991, dated August 29, 1991. Table HP 10.5-3, "Liquid Effluents - Summation of All Releases," Section G, "Maximum Dose Commitment - Whole body," has been revised to correct a mathematical error. The percent of Technical Specification 3.24.4.1a whole body limit for the second quarter had been erroneously calculated to be 5.67E-05% when it should have been 5.67E-01%. This change has been made to the Table and is indicated by the "#" in the right hand margin. This change does not result in a change to any dose projections.


Gerald B Slade
General Manager

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

Attachment

9112170404 911210
PDR ADOCK 05000255
R PDR

A CMS ENERGY COMPANY

IRAG
11