

ATTACHMENT 1

Consumers Power Company
Palisades Plant
Docket 50-255

SHUTDOWN COOLING

TECHNICAL SPECIFICATIONS CHANGE REQUEST

Revised Technical Specification Change Page

June 22, 1992

Table 3.17.4 (Cont'd)

3. Restore the system to OPERABLE status at the next scheduled refueling.
- (m) The provisions of Specification 3.0.4 are not applicable.
 - (n) With one OPERABLE Pressurizer Wide Range Water Level Channel in lieu of the requirement of 3.17.2, restore the inoperable channel to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
 - (o) With no OPERABLE Pressurizer Wide Range Water Level Channels in lieu of the requirements of 3.17.2, either restore at least one of the inoperable channels to OPERABLE status within 48 hours, or be in at least HOT SHUTDOWN within the next 12 hours.
 - (p) The environmentally qualified core exit thermocouples are used in determining the minimum channels operable requirement.
 - (q) With only three OPERABLE Core Exit Thermocouples per core quadrant, in lieu of the requirement of 3.17.2, either restore the inoperable channel to OPERABLE status within 7 days if repairs are feasible without shutting down or prepare and submit a Special Report to the Commission within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
 - (r) With the number of OPERABLE Core Exit Thermocouples less than three per core quadrant, in lieu of the requirements of 3.17.2, either restore three core exit thermocouples per core quadrant to OPERABLE status within 48 hours, or be in HOT SHUTDOWN or below within the next 12 hours and the reactor shall be placed in a condition where the affected equipment is not required, within 48 hours.
- 3.18 (Deleted)