



Consumers  
Power  
POWERING  
MICHIGAN'S PROGRESS

PALISADES NUCLEAR PLANT  
ENGINEERING ANALYSIS COVER SHEET

EA - SP - 03316 - 04

Total Number of Sheets 32

Title SERVICE WATER SYSTEM - EVALUATION OF PIPE WALL THINNING  
DOWN STREAM OF VALVE MV SW 136.

INITIATION AND REVIEW

Calculation Status		Preliminary <input type="checkbox"/>		Pending <input type="checkbox"/>			Final <input checked="" type="checkbox"/>		Superseded <input type="checkbox"/>		
Rev #	Description	Initiated		Init Appd By	Review Method			Technically Reviewed		Revr Appd By	CPCo Appd
		By	Date		Alt Calc	Detail Review	Qual Test	By	Date		
0	Original Issue	P. Hoang P. HOANG	6/19/93	RBG		✓		BR Rogers BR ROGERS	6/22/93	RBG	

1.0 Purpose:

The purpose of this calculation is to evaluate the structural integrity of a small through wall leak found at the down stream butt weld of valve MV SW136 on line HB23-4" of Service Water system for a temporary non-Code repair permit. The scope of the calculation includes evaluations using the proposed Code Case N-513 "Fracture Mechanics Approach", the Code Case N-480 "Wall Thinning Evaluation Method" and the "Branch Reinforcement Approach" per the proposed Code Case N-513.

2.0 Design Input:

1. Nondestructive Testing Service Thickness Measurement Examination Report Sheet MFS-03, dated 6/10/93. (Attachment 1)
2. Drawing M101-SH. 2744, Rev. 2.
3. Stress Report EA\*SP\* 03316-01, S&L File # 9131-00
4. Palisades Plant Piping Class Summary, M-259, Sh 3HB, Rev. 9.
5. Nondestructive Testing Service Thickness Measurement Examination Report Sheet RDW-01, dated 6/2/93. (Attachment 2)

3.0 Assumptions:

1. Per the plant NDE personnels, the UT weld crown thickness measurement (Ref. 7.1) at 10:00 location is near to the pin hole leak. Weld surface irregularities and component configuration prohibited the taking of UT measurements at this location where the material thickness may be thinner than the weld crown thickness. Surface grinding to facilitate additional UT measurements could not be accomplished to avoid further wall thinning. Therefore, the thickness measurements used as the basis for the calculation are only an approximation of wall thickness at the toe of the weld.
2. Since the thickness measurement of 0.228" at the valve end (Ref. 7.1) is about the same as the expected thickness at the valve end counterbore, it is assumed that there is no significant erosion or corrosion in the valve body.
3. Per the conversation between CPCo Licensing and NRC staff, structural integrity of a pin hole leaked pipe can be evaluated by the "Wall Thinning Approach" or the "Branch Reinforcement Approach" for a non-code repair permit. ( See Attachment 3)

4.0 Approach:

The measured weld thicknesses at several locations around the pipe circumference are plotted in Figure 1. The corroded area is concentrated near the 10:00 o'clock location where the pin hole leak was found. There is no significant thickness reduction in the adjacent pipe metal ( except location E1,  $t=0.187$ " or 0.789 times pipe nominal thickness, Ref. 7.6) . Furthermore, there is no indication of erosion/corrosion on the down stream pipe wall. Therefore, the leak may be resulted from corrosion in a local weld area where the weld is not fully penetrated. Structural integrity of the leaked pipe is evaluated by the following approaches:

4.1. Fracture Mechanics Approach:

a) Flaw characterization:

The stress intensity factor K assuming pipe wall thickness of  $t_{min}$  per the USNRC GL 90-05 is judged to be too conservative for low pressure piping (very small  $t_{min}$ ). Alternatively, the proposed Code Case N-513 (Ref. 7.10) suggests that the adjusted pipe wall thickness  $t_{adj}$  can be chosen such as

$$t_{min} < t_{adj} < t_{act}$$

where  $t_{min}$  is the Code minimum pressure design pipe wall thickness

$$t_{min} := \frac{P \cdot D}{2(15000 + 0.4 \cdot P)}$$

and  $t_{act}$  is the actual pipe thickness adjacent to the flaw ( $t_{act} = 0.19$ ”).

In this calculation  $t_{adj}$  is chosen such that the characterized flaw length  $2a$  is the 2” (15% of the circumference) length limit. From Figure 3, with the smooth flaw profile and  $2a=2$ ”,  $t_{adj}$  is approximately 0.125”.

Therefore, a 2” inch circumferential through wall crack on a 4.5” OD, 0.125” thick pipe, is the postulated fracture mechanics model. The crack length is about from 9:00 to 11:00 o'clock positions.

Note that the predicted pipe wall thickness at the end of the evaluation period is not required for this approach.

b) Applied stress:

The nominal applied stress  $s$ (ksi) for pressure, dead weight and SSE is recalculated from the intensified combined stresses at the valve end (REF. 7.3). Note that thermal load is not considered due to temperature < 150 degree and SSE stress is two times OBE stress. The applied stress is the far field stress (unintensified and no adjustment for pipe wall thickness).

c) Stress intensity factor K: Ref. 7.10

$$K := 1.4 \cdot s \cdot F \cdot \sqrt{\pi \cdot a}$$

where  $F := 1 + A \cdot c^{1.5} + B \cdot c^{2.5} + C \cdot c^{3.5}$

$$c := \frac{a}{(\pi \cdot R)} \quad r := \frac{R}{t_{adj}}$$

$$R := \frac{D - t_{adj}}{2} \quad \text{:Mean radius}$$

The coefficients A,B and C are given in Section 5.2 of this calculation.

d) Acceptance criteria  $K < K_{I0}$

Where  $K_I$  is the material initiation stress intensity. For carbon steel,

$$K_I := 35000 \text{ psi} \cdot \sqrt{\text{in}} \quad (\text{Ref. 7.5 and 7.10})$$

#### 4.2 Wall Thinning Approach:

##### a) Methodology: (Ref. 7.4)

- The predicted pipe wall thickness at the end of 18 month evaluation period is calculated from the current minimum measured thickness and the wear rate.
- The average wear rate of the pass 20 years of the plant operation is calculated from the difference between the maximum and the minimum measured weld thickness divided by 20 year.
- The Code minimum pipe wall thickness  $t_{\min}$  is calculated as such that axial and hoop stresses meet all Code stress limits.

##### b) Acceptance Criteria

- The predicted pipe wall thickness to the next outage (18 month appx.)  $t_p$  shall be greater than  $t_{\min}$ .
- The stress limit for pressure hoop stress is  $Sh$  (15 Ksi)
- The stress limit for equation 11 (P+WT) is  $Sh$  (15 Ksi)
- The stress limit for equation 12B (P+WT+OBE) is  $1.2Sh$  (18 Ksi)
- The stress limit for equation 12B (P+WT+SSE) is  $2.4Sh$  (36 Ksi)

#### 4.3 Branch Reinforcement Approach

a) Flaw characterization: (Proposed Code Case N-513)

The Code minimum thickness is calculated as:

$$t_{\min} := \frac{P \cdot D}{2(15000 + 0.4 \cdot P)}$$

Per the proposed Code Case N-513 (Ref. 7.10), the adjusted pipe wall thickness  $t_{\text{adj}}$  can be chosen such as

$$2 \cdot t_{\min} < t_{\text{adj}} < t_{\text{act}}$$

In this calculation  $t_{\text{adj}}$  is chosen such that the characterized flaw is entirely contained within a 2.25 inch diameter circular opening which is half of  $d=4.5$ ", the diameter of a postulated circular opening. (Ref. 7.10, Section 3.2).

- Applied stress:

The nominal applied stress  $s$  for pressure, dead weight and SSE is recalculated from the intensified combined stresses at the valve end (REF. 7.3). Note that thermal load is not considered due to temperature  $< 150$  degree. SSE stress is two times OBE stress. The nominal stresses are then adjusted for the new pipe thickness before reintensified by the UFT stress intensification factor.

- The required reinforcement area for the circular opening is calculated in accordance with ND-3643.3, Ref. 7.7.

- Stress intensification factor of an equivalent unreinforced fabricated tee (UFT) is calculated using Figure ND-3673.2(b)-1, Ref 7.8.

c) Acceptance criteria

Stress at the postulated circular opening using UFT stress intensification factor shall be within the ND-3650 limits for all service levels.

5.0 Calculations

$l := \pi \cdot 4.5$

5.1 Measured pipe wall thickness:

Weld thickness plot using the measured data dated 6/10/93

Location from top (12:00)

fraction of the circumference

$D := 4.5$  : OD of the pipe

$l := \pi \cdot D$  : The circumference

$x :=$

0
$\frac{1}{12}$
$\frac{1}{6}$
$\frac{1}{4}$
$7 \cdot \frac{1}{24}$
$\frac{1}{3}$
$\frac{1}{2}$
$3 \cdot \frac{1}{4}$
$5 \cdot \frac{1}{6}$

Distance from the top (in)

Weld thickness(in)

$x =$

0
1.178
2.356
3.534
4.123
4.712
7.069
10.603
11.781

$t :=$

.3
.185
.094
.148
.184
.362
.38
.330
.33

$i := 0..8$




Figure 1: Measured weld thickness along the circumference.

5.2 Calculation using fracture mechanics approach.

a) Flaw characterization:

The Code min wall thickness for design pressure: P := 100

$$D := 4.5$$

$$t_{\min} := \frac{P \cdot D}{2 \cdot (15000 + 0.4 \cdot P)}$$

$$t_{\min} = 0.015$$

Envelope the pipe wall thickness to a smooth profile  
(curve in Fig. 2)

tsm := [ .3  
.13  
.094  
.138  
.184  
.282  
.38  
.330  
.33 ]

$$z := 0.1 .. 12$$

$$vs := \text{pspline}(x, \text{tsm})$$

$$f(z) := \text{interp}(vs, x, \text{tsm}, z)$$

From Figure 2, for crack length  $2a = 2"$ , the adjusted thickness is approximately 0.125"

$$t_{\min} = 0.015 < t_{\text{adj}} := 0.125 < t_{\text{act}} := 0.19$$




Figure 2 : Smooth weld thickness profile in circumferential direction.  $t_{\text{adj}}$  is determined from the smooth wall profile such that the through wall crack length  $2a$  is 2 inches.

b) Applied Stress

Nominal stress field  $s$  near the flaw (RUNID 03316A.INP EA-SP-03316-01 Rev 0)

At node point 66, analysed pressure  $P=65$  psi  $i := 1.425$  0.75 factor included

$$P := 65 \quad D := 4.5 \quad t_{\text{nom}} := 0.237 \quad s_{11} := 2465 \quad s_{12B} := 3457$$

$$s_p := \frac{P \cdot D}{4 \cdot t_{\text{nom}}} \quad s_p = 308.544 \quad \text{: Pressure stress}$$

$$s_{\text{wt}} := \frac{s_{11} - s_p}{i} \quad s_{\text{wt}} = 1.513 \cdot 10^3 \quad \text{: Weight stress}$$

$$s_{\text{obe}} := \frac{s_{12B} - s_{11}}{i} \quad s_{\text{obe}} = 696.14 \quad \text{: OBE stress}$$

$$s_{\text{sse}} := 2 \cdot s_{\text{obe}} \quad s_{\text{wt}} = 1.513 \cdot 10^3 \quad \text{: SSE stress}$$

$$s := s_p + s_{\text{wt}} + s_{\text{sse}} \quad s = 3.214 \cdot 10^3 \quad \text{: Applied stress}$$

c) Applied stress intensity K

$$R := \frac{D - t_{\text{adj}}}{2}$$

The 2a flaw length is about 15% of the circumference  
at thickness  $t_{\text{adj}}$

$$r := \frac{R}{t_{\text{adj}}} \quad a_1 := \frac{2}{2} \quad r = 17.5$$

Coefficients A,B,C and D in matrix form

$$a := \begin{pmatrix} -3.26543 & 1.52784 & -0.072698 & 0.0016011 \\ 11.36322 & -3.91412 & 0.18619 & -0.004099 \\ -3.18609 & 3.84763 & -0.18304 & 0.00403 \end{pmatrix}$$

$$b := \begin{bmatrix} 1 \\ r \\ r^2 \\ r^3 \end{bmatrix} \quad c := a \cdot b \quad c = \begin{pmatrix} 9.789 \\ -22.081 \\ 29.69 \end{pmatrix}$$



PALISADES NUCLEAR PLANT  
ANALYSIS CONTINUATION SHEET

EA-SP-03316-04

Sheet 9 Rev # 00

$$C := \frac{aI}{(\pi R)} \quad C = 0.146$$

$$F := 1 + c_0 \cdot C^{1.5} + c_1 \cdot C^{2.5} + c_2 \cdot C^{3.5}$$

$$F = 1.4$$

$$s = 3.214 \cdot 10^3$$

$$s := \frac{s}{1000} \quad \text{Ksi}$$

$$K := 1.4 \cdot s \cdot F \cdot (\pi aI)^{0.5}$$

$$K = 11.165 \quad \text{Ksi} \cdot \sqrt{\text{in}}$$

$$K < K_{I0}$$

$$K_{I0} := 35 \quad \text{Ksi} \cdot \sqrt{\text{in}}$$

d) Results

The applied stress intensity K (11.165) is less than 35 ksi  $\sqrt{\text{in}}$   
Therefore, no Code repair or replacement is required.

5.3 Wall thinning approach:

a) Minimum measured thickness

$$t_{\text{meas}} := t_2 \quad t_{\text{meas}} = 0.094$$

b) Predicted pipe thickness in the next 18 month period

- The average wear rate in the pass 20 years of operation based on the max and min measured weld thickness.

$$\text{rate} := \frac{0.38 - 0.094}{20}$$

$$\text{rate} = 0.014 \quad \text{inch per year}$$

- The predicted pipe thickness for the next 18 month period is

$$t_p := t_{\text{meas}} - \frac{18}{12} \cdot (\text{rate})$$

$$t_p = 0.073$$

$t_p$  is greater than  $0.3 \cdot t_{\text{nom}} = 0.71$  inch, therefore  $t_p$  meet the requirement 3410 of Code Case N-480.

c) Minimum pipe wall thickness required per the Code Case N-480

c.1) Minimum pipe wall thickness required for hoop stress

Hoop stress due to design pressure  $P=100$  psi. was calculated in section 5.2(a) for the following condition.

$$P := 100 \quad D := 4.5 \quad S_h := 15000$$

$$t_{\text{min}} = 0.015$$

c.2) Minimum thickness required for axial stress to meet the Code stress limits

Section modulus for thin wall pipe:

$$Z(t) := \pi \left( \frac{D-t}{2} \right)^2 \cdot t \quad t_{\text{nom}} := 0.237 \quad Z_{\text{orig}} := Z(t_{\text{nom}})$$

As analysed stresses based on the original section modulus (Ref. 7.3)

$$s_{11} = 2.465 \cdot 10^3$$

$$s_{12B} = 3.457 \cdot 10^3$$

$$s_{12D} := s_{11} + 2 \cdot (s_{12B} - s_{11})$$

- Minimum thickness required to meet Eq. 11 stress limit

Stress as a function of t calculated from the ratio of the original section modulus and the reduced thickness section modulus.

$$s(t) := s_{11} \cdot \frac{Z_{orig}}{Z(t)} \quad S_{all} := 15000 \quad t := 0.01 \quad \text{Initial guess}$$

Solve for t

$$t_{min} := \text{root}(s(t) - S_{all}, t) \quad t_{min} = 0.036$$

- Minimum thickness required to meet Eq. 12B stress limit.

$$s(t) := s_{12B} \cdot \frac{Z_{orig}}{Z(t)} \quad S_{all} := 18000$$

Solve for t

$$t_{min} := \text{root}(s(t) - S_{all}, t) \quad t_{min} = 0.042$$

- Minimum thickness required to meet Eq. 12D stress limit.

$$s(t) := s_{12D} \cdot \frac{Z_{orig}}{Z(t)} \quad S_{all} := 36000$$

Solve for t

$$t_{min} := \text{root}(s(t) - S_{all}, t) \quad t_{min} = 0.027$$

Therefore, the Code minimum pipe thickness is  $t_{min} := 0.042$

c.3) Evaluations using N-480, 3610(a) acceptance criteria:

The  $t_p$  at the end of evaluation period is greater than the Code minimum pipe wall thickness.

$$t_p = 0.073 \quad t_{\min} = 0.042$$

$$t_p > t_{\min}$$

Therefore, the flaw is acceptable per 3610(a) of N-480.  $t_p$  is also greater than the required thickness per section 3420 of Code Case N-480, 0.3 times  $t_{\text{nom}}$  or 0.071".

d) Result:

The flaw wall thinning predicted for the next 18 month period is acceptable per N-480 acceptance criteria 3610 (a). Therefore, code repair is not required. Note that the minimum measured weld thickness in the subsequence inspections shall not be less than 0.3 times  $t_{\text{nom}}$  or 0.071" per the requirement 3420 of N-480.

5.4 Branch reinforcement approach ( Proposed Code Case N-513)

a) Flaw characterization

The Code min wall thickness for design pressure:  $P := 100$   $D := 4.5$

$$t_{\min} := \frac{P \cdot D}{2 \cdot (15000 + 0.4 \cdot P)} \quad t_{\min} = 0.015$$

$$t_{\text{act}} := 0.19 > t_{\text{adj}} > 2 \cdot t_{\min} = 0.03$$

The postulated circular opening diameter  $d := 4.5$

From Figure 4, for  $t_{\text{adj}} := 0.135$ , the flaw is within a  $d/2 = 2.25$ " diameter circular area.




Figure 4 : Pipe Wall Thickness in circumferential direction measured near the fillet weld toe. The smooth wall thickness profile is used to determine  $t_{\text{adj}}$  such that  $t > 2 \cdot t_{\min}$  and the flaw is within a 2.25 inch diameter circular opening.

b) The required reinforcement area for the circular opening is calculated in accordance with ND-3643.3, Ref. 7.7.

$d := 4.5$  : the postulated circular opening

$d_2 := d$  : the header reinforcement length

$$A_1 := d_2 \cdot (t_{\text{adj}} - t_{\min}) \quad \text{:available reinforcement area from header}$$

$$A_1 = 0.54 \quad \text{in}^2$$

$$A_{\text{req}} := 1.07 \cdot d \cdot t_{\min}$$

$$A_{\text{req}} = 0.072 \quad \text{in}^2 \quad \text{:required reinforcement area}$$

Therefore, the reinforcement area meet the requirement per ND-3643.3, Ref. 7.8

c) Stress using UFT stress intensification factor

$$t_{adj} = 0.135 \quad R := \frac{D - t_{adj}}{2} \quad h := \frac{t_{adj}}{R}$$

$$i_{uft} := \frac{0.9}{\frac{2}{h^3}} \quad i_{uft} = 5.754$$

Nominal stress for the original pipe thickness (RUNID 03316A.INP EA-SP-03316-01 Rev 0)

$$P := 65 \quad t_{nom} := 0.237 \quad i := 1.425 \quad 0.75 \text{ factor included}$$

$$s_p := \frac{P \cdot D}{4 \cdot t_{nom}} \quad s_p = 308.544 \quad \text{: Pressure stress}$$

$$s_{wt} := \frac{s_{11} - s_p}{i} \quad \text{: WT stress}$$

$$s_{obe} := \frac{s_{12B} - s_{11}}{i} \quad \text{: OBE stress}$$

For thin wall pipe, the modified nominal stress for pipe wall thickness of  $t_{adj}$  can be approximated as follows:

$$S_p := s_p \cdot \frac{t_{nom}}{t_{adj}} \quad S_{wt} := s_{wt} \cdot \frac{t_{nom}}{t_{adj}} \quad S_{obe} := s_{obe} \cdot \frac{t_{nom}}{t_{adj}}$$

Reintensified stress using UFT stress intensification factor

$$\text{Eq 11} \quad S_{11} := S_p + 0.75 \cdot i_{uft} \cdot S_{wt} \quad S_{11} = 1.201 \cdot 10^4 < 15,000 \text{ psi}$$

$$\text{Eq 12B} \quad S_{12B} := S_p + 0.75 \cdot i_{uft} \cdot S_{wt} + 0.75 \cdot i_{uft} \cdot S_{obe} \quad S_{12B} = 1.728 \cdot 10^4 < 18,000 \text{ psi}$$

$$\text{Eq 12D} \quad S_{12D} := S_p + 0.75 \cdot i_{uft} \cdot S_{wt} + 0.75 \cdot i_{uft} \cdot S_{obe} \cdot 2 \quad S_{12D} = 2.256 \cdot 10^4 < 36,000 \text{ psi}$$

d) Results: The leaked pipe meet the N-513 UFT evaluation criteria 3.2 (c).

6.0 Summary and Conclusion:

Three different approaches were used to evaluate the structural integrity of the pin hole leak on line HB23-4". The results of the evaluations are as the follows:

- Linear Elastic Fracture Mechanics Approach: (N-513 )

$$K = 11.165 \quad \text{Ksi} \sqrt{\text{in}} \quad : \text{Applied stress intensity}$$

is less than

$$K_I = 35 \quad \text{Ksi} \sqrt{\text{in}} \quad : \text{Allowable stress intensity}$$

- Wall Thinning Approach: (Code Case N-480 )

$$t_p = 0.073 \quad \text{in} \quad : \text{Predicted pipe wall}$$

is greater than

$$t_{\min} = 0.071 \quad \text{in} \quad : \text{Required minimum pipe wall thickness} \\ 0.3 * \text{nominal thickness.}$$

- Branch reinforcement Approach: (Proposed Code Case N-513)

$$A_1 = 0.54 \quad \text{in}^2 \quad : \text{total available reinforcement area}$$

is greater than

$$A_{\text{req}} = 0.072 \quad \text{in}^2 \quad : \text{required reinforcement area}$$

$$S_{11} = 1.201 \cdot 10^4 < 15,000 \text{ psi} \quad : \text{Pass}$$

$$S_{12B} = 1.728 \cdot 10^4 < 18,000 \text{ psi} \quad : \text{Pass}$$

$$S_{12D} = 2.256 \cdot 10^4 < 36,000 \text{ psi} \quad : \text{Pass}$$

The structural integrity of the pipe leak was found to be assured by the fracture mechanics approach, the wall thinning approach and the branch reinforcement approach.

On the basis of the above evaluations and discussion we conclude that the structural integrity of the pipe leak on line HB23-4" is assured and due to design pressure less than 275 psig and temperature less than 200 °F, the leaked pipe is acceptable for a non-weld repair. (Ref. 7.5).

7.0 References

7.1. Nondestructive Testing Service Thickness Measurement Examination Report MFS-03, dated 6/10/93. (Attachment 1)

7.2. Drawing M101 SH. 2744, Rev. 2

7.3. Stress Report EA\*SP\* 03316-01, S&L File # 9131-00

7.4. Code Case N-480, "Examination Requirements for Pipe Wall Thinning Due to Single Phase Erosion and Corrosion", Section XI, Division 1, 05/10/90.

7.5. USNRC Generic Letter 90-05, "Guidance for Performing Non-Code Repair of ASME Code Class 1,2, and 3 Piping", 6/15/90.

7.6 Nondestructive Testing Service Thickness Measurement Examination Report Sheet No. RDW-01, dated 6/2/93. (Attachment 2)

7.7 Palisades Plant Piping Class Summary, M-259, Sh 3HB, Rev. 9.

7.8 ASME B&PV Code, Section III, Subsection ND, 1992

7.9 ANSI/ASME B31.1, 1973

7.10 Proposed Code Case N-513, "Evaluation Criteria for Temporary Acceptance of Flaws in Class 3 Piping", Section XI, Division 1, 08/13/92. (Presented in February 1993 Committee Meeting).





CONSUMERS POWER COMPANY  
 NONDESTRUCTIVE TESTING SERVICES  
 THICKNESS MEASUREMENT  
 EXAMINATION REPORT

Examiner M. F. SHERWIN Level III Date 6/10/93 Sheet No. MFS-03  
 Examiner N/A Level N/A NDT Company C.P.C. / (MQS)  
 Project No. 239315-228051 Requesting Dept MECH. MAINT.  
 Job Location PALISADES Total Hours Worked \_\_\_\_\_

NDT Procedure NDT-UT-02 Rev 5

Reference Documents N/A  
INFORMATION ONLY

Material Type CS Joint Design \_\_\_\_\_

Nominal Diameter 4" Nominal Thickness 0.237

Item Type 4" SERVICE WATER

Ultrasonic Equipment PAN 26DL+ Serial No. 000355 Cal Due 9/10/93

Search Unit Size/Frequency 0.2 / 5 MHz Serial Number 19209

Ultrasonic Couplant SONOTRACE 40 Batch Number 091014

Mechanical Equipment N/A Serial No. N/A Cal Due N/A

Item ID Number A7 System Name SWS Sub Project Number .3

Line Number \_\_\_\_\_ ISO/Drawing No. M-208 SHC 1A

Item
Location

SUPPLEMENTARY SKETCH

SEE ATTACHMENT SHEET.

WELD CROWN IS ESSENTIALLY FLAT, BUT IN THE "AS WELDED" CONDITION.

POWER WIRE BRUSH WAS USED TO CLEAN THE SURFACES PRIOR TO ULTRASONIC EXAMINATION.

NOTE: READINGS VERIFIED 6/11/93 MFS  
 \*

Examiner *M. F. Sherwin*


EA-SP-03316-04 ATTACHMENT 1 PAGE 1 OF 2



CONSUMERS POWER COMPANY  
NONDESTRUCTIVE TESTING SERVICES  
SUPPLEMENTARY SKETCH

Examiner M.F. SHERWIN Level III Date 6/10/93 Attachment Sheet No MFS-03  
 Project No. 239315-228051 Examination Report Sheet No MFS-03  
 Job Location PALISADES WOMO No N/A  
 Line No. \_\_\_\_\_ Item Type/No 4" SERVICE WATER

ALL DIMENSIONS IN INCHES



NOTE: VALVE BODY GEOMETRY PRECLUDES OBTAINING THICKNESS DATA ON THE COMPONENT AT OTHER CLOCK POSITIONS

LEGEND:  
 W = ON WELD.  
 P = ON PIPE ADJACENT TO THE WELD.  
 V = VALVE (NO READINGS WERE TAKEN ON THE VALVE BODY)  
 MFS 6/11/93

EA-SP-03316-04 ATTACHMENT 1 PAGE 2 OF 2



CONSUMERS POWER COMPANY  
NONDESTRUCTIVE TESTING SERVICES  
THICKNESS MEASUREMENT  
EXAMINATION REPORT

Examiner RANDELL WELLS Level II Date 6-2-93 Sheet No. RDW-01  
 Examiner DAVID HECKSEL Level II NDT Company C.P. CO.  
 Project No. 249315225056 Requesting Dept SYSTEM ENGR.  
 Job Location PALISADES NUCLEAR PLANT Total Hours Worked N/A

NDT Procedure NDT-4T-02 Rev 5  
N/A  
 Reference Documents N/A  
N/A  
 Material Type C/S Joint Design N/A  
 Nominal Diameter 4" Nominal Thickness .237"  
 Item Type 4" PIPING

Ultrasonic Equipment ANAMETRICS 262LP Serial No. <sup>RDW</sup> 274-00355 Cal Due 9-10-93  
 Search Unit Size/Frequency .2" 15MHZ Serial Number 19209  
 Ultrasonic Couplant SONOTRACE 40 Batch Number 091014  
 Mechanical Equipment N/A Serial No. N/A Cal Due N/A  
N/A  
 Item ID Number PIPING DOWNSTREAM OF VALVE EXHIBIT 7 System Name SWS Sub Project Number N/A  
MVSU136  
 Line Number N/A ISO/Drawing No. N/A

Item	Thickness Measurements																					
	Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
A	.245	.250	.249	.246	.247	.239	.244	.244	.247	.249	.256											
B	.250	.247	.254	.275	.270	.240	.246	.243	.238	.242	.249											
C	.257	.254	.258	.247	.252	.255	.253	.252	.238	.248	.246											
D	.256	.254	.272	.252	.254	.246	.247	.246	.245	.249	.232											
E	.187	.240	.252	.257	.242	.258	.249	.246	.253	.247	.243											
F	.220	.247	.247	.248	.246	.248	.253	.246	.247	.244	.251											
G	.244	.245	.249	.245	.246	.246	.241	.242	N/A	N/A	.243											
H	.237	.241	.248	.252	.253	.253	.245	.251	.251	.252	.260											
I	.243	.247	.248	.247	.254	.251	.244	.249	.258	.257	N/A											
J	.232	.238	.241	.242	N/A	.234	.240	.246	.259	.255	.265											
K	.241	.232	.227	N/A	.238	.239	.234	.243	.234	.259	.272											
L	.242	.242	.245	.240	.254	.256	N/A	.233	.247	.250	N/A											

Examiner Randell D. Wells

Page 1 of 2 (SEE ATTACHED SKETCH)

Reviewed by ME

EA-SP-03316-04 ATTACHMENT 2 PAGE 1 OF 3

THICKNESS MEASUREMENT EXAMINATION REPORT  
CONTINUATION SHEET

Project No. *249315225056*

Examination Report Sheet No. *ADW-01*

Date *6-2-93*

Page *2* of *2*

Item	Thickness Measurements																				
Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
<i>M</i>	<i>.254</i>	<i>.248</i>	<i>.259</i>	<i>.252</i>	<i>.260</i>	<i>.253</i>	<i>.255</i>	<i>.247</i>	<i>.248</i>	<i>.259</i>	<i>.255</i>										
<i>N</i>	<i>.239</i>	<i>.235</i>	<i>.244</i>	<i>.236</i>	<i>.240</i>	<i>.254</i>	<i>.239</i>	<i>.235</i>	<i>.238</i>	<i>.236</i>	<i>.240</i>										
<i>NOTE: SPACES MARKED "N/A" ARE AREA WHERE SURFACE CONDITION PREVENTS READINGS.</i>																					

EA-SP-03316-04 ATTACHMENT 2 PAGE 2 OF 3




CONSUMERS POWER COMPANY  
NONDESTRUCTIVE TESTING SERVICES  
SUPPLEMENTARY SKETCH

Examiner Heckel/R. Wells Level II Date 6-2-93 Attachment Sheet No NA-1  
 Project No. 249315225056 Examination Report Sheet No RDW-01  
 Job Location Palisades WOMO No NA  
 Line No. NA Item Type/No Piping Downstream of Valve CV-0822 MV-SW-136 6/16/93


Wall Thickness Measurements Taken on 1" Grid.  
Leak Located in Weld between Rows C & D

PLH 6-2-93  
Tank  
24" Pipe



View Looking West

View A



West Side  
View A

North →

EA-SP-03316-04 ATTACHMENT 2 PAGE 3 OF 3

FIGURE 1

Consumers Power Company  
Palisades Plant  
Docket 50-255

P&ID Drawing M-208, Sheet 1A

July 1, 1993

**System Description: Service Water Line HB-23-16"**

Service water line HB-23-16" taps into the "A" Critical Service Water Header (HB-23-24"). Service water from the "A" Critical Header flows through HB-23-16" to the Component Cooling Water Heat Exchanger, E-54B. The service water flows through the tubes in E-54B and exits the heat exchanger back into service water line HB-23-16". The service water goes through CV-0826, E-54B Service Water Outlet Valve and then HB-23-16" taps into the main service water return header pipe, HB-23-24" and discharges to Lake Michigan.

A 4" bypass line around CV-0826, contains a temperature control valve, CV-0822 and a manual isolation valve, MV-SW136. Normally most of the service water going through E-54B goes through the bypass line, HB-23-4". As the lake temperature warms during summer, CV-0822 will be manually throttled open to help keep the temperature control valve, CV-0822 in a mid-point position. Estimated service water flow rates are 1000 gpm/heat exchanger in the winter to 1500 gpm/heat exchanger in the summer.




FIGURE 1  
P&ID Drawing M-208, Sheet 1A