

SEP 14 1993

Docket No. 50-255

Consumers Power Company
 ATTN: Gerald B. Slade
 General Manager
 Palisades Nuclear Generating Plant
 27780 Blue Star Highway
 Covert, MI 49043

Dear Mr. Slade:

SUBJECT: REVIEW OF REVISIONS TO PALISADES SITE EMERGENCY PLAN

In August and September 1993, we received minor revisions to Sections 7 and 8 of the Site Emergency Plan. Other submittals indicated that Appendices A and C of the plan were not being revised following a periodic review by your staff.

We have reviewed these submittals and have determined that they are acceptable and do not degrade the effectiveness of your emergency planning. Section 7 was revised to indicate that the Mechanical Maintenance Shop was an alternate location for the Operational Support Center. Section 8 included updated references to the corporate administrative procedures related to control of the onsite meteorological monitoring program and the dose assessment software used by your emergency responders.

If you have any questions, please have your staff contact Mr. T. Ploski of my staff at (708) 790-5634.

Sincerely,

Original Signed by James L. Belanger

James R. Creed, Chief
 Safeguards and Incident
 Response Section

cc: David P. Hoffman, Vice President
 Nuclear Operations
 David W. Rogers, Safety
 and Licensing Director
 OC/LFDCB
 Resident Inspector, RIII
 James R. Padgett, Michigan Public
 Service Commission
 Michigan Department of
 Public Health
 Palisades, LPM, NRR
 SRI, Big Rock Point
 D. Gonzalez, Region III
 A. Williams, FEMA, Region V

170044

RIII
 Ploski/jp
 09/14/93

RIII
 McCormick-Barger
 9/13/93

RIII
 Shetler
 9/14/93

RIII
 Creed
 9/14/93

9309210064 930914
 PDR ADDCK 05000255
 F PDR

JE35 1/0
 JE04