

Palisades Nuclear Plant: 27780 Blue Star Memorial Highway, Covert, MI 49043

June 3, 1994

US Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

LICENSEE REPORT OF MONTHLY OPERATING DATA DPR-20, DOCKET NO 50-255

Enclosed is a copy of the Monthly Operating Data and Summary of Operating Experience for the Palisades Nuclear Plant for the month of May, 1994.

If you have any questions or concerns, please feel free to contact me at (616) 764-8913, extension 0113.

Sincerely,

M L Banks

Reactor Engineer

RAFenech, Palisades CC:

JMartin, USNRC

JLKuemin, Palisades

Resident Inspector, Palisades

DRHahn, Div of Rad Health Services, Lansing, MI BWJorgensen, Michigan Dept of Labor, Lansing, MI

JPadgett, Michigan Public Service Commission

Records Center, INPO, Atlanta, GA

RWTaylor, CE, Palisades JDStafford, Palisades SMMcIntyre, P13-121

Region III Administrator, USNRC Document Control, 950\*22\*35\*10/L

Cycle 11 Reports

#### OPERATING DATA REPORT

DOCKET NO 50-255

DATE 06-02-94

COMPLETED BY BWBerles

TELEPHONE (616)764-8913

NOTES:

OPERATING STATUS:

GIVE REASONS:

1.	UNIT NAME	Palisades
2.	REPORTING PERIOD:	940501-940531
3.	LICENSED THERMAL POWER (MWt)	2530.0
4.	NAMEPLATE RATING (GROSS MWe)	811.7
5.	DESIGN ELECTRICAL RATING (NET MWe)	805.0
6.	MAXIMUM DEPENDABLE CAPACITY (GROSS MWe)	**770
7.	MAXIMUM DEPENDABLE CAPACITY (NET MWe)	<b>**73</b> 0
8.	IF CHANGES OCCUR IN CAPACITY RATINGS (ITEM NUMBERS 3 AND 7	) SINCE LAST REPORT

- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe):
- 10. REASONS FOR RESTRICTIONS, IF ANY:

	This Month	Yr-to-Date	Cumulative
11. HOURS IN REPORTING PERIOD	744.0	3623.0	196790.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0.0	1150.1	109590.1
13. REACTOR RESERVE SHUTDOWN HOURS			
14. HOURS GENERATOR ON-LINE	0.0	1149.3	104950.9
15. UNIT RESERVE SHUTDOWN HOURS		:	
16. GROSS THERMAL ENERGY GENERATED (MWH)	0.0	2848800.0	226511619.0
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0.0	937490.0	71555993.0
18. NET ELECTRICAL ENERGY GENERATED (MWH)	0.0	892790.0	67475525.0
19. UNIT SERVICE FACTOR	0.0%	31.7%	53.3%
20. UNIT AVAILABILITY FACTOR	0.0%	31.7%	53.3%
21. UNIT CAPACITY FACTOR (USING MDC NET)	0.0%	33.8%	51.0%*
22. UNIT CAPACITY FACTOR (USING DER NET)	0.0%	30.6%	42.6%
23. UNIT FORCED OUTAGE RATE	100.0%	68.3%	30.5%
24. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE AND DUR	ATION OF EACH):	•	

- 25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: June 13, 1994
- 26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION	<del></del>	<u></u>

<sup>\*\*</sup> Based on condenser backpressure

<sup>\*</sup> Weighted Average (635 MWe used as MDC Net prior to October 1985)

# AVERAGE DAILY UNIT POWER LEVEL

MONTH	May		DOCKET NO50- UNITPalisa DATE06/03 COMPLETED BY _BWBer TELEPHONE (616)764-8	<u>des</u> /94 les
DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER	LEVEL
	(MWe Net)		(MWe Net)	
1.	0	17.	0	
2.	0	18.		
3.	0	19.	0	
4.	0	20.	0	
5.	0	21.	0	
6.	0	22.	0	
7.		23.	0	
8.	0	24.	0	
9.		25.	. 0	
10.		26.	0	
11.	0	27.	0	
12.	0	28.	0	
13.	0	29.	0	
14.	0	30.	0	
15.	0	31.	0	
16.	<b>0</b>			

## INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-NET for each day in the reporting month. Compute to the nearest whole megawatt.

## SUMMARY OF OPERATING EXPERIENCE FOR MAY 1994

The plant remained off-line the entire month of May.

 DOCKET NO
 50-255

 UNIT
 Palisades

 DATE
 06/06/94

 COMPLETED BY
 BWBerles

 TELEPHONE
 (616)764-8913

REPORT MONTH \_\_\_\_\_ MAY 1994

### UNIT SHUTDOWNS AND POWER REDUCTIONS

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective  Action to  Prevent Recurrence
01	02/17/94	F	744	A	1	94-006	·		Safety Injection System Check Valve Leak Repair
						94-005			RPS Cable Separation Inspections
						94-007	*		EDG Fuel Oil Supply - Licensing Basis
						94-008			Lack Of Separation/Isolation Between 1E Non 1E Circuits
						94-009			CST And PCS Makeup Tank Inventory Below TS Criteria
						94-010			Bioshield Concrete Temperature In Excess of TS Limit
						94-011			Potential Inability Of A Single Source To Start DG's Within TS Limits
				•		94-012			TMM Internal Ground - RPS Design Basis

94-013

94-014

Instrument Tubing To RCP's Outside Plant Design Basis

Potential Pump Sump Blockage From Debris

1. F: Forced

S: Scheduled

Reason:

2.

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License

Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3.
Method:

1-Manua l

2-Manual Scram

3-Automatic Scram

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data

Entry Sheets for Licensee Event Report (LER) File

(NUREG-0161)

5. Exhibit I - Same Source

**,**....,