

NOTICE OF VIOLATION

Consumers Power Company
Palisades Nuclear Generating Facility

Docket No. 50-255
License No. DPR-20

During an NRC inspection conducted from April 13 through May 27, 1995, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specifications 6.8.4.b and 6.5.2.4.2.j respectively require a program to monitor the radiation and radionuclides of the Palisades Nuclear Plant and audits of the radiological environmental monitoring program. 10 CFR 50 Appendix B Criterion XVI requires that identified deficiencies be promptly identified and corrected.

Contrary to the above, sampling deficiencies in the radiological environmental monitoring program remained uncorrected after being identified by the Nuclear Performance Assessment Department in October 1991 and October 1992.

This is a Severity Level IV violation. (Supplement IV)

Dated at Lisle, Illinois this
27th day of June 1995

9507070021 950627
PDR ADOCK 05000255
G PDR