

**ENCLOSURE**

**CONSUMERS POWER COMPANY  
PALISADES PLANT  
DOCKET 50-255**

**FINAL SCENARIO  
1996 PALISADES EMERGENCY EXERCISE**

*9612110205 200P*



**Consumers  
Power**

**POWERING  
MICHIGAN'S PROGRESS**

**1996**

**PALEX**

**October 22, 1996**

Palex 1996

With one of the two diesel electrical generators tagged out for maintenance, (recoverable if maintenance on the diesel is completed) the plant undergoes a Steam Generator tube leak and is tripped off line.

Safety Injection will be initiated to maintain Primary Coolant Pressure and will be subsequently throttled. One of the High Pressure pumps will trip but may be recovered by the crew if timely and appropriate actions occur.

Emergency procedures mitigating the casualty will be entered. An Alert will be declared and the Emergency Plan entered. An accountability exercise will require the plant staff to locate an unaccounted for employee. Two Primary Coolant Pumps will be turned off.

A Primary Coolant Pump will become distressed as it undergoes shaft failure. When it fails (just as it is tripping), debris will enter the Primary Coolant System. Within minutes it enters the fuel region of the core and causes fuel failure due to impingement. Local radiation detectors will then give some indication of the failed fuel. At this time, an uncontrolled cool down of the Primary Coolant System begins due to a structural failure of Steam Generator relief valve RV-0707 which allows the valve to open. As the downstream flange on this valve has been improperly assembled (no gasket), the affected steam generator safety valve downstream piping in the middle level of the Component Cooling Room is also spewing contaminated steam into the room. This area will then be inaccessible due to steam, visibility and unknown radiation dose rates.

Attempts to quantify the extent of failed fuel will be reduced to sample analysis and field data. A significant off site contaminated plume will be manifested for at least an hour.

The Site Emergency Director( SED) at the Emergency Off Site Facility (EOF) should raise the event classification to a General Emergency (GE). Protective Action Recommendations should be given to the State of Michigan Authorities recommending some identified sheltering of local inhabitants. As information from the field begins to come in as to the extent and intensity of the radioactive plume, Protective Action Recommendations are escalated to include evacuation locally and in specific areas.

A security door alarm will be received at the Spent Fuel Pool. The security force is prevented from checking the alarm on time by the Operations Support Center OSC (requires significant communications, notifications, and decision making).

A news media team attempts to breech security at the Emergency Off Site Facility (EOF) to obtain an interview with the Site Emergency Director (SED).

Time jump to stable plant conditions (no further release occurring or threatened).

Drill terminated.

**Time:**

0815 Initial conditions:

**Plant is at 100% Power near the end of Core Life.**

**1-2 Diesel is tagged out of service for maintenance** and work is in progress. Mechanical maintenance has removed the first of two Pressure Control Valves (PCVs) 1489 and 1490 from the Air start motors for their replacement. Instrument Technicians have removed the belly tank fuel switches LS 1468, 1471, 1473, and 1475 for a Functional Equivalent Substitution.

Radiation monitor RIA 2325 (Stack Gas) is out of service for calibration.

**No other equipment is out of service.**

0830 Scenario begins (post turnover etc.):

0835 **70 g.p.m. tube leak begins in the B Steam Generator.**

0836 Condenser Off Gas Radiation Monitor Alarms (RIA 0631 @ 5xE6) and continues to rise (Will lower if it is isolated from the steam flow stream from the B Steam Generator). The Operators enter the Alarm Response Procedure (ARP) and begin to perform directed actions such as: requests confirmatory Steam Generator samples and consider entry into Off Normal Procedures (ONPs) for Steam Generator Tube Leak (ONP 23.2).

0837 Second Charging pump automatically starts, first Charging pump speeds up in an attempt to maintain level in the Pressurizer.

Operators attempt to quantify the leak (may leave Letdown in service). Failed Fuel Monitor Low Flow alarm if Letdown is isolated.

RIA 2323 "B" Main Steam Line Gamma Radiation monitor alarms in the "alert" range.

RIA 2326 Stack Gas low range monitor reading trends upward.

Stack gas monitor trending up.

PCS Pressure begins to lower.

0838 Third Charging pump automatically starts, first Charging pump at max speed  
(May take longer if letdown is isolated).

0840 Volume Control Tank Low Level alarm (VCT).

0842 Crew quantifies the leak at greater than 50 gallons per minute and then:

The Control Room Supervisor (CRS) orders the reactor plant "tripped" off and the Shift Supervisor (SS) enters the Emergency Implementation (E.I.) Procedure (per Off Normal Procedure 23.2).

OR.... The CRS orders the plant to commence a down power evolution (per Off Normal Procedure ONP 23.2).

IF.... The plant down power evolution is ordered instead of a plant trip, the scenario controllers will insert a turbine trip on the simulator to cause the reactor plant to trip and force Emergency Operating Procedure (EOP) entry by the crew.

Post trip actions and diagnosis of Emergency Operating Procedure EOP 1.0 and Emergency Implementation Plan event classification begins.

0847 Steam Generator Blowdowns isolate (affects the ability to obtain Steam Generator chemistry samples.)

0851 Event diagnosis and classification complete.

Control Room Supervisor conducts a "briefing" of the operating crew.

Operators exit the Reactor Trip procedure (EOP1.0) and enter the Steam Generator Tube Rupture procedure (EOP 5.0) or the Functional Recovery procedure (EOP 9.0).

Operators initiate Emergency Boration of the Primary Coolant System.

Shift Supervisor activates the Site Emergency Plan at the ALERT level based on Primary Coolant System Integrity. Emergency Siren sounded, site wide accountability initiated.

Work on the 1-2 Diesel is interrupted.

**Note: The Diesel 1-2 can be returned to service after installation of the**

**Pressure Control Valves and Level Switches.** The protective tagging would have to be released and cleared, post maintenance testing performed and operability testing done before it would be considered OPERABLE. This would take several hours if undertaken.

**Controllers arrange the detention of an employee** in the Nuclear Performance Assessment Department (NPAD) office trailer for an Accountability process check.

- 0855 Operations requests Chemistry samples for activity and Lithium requested on both steam generators in accordance with Emergency Procedures (sample path may be automatically isolated).

Operators request Radiation surveys for both main steam lines.

- 0900 Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure EI-2.1.

- 0905 Safety Injection Actuation Signal (SIAS) initiates on low Pressurizer Pressure.

Operators begin B Steam Generator isolation.

Operators determine adequate boron to be in the Primary Coolant System (PCS) allowing the cooling of the PCS below 525 degrees F. They then start cooling <525 but >500 degrees F. (They must get the plant below 525 degrees F to be able to isolate the B Steam Generator.)

Operators open Primary system relief valves (PORV) isolation valves in anticipation of future over pressure protection needs.

- 0907 **P 66A High Pressure Safety Injection (HPSI) pump trips** on a faulty supply breaker over current timed (Y phase) relay (the relay turns but does not reset as it should thus resulting in the unwarranted trip of the breaker).

**Note:** Recovery of this component enhances the plant safeguards capability should the crew elect to troubleshoot, repair, and recover P66A. The relay could be replaced from plant spared storage or the entire breaker may be exchanged with the spare breaker. The coordination of the activities necessary to restore this pump could take several hours.

- 0913 Operators remove the first two Primary Coolant Pumps (PCP)s from service.

- 0916 Operators meet the criteria for throttling and then throttle the equipment initiated by the Safety Injection Actuation Signal (SIAS).

0920 The Duty and Call Superintendent takes the Site Emergency Director (SED) role from the Shift Supervisor (SS). Emergency notifications are turned over from the Control Room to the Technical Support Center (TSC).

Chemistry delivers sample results (activity and lithium) if they were attainable (not isolated).

Operators complete the isolation of B Steam Generator.

0921 Accountability is completed and it is determined that one employee is missing.

Search and rescue activities begin.

0950 Site Emergency Director (SED) transfers Command and Control to the Emergency Off Site Facility (EOF) Director.

The missing employee in the NPAD trailer is recovered.

0956 Operators request that the Turbine Building Sump, Condensate, and connected systems requested be sampled.

Operators request additional radiation surveys per EOP Sup #14.

Operators place Low Temperature Over Protection System in service.

1000 Operators begin a plant cooldown below 500 degrees F to curtail the Steam Generator tube leak.

Emergency Procedure actions and notifications continue.

1015 **Intrusion alarm** is received on the Cask Transfer access door due to a faulty mechanism. Security must coordinate their response through the Operations Support Center (OSC). Due to concerns regarding unknown radiation doses in the area, the response may be delayed by the OSC. Interface between security and the OSC must be sufficient to ensure appropriate permissions and notifications occur with regard to the suspension/delay of normal security requirements.

1020 **Primary Coolant Pump (PCP) P50C vibration distress alert** occurs.

1025 **PCP P50C tripped** (due to distress associated with shaft failure) if the crew has not manually tripped the pump by this time.

1031 **B Steam Generator steam safety valve RV- 0707 undergoes structural failure** allowing the valve to lift, causing an uncontrolled cool down of the plant to begin.

**1%Failed fuel** (due to PCP shaft component debris) occurs causing some local radiation monitors to begin to reflect elevated radiation indications.

Operators exit any "optimal recovery" procedures that they might have been in (EOP 5.0) and enter Emergency Operating Procedure (EOP) 9.0 (if they were not already using this "functional recovery" procedure).

**Main steam line gamma monitors (RIA 2323 and 2324), the corridor monitor outside the Control Room (RIA 2309), the Containment area monitor (RIA 2315), and the Component Cooling Upper Level area monitor (penetration and fan room RIA 5710) radiation readings begin to raise slightly.**

The Component Cooling Room (CCW) room is uninhabitable due to steam, visibility and unknown radiation as there was no gasket installed in the downstream flange.

A radioactive plume is initiated with some contamination (only on site at first).

Radiation levels around Chemical and Volume Control System components is unaffected as Letdown flow is isolated.

1040 Failed Fuel Monitor (if in service via Letdown flow) alarms and indicates at the top of its scale. If the crew asks to have this monitor "up scaled", **controllers will only simulate doing so and report that it has been up scaled (leave it on the initial scale where it is at the top of the scale)**.

Attempts to obtain Primary Coolant System (PCS) samples via Post Accident Sample Panel (PASM Panel) may be made. (Extent of fuel damage is not discernable from the indications of fuel damage which are available at this time). Radiation dose received by those attempting to draw and process such samples will be significant.

Off Gas and Containment Area Monitors (RIA 1805, 1806, 1807, and 1808) are trending higher. **Controllers will raise the background radiation levels on these detectors about for an hour before allowing them to begin to lower or "decay".**

Entry into the Failed Fuel Procedure Off Normal Procedure (ONP) 11.1 may be delayed due to the time it takes for plant conditions to match the "Symptoms" for entry.

- 1045 The Emergency Off Site Facility (EOF) Director declares a **General Emergency (GE)**

**Protective Action Recommendations** given to the State of Michigan for shelter within 2 miles and a radius 5 miles for the downwind sector.

First field team radiation readings detected at  $\frac{1}{2}$  mile from the site indicate that an off site release is in progress.

- 1100 Field team data indicates that the **Protective Action Guidelines are exceeded at 2 miles.**

Emergency Procedure actions and notifications continue.

- 1115 **Protective Action Recommendations** are generated (evacuation to 5 miles in all sectors and 10 miles in down wind sectors).

- 1150 A media identified vehicle breeches Emergency Off Site Facility (EOF) perimeter security.

Security within the Emergency Off Site Facility (EOF) is notified to anticipate an encounter with the media by the perimeter security.

- 1155 Media team attempts access to Emergency Off Site Facility (EOF) to film and interview the Site Emergency Director (SED).

Emergency Off Site Facility (EOF) security detains the media team and makes the appropriate notifications.

- 1200 Emergency Procedure actions and notifications continue.

- 1300 Emergency Procedure actions and notifications continue.

- 1400 "Time jump" conditions announced: Plant is in Cold Shutdown and depressurized on Shutdown Cooling System flow. All electrical and Safety Train equipment is operable. The release has been terminated. Maintenance has "shored up" the depressurized RV-0707 and its downstream flange (from the B Steam Generator) in the Component Cooling Room middle level.

- 1415 Scenario concluded.

Scenario: **Palex 96** Date 22 October 1996 Time 0800

Message No: 1 Scenario time 0000

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

All oncoming shift personnel

**Simulated Plant Conditions:**

See the attached data sheets and the initial conditions listed below.

**Message:**

The plant has been operating at 99.6 % power for more than 100 days and is very near to the end of core life. The plant is running well and few alarms are annunciated. The 1-2 Diesel Generator has been tagged out of service for workmen protection at 0200 and released for Maintenance at 0300. Mechanical Maintenance has removed the first of two pressure control valves (PCVs 1489 and 1490) from the 1-2 Diesel Generator air start motors for their replacement. Instrument Technicians have removed the belly tank fuel oil switches (LS-1468, 1471, 1473, and 1475) from the 1-2 Diesel Generator for a Functional Equivalent Substitution of the switches. RIA 2325 Radiation Monitor (Stack Gas Effluent particulate Iodine) is out of service for calibration. No other equipment is degraded or out of service. The plant is at 11.7 GWD with PCS boron at 71 ppm. Xenon is at equilibrium and target ASI is .02. Dose equivalent iodine is  $8.5 \times 10^{-2}$   $\mu\text{Ci}$  and Iodine 131 is at  $2.1 \times 10^{-1}$   $\mu\text{Ci}$ . The Primary to Secondary Leak Rate based on Xenon 133 analysis of condenser off gas is at  $7 \times 10^{-5}$  gpm. The weather is cool, partly cloudy, with a 10% chance of precipitation.

---

**For Controller use only**

**Controller Notes:**

Selected players have been given copies of these initial conditions at the player briefing. The Simulator operator has brought up the **Simulator in IC 21** with 1-2 DG OOC (Remote ED-45B Local over speed trip lever tripped and the red "unit" light turned off **override DG 1-2 Pus-R** to simulate "tagged out" configuration). **RIA 2325** is on override "off". The simulator has been placed in "run" with charts etc. on.

**Action expected:**

The SCR staff should thoroughly familiarize themselves with the provided conditions.

Scenario: **Palex 96** Date 22 October 1996 Time 0815

Message No: 2 Scenario time 0015

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

Instruct the Control Room (simulator) to announce the following message: "Attention all personnel. The Emergency exercise will commence shortly. All announcements related to the exercise will be preceded and followed by the statement 'This is a drill.'"

---

**For Controller use only**

**Controller Notes:**

**Note: The Diesel 1-2 can be returned to service after reinstallation of Pressure Control Valves and Level Switches. The protective tagging would have to be released and cleared, post maintenance testing performed and operability testing done before it would be considered fully OPERABLE even if it were placed back in service. This would take several hours if undertaken. The Simulator Operator restores the diesel to service when "clearing" the protective tagging order (remote ED-45B local over speed trip lever for and the red "unit" light DG 1-2 PUS-R lit on 1-2 DG). AO Controller will have to get word to the Simulator Operator when the "clearing of the tags" has begun.**

**Action expected:**

Control Room makes the Drill preparatory announcement.

Scenario: **Palex 96** Date 22 October 1996 Time 0830

Message No: 3 Scenario time 0030

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

The Simulator Operator will **insert a 70 gpm tube rupture** in the B Steam Generator (**MF-SG01B at .07**) in 5 minutes (0835 and runtime 0035). If a plant down power evolution is ordered instead of a plant trip, the scenario controllers will **insert a turbine trip (MF TC 01)** on the simulator to cause the reactor to trip and force Emergency Operating Procedure (EOP) entry.

**Action expected:**

Operators begin to detect/diagnose the casualty. Condenser Off Gas Radiation Monitor Alarms (RIA 0631 @ 5xE6) and continues to rise (Will lower if it is isolated from the steam flow stream from the B Steam Generator). The Operators enter the **Alarm Response Procedure (ARP)** and begin to perform directed actions such as: request confirmatory Steam Generator samples and consider entry into Off Normal Procedures (ONPs) for Steam Generator Tube Leak (ONP 23.2). They should then enter **ONP 23.2** for procedural guidance. The "B" Charging pump automatically starts and "A" Charging pump speeds up in an attempt to maintain level in the Pressurizer. Operators attempt to quantify the leak (may leave Letdown in service). The Failed Fuel Monitor Low Flow alarm will be received if Letdown is isolated. RIA 2323 "B" Main Steam Line Gamma Radiation monitor alarms in the "alert" range. RIA 2326 Stack Gas low range monitor reading trends upward. Stack gas monitor trending up. PCS Pressure begins to lower. The "C" Charging pump automatically starts, "A" Charging pump reaches maximum speed (if letdown is not isolated). Volume Control Tank Low Level alarm (VCT) annunciates. When the operators determine that the **PCS leak is greater than 50 gpm** and that it possibly is going into one of the Steam Generators, the following should occur: The Control Room Supervisor (CRS) orders the reactor plant "tripped" off or powered down, post trip actions and diagnosis per Emergency Operating Procedure EOP 1.0 begins.

Scenario: **Palex 96** Date 22 October 1996 Time 0845

Message No: 4 Scenario time 0045

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Controllers arrange the detention of an employee in the Nuclear Performance Assessment Department (NPAD) office trailer for an Accountability process check.**

**Action expected:**

Steam Generator Blowdowns isolate (affects the ability to obtain Steam Generator chemistry samples.) Operators should determine that the PCS leak is a tube leak and that it is most likely in the B Steam Generator. They should have entered EOP 1.0 upon the reactor trip. Operators continue to diagnose the casualty in EOP 1.0. When the post trip actions and event diagnosis are complete, the following activities should occur: Control Room Supervisor (CRS) conducts a "briefing" of the operating crew, Operators exit the Reactor Trip procedure (EOP1.0) and enter the Steam Generator Tube Rupture procedure (EOP 5.0) or the Functional Recovery procedure (EOP 9.0), Operators initiate Emergency Boration of the Primary Coolant System, the Shift Supervisor completes event classification and activates the Site Emergency Plan at the ALERT level based on Primary Coolant System Integrity, the Emergency Siren is sounded, site wide accountability is initiated, work on the 1-2 Diesel is interrupted as workers assemble in accountability areas, Operators requests Chemistry samples for activity and Lithium on both steam generators in accordance with Emergency Procedures, Operators request Radiation surveys for both main steam lines.

Scenario: **Palex 96** Date 22 October 1996 Time 0900

Message No: 5 Scenario time 0100

**Palisades Nuclear Plant**

**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

Simulator Operator causes **P 66A High Pressure Safety Injection (HPSI) pump to trip** after it is automatically started on Safety Injection Actuation Signal (SIAS) for low Pressurizer pressure (**MF SI-01**). **Note:** Recovery of this component enhances the plant safeguards capability **should the crew elect to troubleshoot, repair, and recover P66A**. The relay has a faulty supply breaker over current timer on the Y phase (the relay turns but does not reset as it should thus resulting in the unwarranted trip of the breaker). **AO and Maintenance Controllers must know which relay to indicate tripped** to the players. The relay could be replaced from plant spared storage or the entire breaker may be exchanged with the spare breaker. The coordination of the activities necessary to **restore this pump could take several hours**. The **AO controller will have to notify the Simulator Operator** when the initial tagging and final "clearing" has begun to facilitate installation and deletion of (**MF SI-01**) the P 66A malfunction which removes and restores the pump to service. If an **Alert is not declared** by 0910, **Controllers will "force" the Alert declaration**.

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure EI-2.1 and an **Alert** declared.. The following should be expected: Safety Injection Actuation Signal (SIAS) initiates on low Pressurizer pressure, Operators determine adequate boron to be in the Primary Coolant System (PCS) allowing the cooling of the PCS below 525 degrees F., they then start cooling <525 but >500 degrees F. (They must get the plant below 525 degrees F to be able to isolate the B Steam Generator.), Operators begin B Steam Generator isolation, Operators open Primary system relief valves (PORV) isolation valves in anticipation of future over pressure protection needs, **P 66A High Pressure Safety Injection (HPSI) pump trips**, Operators detect the loss of P66A, Operators remove the first two Primary Coolant Pumps (PCP)s from service at 1300 Psi as directed by procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 0915  
Message No: 6 Scenario time 0115

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**  
Control Room personnel

**Simulated Plant Conditions:**  
See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

If Radiation Protection performs a survey of the steam piping prior to 1030, the Controller can indicate that the levels are near normal with B generator steam lines slightly elevated (After 1030, the area will not be accessible).

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure. This should include the meeting of the SIAS throttling criteria and the possible throttling of some of this equipment, as well as the possible completion of the isolation of B Steam Generator. Chemistry delivers sample results (activity and lithium) if they were attained. The Duty and Call Superintendent takes the Site Emergency Director (SED) role from the Shift Supervisor (SS). Emergency notifications are turned over from the Control Room to the Technical Support Center (TSC). Accountability is completed and it is determined that one employee is missing. Search and rescue activities begin.

Scenario: **Palex 96** Date 22 October 1996 Time 0930

Message No: 7 Scenario time 0130

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure

Scenario: **Palex 96** Date 22 October 1996 Time 0945

Message No: 8 Scenario time 0145

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure. Site Emergency Director (SED) transfers Command and Control to the Emergency Off Site Facility (EOF) Director. The missing employee in the NPAD trailer is recovered. Operators request that the Turbine Building Sump, Condensate, and connected systems requested be sampled. Operators request additional radiation surveys per EOP Sup #14. Operators place Low Temperature Over Protection System in service as they are able.

Scenario: **Palex 96** Date 22 October 1996 Time 1000

Message No: 9 Scenario time 0200

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure. Operators begin a plant cooldown below 500 degrees F to curtail the Steam Generator tube leak.

Scenario: **Palex 96** Date 22 October 1996 Time 1015

Message No: 10 Scenario time 0215

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

Controllers cause a the SFP access door to alarm (with a "nonplaying" Security Officer). At 1020, Primary Coolant Pump (PCP) P50C vibration distress alert alarm occurs (**Simulator Operator inserts RC-16C**). **PCP P50C tripped by the Simulator operator** after 5 minutes (due to distress IAW shaft failure) if the crew has not manually tripped the pump by this time. Some **component material** from the Primary Coolant Pump (PCP) enter the system and begin to **access the reactor core**. If Letdown has been isolated by the crew, **The Simulator Operator overrides the Control Valve hand switch to close** to prevent its reopening. If it is still in service, then **the Simulator Operator will override the Hand Switch for CV 2001 to "auto"** and **override TIC 0201 to "1.0"** (could be preloaded on remote 5 for easier implementation).

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures (EOP 5.0 or 9.0) and Emergency Implementation Procedure. Operators may trip P50C Primary Coolant Pump. **Intrusion alarm** is received on the Spent Fuel Pool access door due to a faulty mechanism. Security must **coordinate their response through the Operations Support Center (OSC)**. Due to concerns regarding unknown radiation doses in the area, the response may be delayed by the OSC. Interface between security and the OSC must be sufficient to ensure appropriate permissions and notifications occur with regard to the suspension/delay of normal security requirements.

Scenario: **Palex 96** Date 22 October 1996 Time 1030

Message No: 11 Scenario time 0230

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**B Steam Generator steam safety valve RV-0707** (last of the 12) **undergoes structural failure and lifts (MS-06B)**, causing an uncontrolled cool down of the plant to begin as **contaminated steam exits the North West Safety Valve plenum (3 valves per plenum) forming a plume (AO Controller)**. The downstream flange was improperly assembled (no gasket) and is allowing large quantities of contaminated **steam to flow into the Component Cooling Water (CCW) Room** and out of its "Jail House Doors" (AO Controller). Visibility in the CCW Room is zero. **1% Failed fuel** (due to PCP shaft debris) occurs (RC-22 @ 1.0) causing some local radiation monitors to begin to reflect elevated radiation indications. If the crew asks for the Failed Fuel monitor "up scaled", controllers will report it done but not perform the action. Attempts to obtain Primary Coolant System (PCS) samples via Post Accident Sample Panel (PASM Panel) may be made but will result in significant dose to participants. (Extent of fuel damage is not otherwise discernable). Off Gas and Containment Area Monitors (RIA 1805, 1806, 1807, and 1808) are trending higher. Controllers will raise the background radiation levels on these detectors for about an hour before allowing them to begin to lower/decay.

**Action expected:**

Operators continue the actions and notifications of the Emergency Implementation Procedure. When the Excess Steam Demand Event occurs, Operators exit any "optimal recovery" procedures that they might have been in (EOP 5.0) and enter Emergency Operating Procedure (EOP) 9.0 if they were not already using this "functional recovery" procedure. **Main steam line gamma monitors (RIA 2323 and 2324), the corridor monitor outside the Control Room (RIA 2309), the Containment area monitor (RIA 2315), and the Component Cooling Upper Level area monitor (penetration and fan room RIA 5710) radiation readings begin to raise slightly.** The Component Cooling Room (CCW) room is uninhabitable due to steam, visibility, high radiation, and heated unlagged metal structures. Failed Fuel Monitor (if Letdown is in service) alarms and indicates at the top of its scale. Entry into the Failed Fuel Procedure Off Normal Procedure (ONP) 11.1 is delayed due to "symptoms" not yet matching conditions. the time it takes for plant conditions to match the "Symptoms" for entry.

Scenario: **Palex 96** Date 22 October 1996 Time 1045

Message No: 12 Scenario time 0245

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

First field team radiation readings detected at  $\frac{1}{2}$  mile from the site indicate that an off site release is in progress.

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures 9.0 and Emergency Implementation Procedure. The Emergency Off Site Facility (EOF) Director declares a **General Emergency (GE)**. **Protective Action Recommendations** given to the State of Michigan for shelter within 2 miles and a radius 5 miles for the downwind sector. First field team radiation readings detected at  $\frac{1}{2}$  mile from the site indicate that an off site release is in progress.

Scenario: **Palex 96** Date 22 October 1996 Time 1100

Message No: 13 Scenario time 0300

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

Field team data indicates that the **Protective Action Guidelines are exceeded at 2 miles.**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure. Field team data indicates that the **Protective Action Guidelines are exceeded at 2 miles.**

Scenario: **Palex 96** Date 22 October 1996 Time 1115

Message No: 14 Scenario time 0315

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

Steam, Heat, and Visibility are yet preventing entry into the Component Cooling Water Room. The Air Monitoring Alarm system outside the Control Room (in the plume area) does not alarm (though its read out continues to elevate) because of its background substitution feature. The approximate 4 to 5 mR/hr field is detectable on **RIA 2310 which elevates to its 5 mR/hr alarm** in the near future.

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure. **Protective Action Recommendations** are generated (**5 evacuation to miles in all sectors and 10 miles in down wind sectors**).

Scenario: **Palex 96** Date 22 October 1996 Time 1130

Message No: 15 Scenario time 0330

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1145

Message No: 16 Scenario time 0345

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

A media identified vehicle ignores/breeches Emergency Off Site Facility (EOF) perimeter security. The media team then attempts to access Emergency Off Site Facility (EOF) purposing to film and interview the Site Emergency Director (SED).

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure. Security within the Emergency Off Site Facility (EOF) is notified to anticipate an encounter with the media reported by the perimeter security. Emergency Off Site Facility (EOF) security detains the media team and makes the appropriate notifications.

Scenario: **Palex 96** Date 22 October 1996 Time 1200

Message No: 17 Scenario time 0400

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1215

Message No: 18 Scenario time 0415

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1230

Message No: 19 Scenario time 0430

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1245

Message No: 20 Scenario time 0445

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1300

Message No: 21 Scenario time 0500

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1315

Message No: 22 Scenario time 0515

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1330

Message No: 23 Scenario time 0530

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1345

Message No: 24 Scenario time 0545

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

**Action expected:**

Operators continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure.

Scenario: **Palex 96** Date 22 October 1996 Time 1400

Message No: 25 Scenario time 0600

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

At 1405 "Time jump" conditions (24 hours) are announced in **each facility** as follows: "Plant is in Cold Shutdown and depressurized on Shutdown Cooling System flow (**no steam being formed and no plume being released**). All electrical and Safety Train equipment is operable. Maintenance has closed RV-0707 steam generator relief valve in the middle level Component Cooling Room." **The EOF Director should make this announcement to the Plant over the P.A. system.** The conclusion of the scenario is eminent at the "time jump" announcement.

**Action expected:**

Operators initially continue the actions and notifications of Emergency Operating Procedures EOP 9.0 and Emergency Implementation Procedure until the "time jump".

Scenario: **Palex 96** Date 22 October 1996 Time 1415

Message No: 26 Scenario time 0615

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

The last set of data sheets reflect the "Cold Shut Down" conditions of the 24 hour "time jump".

**Action expected:**

Scenario concluded, Conclusion announced.

Scenario: **Palex 96** Date 22 October 1996 Time 1415

Message No: 26 Scenario time 0615

**Palisades Nuclear Plant**  
**Emergency Preparedness Exercise Form**

**Message For:**

Control Room personnel

**Simulated Plant Conditions:**

See the attached data sheets.

**Message:**

---

**For Controller use only**

**Controller Notes:**

The last set of data sheets reflect the "Cold Shut Down" conditions of the 24 hour "time jump".

**Action expected:**

**Scenario concluded,** Conclusion announced.

Site Emergency Planning Exercise  
Plant Status Report

.20

10/23/1996 14:15

PANEL C-13 INSTRUMENTS

MDSATE STO TANK LVL	78.75 percent
CNMT BLDG DOME TEMP	82.48 Deg F
SIRW TANK LEVEL	96.85 percent
CNMT WR PRESS 1805A	.00 psig
CNMT SUMP WATER LVL	585.01 feet
CNMT FLOOR WATER LVL	590.30 feet
SAFETY INJ T-82A LVL	84.56 percent
SAFETY INJ T-82B LVL	84.30 percent
SAFETY INJ T-82C LVL	84.24 percent
SAFETY INJ T-82D LVL	84.27 percent
SAFETY INJ T-82A PRS	216.90 psig
SAFETY INJ T-82B PRS	215.93 psig
SAFETY INJ T-82C PRS	216.99 psig
SAFETY INJ T-82D PRS	216.80 psig
SIAS SIGNAL STATUS	Normal

ANNUCIATOR PANEL K-13

HI PRES SIG STAT	Normal
JMT HI RAD SIG STAT	Normal

PANEL C-12 INSTRUMENTS

BOR ACID TK T-53A LVL	98.00 percent
BOR ACID TK T-53B LVL	98.00 percent
PRI COOLT PMP A amps	.00 amps
PRI COOLT PMP B amps	.00 amps
PRI COOLT PMP C amps	.00 amps
PRI COOLT PMP D amps	.00 amps
HOT LEG LP 1 TEMP	124.47 Deg F
HOT LEG LP 2 TEMP	124.49 Deg F
COLD LEG LP 1A TEMP	113.31 Deg F
COLD LEG LP 2A TEMP	100.69 Deg F
COLD LEG LP 1B TEMP	113.31 Deg F
COLD LEG LP 2B TEMP	100.69 Deg F
SUBCOOLED MAR LOOP A	89.77 Deg F
SUBCOOLED MAR LOOP B	89.76 Deg F
PZR WIDE RNG PRESS	15.41 psia
PZR SI CHANNEL PRESS	***** psia
STM GEN E-50A LVL	71.72 percent
STM GEN E-50A PRESS	14.28 psia
STM GEN E-50A STM FLO	.00 Mlbm/hr
FW FLOW SGA	.00 Mlbm/hr
STM GEN E-50B LVL	.00 percent
STM GEN E-50B PRESS	14.28 psia
STM GEN E-50B STM FLO	.00 Mlbm/hr
FW FLOW SGB	.00 Mlbm/hr

Site Emergency Planning Exercise  
Plant Status Report

21

10/23/1996 14:15

PANEL C-01 INSTRUMENTS

STM GEN FD P-1A DISCH	14.99 psig
STM GEN FD P-1B DISCH	14.99 psig
SG AUX FD PMP C DISCH	16.90 psig
AUX FW PMP TURB STM P	.00 psig
SG AUX FD PP DISC HDR	16.90 psig
CNDR HOTWELL LEVEL	170.85 percent
CNDR VACUUM WR	.00 inHg
SG E50B ATMOS RV 779	Closed
AUX FW PMP P-8A MOTOR	Stopped
TURB DR AUX FW P-8B	Off
AUX FW PMP P-8C	Stopped
HTR DRAIN PMP P-10A	Stopped
HTR DRAIN PMP P-10B	Stopped
CONDENSATE PMP P2A	Off
CONDENSATE PMP P2B	Off

PANEL C-11 INSTRUMENTS

FW FLOW STM E-50A	.00 gpm
FW FLOW STM E-50A	.00 gpm
JX FW FLOW STM E-50B	.00 gpm
AUX FW FLOW STM E-50B	.00 gpm
CNDR VACUUM PRESSURE	.00 inHg

PANELS C-11 AND BACK OF C-11A

CNMT RAD ISO RI1805	.62E+00 rem/hr
CNMT RAD ISO RI1806	.70E+00 rem/hr
CNMT RAD ISO RI1807	.61E+01 rem/hr
CNMT RAD ISO RI1808	.30E+01 rem/hr
CNMT HI R GAM RIA2321	.16E-01 rem/hr
CNMT HI R GAM RIA2322	.15E-01 rem/hr
CNMT H2 CONC RIGHT	.00E+00 percent
CNMT H2 CONC LEFT	.00E+00 percent
STM GEN A GAM RIA2324	.33E+02 rem/hr
STM GEN B GAM RIA2323	.17E+02 rem/hr

DATALOGGER ONLY INPUTS

GEN GROSS OUTPUT	.00 MW
STAT NET ELEC OUTPUT	.00 MW
GRP 1 GRP TARGET ROD	.00 inches
GRP 2 GRP TARGET ROD	.00 inches
GRP 3 GRP TARGET ROD	.00 inches
GRP 4 GRP TARGET ROD	.00 inches
GRP A GRP TARGET ROD	.00 inches
GRP B GRP TARGET ROD	.00 inches
AVG CET TEMP	128.43 Deg F

Site Emergency Planning Exercise  
Plant Status Report

22

10/23/1996 14:15

PANEL C-08 INSTRUMENTS

ERVICE WTR PMP P-7A	Started
ERVICE WTR PMP P-7B	Started
ERVICE WTR PMP P-7C	Started
OMP CLG PMP P-52A	Started
OMP CLG PMP P-52B	Stopped
OMP CLG PMP P-52C	Started
NMNT AIR CLR FAN V-1A	Stopped
NMNT AIR CLR FAN V-2A	Stopped
NMNT AIR CLR FAN V-3A	Started
NMNT AIR CLR FAN V-4A	Started

PANEL C-03 INSTRUMENTS

PSI PUMP P-66A	Stopped
PSI PUMP P-66B	Stopped
PSI PUMP P-67A	Stopped
PSI PUMP P-67B	Started
NMNT SPRAY PMP P-54A	Stopped
SPRAY PMP P-54B	Stopped
SPRAY PMP P-54C	Stopped
REF TK CV-3057	Closed
NMNT SUMP CV-3029	Closed
SI & REF TK CV-3031	Closed
NMNT SUMP CV-3030	Closed

PANEL C-02 INSTRUMENTS

SDC HX PCS OUT TEMP	100.80 Deg F
VOLUME CNTRL TK TEMP	68.83 Deg F
VOLUME CNTRL TK PRESS	35.28 psig
VOLUME CNTRL TK LEVEL	70.00 percent
PRI CLT LETDOWN FLOW	.00 gpm
CHARGING LINE FLOW	.00 gpm
QUENCH TK T-73 PRESS	.01 psig
QUENCH TK T-73 LEVEL	64.16 percent
PZR SI CHANNEL PRESS	15.41 psig
PZR T-72 LEVEL	66.11 percent
PZR WR LEVEL IND	43.23 percent
PZR HTR TRANS amps	.00 amps
PZR HTR TRANS amps	.00 amps
PCS LOOP1 TAVG	118.89 Deg F
PCS LOOP2 TAVG	112.58 Deg F
STUP CNT RATE X NI001	19.09 cps
STUP CNT RATE Y NI002	19.38 cps
WIDE RNG POWER NI003	.00 percent
WIDE RNG POWER NI004	.00 percent
POWER RNG CHANNEL A	.00 percent
POWER RNG CHANNEL B	.00 percent
PZR PWR REL PRV-1042B	Closed
PZR POR BLK VLV 1042A	Open
PZR PWR REL PRV-1043B	Closed
PZR POR BLK VLV 1043A	Open
CHARGING PUMP P-55A	Stopped
CHARGING PUMP P-55B	Stopped
CHARGING PUMP P-55C	Stopped
PRI COOLANT P-50A	Stopped
PRI COOLANT P-50B	Stopped
PRI COOLANT P-50C	Stopped
PRI COOLANT P-50D	Stopped

Site Emergency Planning Exercise  
Meteorological Report

351

10/23/1996 14:15

Temperature  
8.5 C

Height 60 Meters  
Wind Direction 230. Circular Degrees  
Std Deviation 7. Circular Degrees  
Wind Speed 9. mph

Stability

E

Height 10 Meters  
Wind Direction 230. Circular Degrees  
Std Deviation 7. Circular Degrees  
Wind Speed 7. mph

52

Site Emergency Planning Exercise  
Radiological Report

10/23/1996 14:15

Fuel Handling

Mon 1 1.00E-01 mr/hr  
Mon 2 1.00E-01 mr/hr

Liquid RAD Monitors

CW	0915	1.30E-01 cpm
W	0833	3.80E+01 cpm
AD Waste	1049	4.54E+02 cpm
G Blow dn	0707	1.30E+03 cpm
ix basin	1323	2.80E-01 cpm
ailed Fuel	0202B	1.00E+02 cpm
ain stm A	2324	3.28E+01 cpm
ain stm B	2323	1.72E+01 cpm

Containment

RIA1805	6.16E-01 r/hr
RIA1806	6.98E-01 r hr
RIA1807	6.08E+00 r/hr
RIA1808	3.02E+00 r hr
Hi rng L	1.56E-02 r/hr
Hi rng R	1.46E-02 r hr

Stack Monitors

RIA2326	6.07E+01 cpm
RIA2327	1.10E-01 mr/hr
RIA2318	8.37E+03 cpm
RIA2319	8.37E+01 cpm

Control room

Dirty Waste Drain	Monitor	9.77E-02 mr/hr
T-60W	14.2 %	
T-60E	8.9 %	
Cnd off gas	2.50E+01 cpm	
EESG RAD	2.50E+02 cpm	
WESG RAD	2.20E+02 cpm	
RAD WSTE VNT	3.80E+01 cpm	
SFP North	1.00E-01 mr/hr	
SFP South	1.20E-01 mr/hr	

## ANNUNCIATOR TEST PRINT OUTS

K-01

	1	2	3	4	5	6	7	8	9	10	11	12
1	ON				ON			ON	ON		ON	
2								ON	ON			
3										ON	ON	
4								ON		ON		
5										ON		
6									ON	ON	ON	ON

K-02

	1	2	3	4	5	6	7	8	9	10	11	12
1												
2												
3												
4												
5												
6												

1  
2 ON      3 ON      4  
5  
6  
7  
8  
9  
10

K-05

1      2      3      4      5      6      7      8      9      10

\*\* 1 \*\*\*\* 2 \*\*\*\* 3 \*\*\*\* 4 \*\*\*  
1 . . ON . .  
. . . . .  
\*\*\*\*\*  
2 . . ON . .  
. . . . .  
\*\*\*\*\*

K-06B

\*\* 1 \*\*\*\* 2 \*\*\*\* 3 \*\*\*\* 4 \*\*\*  
1 ON . . ON . .  
. . . . .  
\*\*\*\*\*  
2 ON . . ON . .  
. . . . .  
\*\*\*\*\*

K-06C

\*\* 1 \*\*\*\* 2 \*\*\*\* 3 \*\*\*\* 4 \*\*\*  
1 ON . . . .  
. . . . .  
\*\*\*\*\*  
2 ON . . . .  
. . . . .  
\*\*\*\*\*

K-06D

\*\* 1 \*\*\*\* 2 \*\*\*\* 3 \*\*\*\* 4 \*\*\*  
1 . . ON . . ON . .  
. . . . .  
\*\*\*\*\*  
2 . . . . ON . . ON . .  
. . . . .  
\*\*\*\*\*

1 2 3 4 5 6 7 8 9 10 11  
ON ON ON  
2 ON ON  
3 ON ON  
4 ON ON ON ON  
5 ON ON  
6 ON

K-09

1 2 3 4 5 6 7 8 9 10 11 12  
ON ON ON ON  
2 ON ON ON ON ON  
3 ON ON ON ON ON  
4 ON ON ON ON ON  
5 ON ON ON ON ON  
6 ON ON ON ON ON

K-11

• 1 • 2 • 3 • 4 • 5 • 6 • 7 • 8 • 9 • 10 • 11 • 12 • 13 •  
1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

K-13

• 1 • 2 • 3 • 4 • 5 • 6 • 7 • 8 • 9 • 10 • 11 • 12 • 13 •  
1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
ON  
ON  
ON

K-22

..	1	...	2	...	3	...	4	...	5	...
.	.	.	.	.	.	.	.	.	.	.
1	.	.	.	.	.	.	.	.	.	.
2	.	.	.	.	.	.	.	.	.	.
3	.	.	.	.	.	.	.	.	.	.
4	.	.	.	.	.	.	.	.	.	.
	ON		ON							

TASK # 27000025

SYSTEM : INCORE COMPUTER CORP. MPX-32 S.6.2

CHIOSYSS PAGE 7

K-33

1	2	3	4	5	6	7	8	9	10
1	1	1	1	1	1	1	1	1	1
2	1	1	1	1	1	1	1	1	1
3	1	1	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1	1	1


K-34


1	2	3	4	5	6
1	1	1	1	1	1
2	1	1	1	1	1
3	1	1	1	1	1
4	1	1	1	1	1


K-35

1	2	3	4	5	6	7
1	1	1	1	1	1	1
2	1	1	1	1	1	1
3	1	1	1	1	1	1
4	1	1	1	1	1	1
5	1	1	1	1	1	1
6	1	1	1	1	1	1
7	1	1	1	1	1	1

24 hour jump








contaminated  
10-30K / 100 cm<sup>2</sup>  
(5m-Bq) - 6m Area

plume -  
influence east  
turbine bldg which  
is unshielded

625'


CONSUMERS POWER COMPANY
EQUIP. LOC. REACTOR & TURBINE PLANT IN 1000 ft <sup>2</sup>
PARTIAL SHAD. PLANT IN 1000 ft <sup>2</sup>
(C)



(500 - 8kg) - เก็บรักษา  
Conformity of 8-30K / 100 cm




plan by hand pen



คงอยู่

LAKE MICHIGAN

24 hour pump  
5K → 10K / 100 cm<sup>2</sup>  
Contaminated area




PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES

**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**


SECTION 2  
Revision 3  
Page 1 of 1

**FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE**



## **24 HOUR TIME JUMP ENVIRONMENTAL DATA**

The following map shows the boundary of the ground deposition. The survey data was collected over the last 24 hours. Isotopic analysis is unavailable.



CHEMISTRY ANALYSIS

RX WATER SAMPLE

OCTOBER 22, 1996

0800-1035

I-131=2.1E-02 uCi\ml  
DEI =8.5E-02 uCi\ml

1040-1230

PASM ONLY

I-131=1.30E00 uCi\ml  
DEI =5.26E00 uCi\ml

\* STEAM GENERATOR SAMPLES

NOT ABLE TO OBTAIN AFTER TRIP

0900 →  
TURBINE SUMP 3.8 E-05  $\mu$ ci/ml

Use this table to provide the CFMS Met. Data, onsite Met Tower data, and/or the WSI hourly met data.

Met Data for Palex '96								
Scenario Time	Temp °C	Stab. Class (Pas/dT)	Wind Speed (10 m)	Wind Dir. (10 m)	Std. Dev. (10 m)	Wind Speed (60 m)	Wind Dir. (60 m)	Std. Dev. (60 m)
0800	3.0	E/-0.4	13	227	7.2	17	227	7.2
0815	3.2	D/-0.9	13	222	11.2	17	222	11.2
0830	3.5	D/-1.1	18	229	9.5	23	229	9.5
0845	3.5	D/-1.2	22	221	12.0	28	221	12.0
0900	3.7	D/-1.3	19	219	10.4	24	219	10.4
0915	4.0	D/-1.1	15	225	9.2	20	225	9.2
0930	4.5	D/-0.9	13	230	7.9	17	230	7.9
0945	4.6	D/-0.8	15	224	8.3	20	224	8.3
1000	4.9	D/-0.7	12	219	8.1	16	219	8.1
1015	5.2	E/-0.3	8	224	7.2	10	224	7.2
1030	5.5	E/-0.2	9	223	7.0	11	223	7.0
1045	6.0	E/-0.4	7	221	6.9	9	221	6.9
1100	6.2	E/-0.5	5	226	7.0	7	226	7.0
1115	6.8	E/-0.4	4	227	7.0	5	227	7.0
1130	7.1	E/-0.3	5	223	6.8	7	223	6.8
1145	7.3	E/-0.2	6	228	6.5	8	228	6.5
1200	7.3	E/-0.3	5	225	7.0	7	225	7.0
1215	7.5	E/-0.5	3	229	6.7	4	229	6.7
1230	8.2	E/-0.3	5	225	6.9	7	225	6.9
1245	8.5	E/-0.3	8	223	6.0	10	223	6.0
1300	8.7	E/-0.4	9	219	6.2	11	219	6.2
1315	9.3	E/-0.3	8	230	5.5	10	230	5.5
1330	9.2	D/-0.6	11	225	8.2	14	225	8.2
1345	9.5	D/-0.8	10	228	8.9	13	228	8.9
1400	9.1	D/-0.6	12	221	8.2	16	221	8.2
1415	8.9	D/-0.7	13	223	8.1	17	223	8.1
1430	8.8	E/-0.5	7	226	7.1	9	226	7.1
1445	8.8	E/-0.4	9	225	7.2	11	225	7.2
1500	8.5	E/-0.4	7	230	7.2	9	230	7.2
1515	8.7	E/-0.3	5	225	7.0	7	225	7.0
1530	8.9	E/-0.4	4	221	6.4	5	221	6.4
1545	8.8	E/-0.1	5	226	5.3	7	226	5.3

### METEOROLOGICAL FORECAST DATA

INTERPOLATED MOS FOR PAL 4219N, 8619W USING ORD, SBN, GRR:

DY/HR	22/23	23/05	23/11	23/17	23/23	24/05	24/11	24/17	GMT
DY/HR	22/18	23/00	23/06	23/12	23/18	24/00	24/06	24/12	EST
WIND-MP	2709	2703	2804	2908	3011	2914	3115	3312	
CLDS-I	5	9	9	3	2	1	2	1	
HGT-FT	3750	4550	4550	>7500	>7500	>7500	>7500	>7500	
PAS	C	D	D	C	D	E	D	C	

DETECTOR POWER SUPPLIES

<u>Power Supply</u>	<u>Radiation Element</u>	<u>Location</u>
Y10-14	RE-1805	Containment Air Cooler V1
Y20-14	RE-1806	Containment Air Cooler V2
Y30-14	RE-1807	Containment Air Cooler V3
Y40-14	RE-1808	Containment Air Cooler V4
Y01-35	RE-2300	East Engineered Safeguards Room
Y01-35	RE-2301	East Service Corridor E1 - 590'-0"
Y01-35	RE-2302	Radwaste Control Area
Y01-35	RE-2303	Corridor 106A
Y01-35	RE-2304	Controlled Lab Corridor
Y01-35	RE-2305	Access Control Station
Y01-35	RE-2306	E1 607' - Air Lock Auxiliary Building
Y01-35	RE-2307	Containment Purge Unit Room
Y01-35	RE-2308	Radwaste Demin Room Roof
Y01-35	RE-2309	E1 625' - Corridor 340
Y01-35	RE-2310	Main Control Room
Y01-35	RE-2311	Turbine Operating Floor
Y01-35	RE-2312	Lunchroom
Y01-35	RE-2313	Spent Fuel Pool Area (South)
Y01-35	RE-2314	Air Room
Y01-35	RE-2315	Air Lock - Containment Building
Y10-14	RE-2316	Fuel Handling Area, Containment Building
Y20-14	RE-2317	Fuel Handling Area, Containment Building
Y10-11	RE-2321	Elevation 674' - Containment Building
Y20-15	RE-2322	Elevation 674' - Containment Building
Y01-35	RE-5701	Decontamination Room
Y01-35	RE-5702	Evaporator A
Y01-35	RE-5703	Evaporator B
Y01-35	RE-5704	Evaporator Control Panel
Y01-35	RE-5705	Radwaste Decay Tanks
Y01-35	RE-5706	Controlled Lab Corridor
Y01-35	RE-5707	Radwaste Packaging Area East
Y01-35	RE-5708	Radwaste Packaging Area West
Y01-35	RE-5709	Spent Fuel Pool Area (North)
Y01-35	RE-5710	Penetration and Fan Room

10/22/96

	E.Safe grds.	Rm Serv Corridor	RW Control Area	2.4 kV Switch Gear	Control 'D' Lab Corr	Access Control Station	Pers Airlock Outside	Cont Purge Unit Rm North	RW Demin Rm Roof	Outside Ctrl Rm Corridor	Ctrl Rm Main Entrance	East Turb Op Floor	Old Lunch Room	Spent Fuel Pool Rm NFP	Spent Fuel Pool Rm SFP	
	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	
		2300	2301	2302	2303	2304	2305	2306	2307	2308	2309	2310	2311	2312	5709	2313
<b>TIME</b>																
08:00 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
08:15 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
08:30 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
08:45 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
09:00 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
09:15 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
09:30 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
09:45 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
10:00 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
10:15 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
10:30 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	0.4	0.2	.10	0.4	0.4	0.12	0.1
10:45 AM	7		0.8	0.8	1	0.9	0.2	.07	.11	1.0	0.3	.54	60	0.4	50	50
11:00 AM	7		0.8	0.8	1.5	0.9	0.2	.07	.11	1.0	0.5	.78	90	0.4	70	70
11:15 AM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	2.3	4.7	520	0.4	430	430
11:30 AM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	5.2	10.3	1100	0.4	930	930
11:45 AM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	4.9	9.7	1050	0.4	880	880
12:00 AM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	3.3	6.6	1000	0.4	600	600
12:15 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	2.7	5.3	750	0.4	480	480
12:30 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	2.2	4.4	600	0.4	400	400
12:45 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	1.8	3.5	520	0.4	320	320
01:00 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	1.6	3.1	460	0.4	275	275
01:15 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	1.4	2.7	400	0.4	245	245
01:30 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	1.3	2.7	310	0.4	245	245
01:45 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	1.1	2.2	220	0.4	200	200
02:00 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	0.9	1.8	180	0.4	160	160
02:15 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	0.7	1.4	150	0.4	130	130
02:30 PM	7		0.8	0.8	2	0.9	0.2	.07	.11	1.0	0.6	1.1	120	0.4	100	100

10/22/96	590' Air Room	Airlock Inside Cont	Cont Rad Mon	Cont Rad Mon	Cont Rad Mon	Cont Rad Mon
	mr/h	mr/h	R/h	R/h	R/h	R/h
	2314	2315	1805	1806	1807	1808
<b>TIME</b>						
08:00 AM	3.1	2.7	.021	.026	.178	.090
08:15 AM	3.1	2.7	.021	.026	.178	.090
08:30 AM	3.1	2.7	.021	.026	.178	.090
08:45 AM	3.1	2.7	.021	.026	.178	.090
09:00 AM	3.1	2.7	.021	.026	.178	.090
09:15 AM	3.1	2.7	.021	.026	.178	.090
09:30 AM	3.1	2.7	.021	.026	.178	.090
09:45 AM	3.1	2.7	.021	.026	.178	.090
10:00 AM	3.1	2.7	.021	.026	.178	.090
10:15 AM	3.1	2.7	.021	.026	.178	.090
10:30 AM	3.1	2.7	.021	.026	.178	.090
10:45 AM	7	2.7	.698	.698	6.08	3.02
11:00 AM	10	2.7	.798	.798	7.08	3.52
11:15 AM	12	2.7	.898	.898	8.08	4.02
11:30 AM	14	2.7	.998	.998	9.08	4.52
11:45 AM	15	2.7	1.10	1.10	10.1	5.02
12:00 PM	14	2.7	1.10	1.10	10.1	5.02
12:15 PM	13	2.7	.998	.998	9.08	4.52
12:30 PM	12	2.7	.898	.898	8.08	4.02
12:45 PM	11	2.7	.798	.798	7.08	3.52
01:00 PM	10	2.7	.698	.698	6.08	3.02
01:15 PM	10	2.7	.698	.698	6.08	3.02
01:30 PM	9	2.7	.698	.698	6.08	3.02
01:45 PM	9	2.7	.698	.698	6.08	3.02
02:00 PM	8	2.7	.698	.698	6.08	3.02
02:15 PM	8	2.7	.698	.698	6.08	3.02
02:30 PM	8	2.7	.698	.698		

10/22/96	Decan Rm	"A" Evap.	"B" Evap.	Evap Control Panel	RW Decay Tanks	'D' Lab Corr	RW Packaging Area No	RW Packaging Area West	Spent Fuel Pool Criticality	Exhaust Fan Duct	RW Addition Vent	Fuel Handling Rm Vent	
		mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	mr/h	
TIME													
08:00 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
08:15 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
08:30 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
08:45 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
09:00 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
09:15 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
09:30 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
09:45 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
10:00 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
10:15 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
10:30 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	0.1	.1	15	75	
10:45 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	50	.1	10,000	10,000	
11:00 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	70	.1	15,000	15,000	
11:15 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	430	.1	OSH	OSH	
11:30 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	930	.1	OSH	OSH	
11:45 AM	0.3	0.35	10	.13	0.2	0.9	.25	.01	880	.1	OSH	OSH	
12:00 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	600	.1	OSH	OSH	
12:15 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	480	.1	OSH	OSH	
12:30 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	400	.1	OSH	OSH	
12:45 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	320	.1	OSH	OSH	
01:00 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	275	.1	OSH	OSH	
01:15 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	245	.1	OSH	OSH	
01:30 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	245	.1	OSH	OSH	
01:45 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	200	.1	OSH	OSH	
02:00 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	160	.1	OSH	OSH	
02:15 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	130	.1	OSH	OSH	
02:30 PM	0.3	0.35	10	.13	0.2	0.9	.25	.01	100	.1	OSH	OSH	

10/22/96	Service Water Discharge	Steam Generator Blowdown	Component Cooling Water	Circ Water Discharge	Liquid RW Monitor	Turbine Bldg Sump
	cpm	cpm	cpm	cpm	cpm	cpm
	0833	0707	0915	1323	1049	5211
<b>TIME</b>						
08:00 AM	380	1300	130	280	454	150
08:15 AM	380	1300	130	280	454	150
08:30 AM	380	1300	130	280	454	150
08:45 AM	380	2.28E04	130	280	454	1200
09:00 AM	380	2.55E04	130	280	454	1300
09:15 AM	380	Fail (OSH)	130	280	454	1800
09:30 AM	380	Fail (OSH)	130	280	454	1800
09:45 AM	380	Fail (OSH)	130	280	454	1800
10:00 AM	380	Fail (OSH)	130	280	454	1800
10:15 AM	380	Fail (OSH)	130	280	454	1800
10:30 AM	380	Fail (OSH)	130	280	454	1800
10:45 AM	380	Fail (OSH)	OSH	280	454	1800
11:00 AM	380	Fail (OSH)	OSH	280	454	1800
11:15 AM	380	Fail (OSH)	OSH	280	454	1800
11:30 AM	380	Fail (OSH)	OSH	280	454	1800
11:45 AM	380	Fail (OSH)	OSH	280	454	1800
12:00 PM	380	Fail (OSH)	OSH	280	454	1800
12:15 PM	380	Fail (OSH)	OSH	280	454	1800
12:30 PM	380	Fail (OSH)	OSH	280	454	1800
12:45 PM	380	Fail (OSH)	OSH	280	454	1800
01:00 PM	380	Fail (OSH)	OSH	280	454	1800
01:15 PM	380	Fail (OSH)	OSH	280	454	1800
01:30 PM	380	Fail (OSH)	OSH	280	454	1800
01:45 PM	380	Fail (OSH)	OSH	280	454	1800
02:00 PM	380	Fail (OSH)	OSH	280	454	1800
02:15 PM	380	Fail (OSH)	OSH	280	454	1800
02:30 PM	380	Fail (OSH)	OSH	280	454	1800

10/22/96	Stack Gas Gross Activity	Stack Gas Single Isotope	RW Vent	East Safeguards Vent	West Safeguards Vent	Cont Bldg Gas Monitor	Waste Gas Monitor	Condenser Offgas	Blowdown Tank Vent Monitor
	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm
	2318	2319	1809		1810	1811	1817	1113	0631
<b>TIME</b>									
08:00 AM	OOS	OOS	38	220	220	3900	<100	2.5E01	400
08:15 AM	OOS	OOS	38	220	220	3900	<100	2.5E01	400
08:30 AM	OOS	OOS	38	220	220	3900	<100	2.5E01	400
08:45 AM	OOS	OOS	38	220	220	3900	<100	2.30E06	400
09:00 AM	OOS	OOS	38	220	220	3900	<100	5.95E06	400
09:15 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
09:30 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
09:45 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
10:00 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
10:15 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
10:30 AM	OOS	OOS	38	220	220	3900	<100	2.5E03	400
10:45 AM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
11:00 AM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
11:15 AM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
11:30 AM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
11:45 AM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
12:00 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
12:15 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
12:30 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
12:45 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
01:00 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
01:15 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
01:30 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
01:45 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
02:00 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
02:15 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400
02:30 PM	OOS	OOS	38	220	220	3900	<100	EEEEEEEEE	400

10/22/96	Iodine/Part Gas Eff	Normal Noble Gas Eff	High Range Noble Gas	Main Steam Gamma B	Main Steam Gamma A	Cont High Range	Cont High Range	Failed Fuel Monitor	High Range Effluent Monitor
	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm
	2325	2326	2327	2323	2324	2321	2322	0202	(Rad Gun)
<b>TIME</b>									
08:00 AM	OOS	6.07E01	1.10E-01	20	40	1.55E-02	1.45E-02	2.47E04	BKG
08:15 AM	OOS	6.12E01	1.10E-01	20	40	1.55E-02	1.45E-02	2.47E04	BKG
08:30 AM	OOS	6.17E01	1.10E-01	20	40	1.55E-02	1.45E-02	2.47E04	BKG
08:45 AM	OOS	6.21E01	1.10E-01	400-48	40	1.55E-02	1.45E-02	2.38E04	BKG
09:00 AM	OOS	6.38E01	1.10E-01	48	40	1.55E-02	1.45E-02	1.17E04	BKG
09:15 AM	OOS	6.24E01	1.10E-01	48	40	1.54E-02	1.45E-02	2.46E04	BKG
09:30 AM	OOS	6.16E01	1.10E-01	48	40	1.54E-02	1.45E-02	2.45E04	BKG
09:45 AM	OOS	6.24E01	1.10E-01	47	40	1.54E-02	1.45E-02	2.44E04	BKG
10:00 AM	OOS	6.06E01	1.10E-01	47	40	1.54E-02	1.45E-02	1.36E04	BKG
10:15 AM	OOS	6.17E01	1.10E-01	47	40	1.54E-02	1.45E-02	2.42E04	BKG
10:30 AM	OOS	6.05E01	1.10E-01	47	40	1.54E-02	1.45E-02	2.41E04	BKG
10:45 AM	OOS	6.05E01	1.10E-01	7550	50	1.54E-02	1.46E-02	1.00E05	5
11:00 AM	OOS	6.09E01	1.10E-01	9050	140	1.54E-02	1.46E-02	9.00E05	7
11:15 AM	OOS	6.10E01	1.10E-01	12000	165	1.54E-02	1.46E-02	OSH	9
11:30 AM	OOS	6.10E01	1.10E-01	15000	190	1.54E-02	1.46E-02	OSH	10
11:45 AM	OOS	6.12E01	1.10E-01	13000	140	1.54E-02	1.46E-02	OSH	10
12:00 PM	OOS	6.31E01	1.10E-01	12000	130	1.54E-02	1.46E-02	OSH	9
12:15 PM	OOS	6.39E01	1.10E-01	11000	130	1.54E-02	1.46E-02	OSH	8.5
12:30 PM	OOS	6.39E01	1.10E-01	10000	130	1.54E-02	1.46E-02	OSH	8
12:45 PM	OOS	6.15E01	1.10E-01	9000	130	1.54E-02	1.46E-02	OSH	7.5
01:00 PM	OOS	6.25E01	1.10E-01	8500	130	1.54E-02	1.46E-02	OSH	7
01:15 PM	OOS	6.35E01	1.10E-01	8000	130	1.54E-02	1.46E-02	OSH	6.5
01:30 PM	OOS	6.29E01	1.10E-01	7500	130	1.54E-02	1.46E-02	OSH	6
01:45 PM	OOS	6.32E01	1.10E-01	7000	130	1.54E-02	1.46E-02	OSH	5.5
02:00 PM	OOS	6.10E01	1.10E-01	6500	130	1.54E-02	1.46E-02	OSH	5
02:15 PM	OOS	6.08E01	1.10E-01	6000	130	1.54E-02	1.46E-02	OSH	4.5
02:30 PM	OOS	6.04E01	1.10E-01	5500	130	1.54E-02	1.46E-02	OSH	4

**CONVERSIONS**

**IODINE CONVERSION  
WHEN IN PLUME =  
GAMMA RDG X 1.5E-08**

**SERVICE BLDG=  
REDUCE GAMMA BY 10  
EACH FLOOR.**

**SHIELDS  
BLOCK WALL REDUCE  
BY 10**


**1 FT CONCRETE  
REDUCE BY 10  
2 FT CONCRETE  
REDUCE BY 100**

**NO CONTAMINATION  
UNLESS IN PLUME**

**WHEN IN PLUME  
ESTIMATE A  
CONTAMINATION  
VALUE**

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

**FIGURE 2.2**  
**PALISADES PLANT FACILITIES**




0800 - 1030

0800 - 1030  
1030


PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES NUCLEAR PLANT SITE

FIGURE 2-3



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

FIGURE 2-2  
PALISADES PLANT FACILITIES




LAKE MICHIGAN

SHQ1

LC1

PALISADES NUCLEAR PLANT  
SITE  
EMERGENCY  
PLAN


FIGURE 2-3  
PALISADES  
NUCLEAR  
PLANT SITE



110

1100


# LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES PLANT FACILITIES  
FIGURE 2-2

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN


FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE



1100  
'00

1115

LAKE MICHIGAN




PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES

15

1115


**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**

**FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE**



1130

LAKE MICHIGAN




PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES

1130  
1130

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE




LAKE MICHIGAN

1145


PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES PLANT FACILITIES

FIGURE 2-2




**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**

**FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE**



200  
1200


# LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES PLANT FACILITIES  
FIGURE 2-2

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN


FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE



# LAKE MICHIGAN

15

1215




PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

15  
1215

PALISADES NUCLEAR PLANT SITE  
EMERGENCY PLAN


FIGURE 2-3

1



12  
10230

# LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

FIGURE 2-2  
PALISADES PLANT FACILITIES

230


1230

**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**

**FIGURE 2-3**

**PALISADES NUCLEAR PLANT SITE**


SECTION 2  
Revision 3  
Page 1 of 1



1245

1245

LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES PLANT FACILITIES


FIGURE 2-2

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE


SECTION 2  
Revision 3  
Page 1 of 1

124  
1245



130  
1300

LAKE MICHIGAN




PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES

R  
1300

PALISADES NUCLEAR PLANT  
SITE  
EMERGENCY PLAN


FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE



13

1315

LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES


**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**

SECTION 2  
Revision 3  
Page 1 of 1

**FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE**

1315


51



133

1330

LAKE MICHIGAN



PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
FIGURE 2-2  
PALISADES PLANT FACILITIES

1345

# LAKE MICHIGAN





FIGURE 2-2  
PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN  
PALISADES PLANT FACILITIES

142/46  
1345  
1345

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

SECTION 2  
Revision 3  
Page 1 of 1


FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE



1.0  
—  
1400

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN


PALISADES NUCLEAR PLANT SITE



**SECTION 2**  
**Revision 3**  
**Page 1 of 1**

PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN

FIGURE 2.2  
PALISADES PLANT FACILITIES




LAKE MICHIGAN

1400

**PALISADES NUCLEAR PLANT  
SITE EMERGENCY PLAN**

**FIGURE 2-3  
PALISADES NUCLEAR PLANT SITE**



**CONVERSIONS**

**IODINE CONVERSION  
WHEN IN PLUME =  
GAMMA RDG X 1.5E-08**

**SERVICE BLDG=  
REDUCE GAMMA BY 10.  
EACH FLOOR.**

**SHIELDS  
BLOCK WALL REDUCE  
BY 10**

**1 FT CONCRETE  
REDUCE BY 10  
2 FT CONCRETE  
REDUCE BY 100**

**NO CONTAMINATION  
UNLESS IN PLUME**

**WHEN IN PLUME  
ESTIMATE A  
CONTAMINATION  
VALUE**

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr BKG (<0.5)

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Contact mRem/hr BKG (<0.5)

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr BKG (<0.5)

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A:

Contact mRem/hr BKG (<0.5)

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr <0.5 mrem

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

NONE

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/21/96  
0845

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr BK6

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G) Contact mRem/hr /

b. South Steam Line (from 'A' S/G) Contact mRem/hr < 0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 4

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.8 mRem

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

NNE

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/22/96  
0900

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.6

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G) Contact mRem/hr 1.5

b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 5

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 1.0

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

None

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/22/96  
0915

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5

b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes  
from the Turbine Building:

None

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/22/86  
0930

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5

b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

None

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/22/96  
0945

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5  
b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

None

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

10/22/96  
1000

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5
- b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

Noce

---

---

---

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

## STEAM GENERATOR TUBE RUPTURE PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5  
b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

Nope

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

mRem/hr 0.7

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G) Contact mRem/hr 0.5

b. South Steam Line (from 'A' S/G) Contact mRem/hr <0.5

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A: Contact mRem/hr 3

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line: Contact mRem/hr 0.5


LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)




Get steam line  
and flash tank  
off EDP Survey page

FOR TURNING OUT THE BEST FLAT

1. C22 AND C26 PANELS ARE SEISMICALLY ANCHORED PER SFC 8B-864 AND 865
  2. MCC1 AND MCC8 ARE SEISMICALLY ANCHORED PER SFC 8B-866 AND 867
  3. TRANSFORMERS K15 AND X16 ALONG WITH THEIR ADJACENT LOAD CENTERS ARE SEISMICALLY ANCHORED PER SFC 8B-862 AND 863

590'


19	2-18	REMOVED BY OWNER FOR PCT 94%	100
44		AMM. DEL. 31-462	100
100	100	100	100
CONSUMERS POWER COMPANY			
DETROIT, MICHIGAN			
CITY OF DETROIT			
EQUIPMENT LOCATION - AUX. BLDG.			
RADIASTIC MUD LOCATIONS			
PLAN OF EL. 548-8'			
DETROIT, MICHIGAN			
M 2			



607'

19	8	11	14
20	9	12	15
21	10	13	16
22	11	14	17


CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION-AUXILIARY AND  
REACTOR BLDG. RADWASTE MODIFICATION  
PLAN OF EL. 607-61  
M-3



0800-1030

625'

19	8/30	RENEWAL ON CAD PER DEC 9-28-1928	JUN 1951
REC'D	1951	EXPIRED	
CONSUMERS POWER COMPANY DETROIT, MICHIGAN			
EQUIP. LOC. - REACTOR & AUTO. BLDG. RADWASTE MODIFICATIONS PLANT FEE \$255.00			
RENEWAL PER M-4			
18			



0800-1030

NOTE:  
FORMERLY DWG. M-605 REV. 10

1-20 46	MOVE 100 LB LEFT RIDGE & ACROSS 100' ROAD RESIST 100 LB CRASH TESTS L-100 & L-100 PER FC-144 & DCR-10-1422	
14	RETAINED IN PLACE PLR FC-144 & DCR-10-1371	
15		
16		
<b>CONSUMERS POWER COMPANY</b> The People's Power Company DETROIT, MICHIGAN 48226		
EQUIP. LOC. - AUX. BLDG. RADIACTIVE MODIFICATIONS PLAN UP EL. 645'-0"		
M-5		

10/22/96  
1045

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

*Steamin S*  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr \*

b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*Shine from jail house*  
Contact mRem/hr

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*


*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*


*Use room reading ÷ 10 in plume*

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)







THIS DRAWING WAS FORMERLY  
M 603 REV. 12

607'

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION AUTHORITY AND  
REACTOR BLDG. HIGHWASTE PHOTOCOPY  
PLAN NO. 11-607-07  
M 3





1045

NOTE:

649'

CONSUMERS' POWER COMPANY

LINIP, LTD.: AUX. BLDG.  
HAWAII WASTE MITIGATION  
PLAN OF E1.644-01

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

*Steamin's*  
mRem/hr X

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr X

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr X

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A:

*Shine from jail house*  
Contact mRem/hr —

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 5.5

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*

*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*

*Use room reading ÷ 10 in plume*

6. X  
Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)


590

steam field  
containment around  
jail windows & egypt

radiation high  
around jail windows



0011



When sampled  
Bkg to 50 mrem/hr

Bkg to 1 R/hr

SECTION L-L

1100


90 mrem  
steam filled  
high temp

Turbine Bldg  
radiation around  
jail window -  
Contamination on  
east turbine bldg

607'

THIS DRAWING WAS FURNISHED BY  
M-603 REV.12


CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION AUXILIARY AND  
HELIUM BLDG. HIGHBAY MANUFACTURING  
PLANT IN EL DORADO  
KANSAS



Plume -  
influence east  
turbine blk which  
is unshielded

625'

FORMERLY DWG M-604 REV 16



14	PROPOSED UP RATE & ADDITIONAL AMOUNT FOR LARGEST B.L. PLANT IN THE STATE
15	INTERIOR PLATE PER TEN CENTS DOLLARS
16	CONSUMERS POWER COMPANY PRESERVE AND MAINTAIN COMMITMENT
17	EUCLIP LOC. BLDG. HAZARDOUS MODIFICATIONS PLAN OF EL. 649-87

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*shine from jail house*  
Contact mRem/hr

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 5.1

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*

*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*


*Use room reading ÷ 10 in plume*

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

1115



607

East turbine bldg  
Containment on  
Radiation around  
Turbine Bldg


High temp  
steam flow


CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION PLAN  
THIS DRAWING WAS DRAWN BY  
THE ENGINEER IN CHARGE OF PLANT AND  
MAINTENANCE

M 603 REV 12  
THIS DRAWING WAS DRAWN BY  
THE ENGINEER IN CHARGE OF PLANT AND  
MAINTENANCE

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION PLAN  
THIS DRAWING WAS DRAWN BY  
THE ENGINEER IN CHARGE OF PLANT AND  
MAINTENANCE

Bkg to 1E/hr  
Bkg to 50mrem/hr  
when sampled  
(N)






5000 STEAM POWER  
WATER SPRAY  
COPPER

Plume -  
influence east  
turbine bldg which  
is unshielded

625'



*plume by fuel Pool*

NOTE:

649'

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

*Steamings*  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

*Shine from jail house*

3. Flash Tank T-29A:

Contact mRem/hr

*use room reading*

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 50

LOCATION: Above Condensate Pump Pit,

590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*


*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*


*Use room reading ÷ 10 in plume*

6. Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)






THIS DRAWING WAS FORMERLY  
M 603 REV. 12

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION-ALL TURBINE AND  
REACTOR BLDG. HIGHWASTE MINILOCATION  
PLATE IN EL 607-67  
M 3



Plume -  
influence east  
turbine blk which  
is unshielded

625'



CONSUMERS POWER COMPANY  
PONTIAC NUCLEAR PLANT  
EQUIP. LOC. & AQU. BLDG.  
RADWASTE MODIFICATIONS  
PLAN OF EL. 649'-0"

P) 22/96  
145

Proc No EOP Supplement  
Supplement 14.  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

Steamin S  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Steam plume  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating

3. Flash Tank T-29A:

Shine from jail house  
Contact mRem/hr

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 45

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:


Steam cloud coming out of jailhouse window.  
Vision poor. Steam being drawn out by roof  
exhauster up stair well and other penetrations.

6. \* Use room reading ÷ 10 in plume  
Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

1145




radiation high  
around jail window

FOR TURNING STUDENTS INTO PROFESSIONALS


- steam filled  
contamination around  
jail window & equip

590'



THIS DRAWING WAS FORMERLY  
M 603 REV. 12


CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION SHEET AND  
REACTOR BLDG. HIGH-LEVEL PRODUCTION  
PLANT ID: L-607-6



Plume -  
influence east  
turbine bldg which  
is unshielded

625'

**CONSUMERS POWER COMPANY**  
EQUIP. LOC. - REACTOR B & AUX. BLDG.  
RADWASTE MODIFICATIONS  
PLAN OF E1-623 B



14	PLANT HEAD LINE, RAIL & READING PER FC-1418 & G-1412
15	REFINED IN PLACE PER FC-1418 & G-1412
16	CONSUMERS POWER COMPANY
17	ELIMINATE ALL RADIOACTIVE MODIFICATIONS PLAN OF EL. 640'-0"

1200  
12/26

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

Steamings  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Steam plume  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

shine from jail house

3. Flash Tank T-29A:

Contact mRem/hr \*

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

use room reading

4. Off gas line:

Contact mRem/hr 4.0

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:


Steam cloud coming out of jailhouse window.

Vision poor. Steam being drawn out by roof  
exhaustor up stair well and other penetrations.


6. X Use room reading ÷ 10 in plume  
Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)




1200  
REMOVED FROM DRAWING PER FC 916  
DWG T-B-12 REV 1  
CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION - AREA BLD.  
RADIAL ELEVATION LOCATIONS  
PLAN IN EL. 210' 0"  
DWG 590'  
M 2



CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION ASSEMBLY AND  
REACTOR BLDG. WASTEWATER TREATMENT  
PLANT IN EL. 607-2





ACROSS MATCH TO EL 330° F  
- plume by fuel Pool  
EL. 625' OF NOTE:

(e49')

1-19	PROPS HEDO LIPSTICK & MELI TIN PC-945-A & DOL 95-1222
14	REFINER IN PLACE FOR PC-945 & (A-95-137)
	<i>REMOVED</i>
	<i>REMOVED</i>
	<i>REMOVED</i>
	<b>CONSUMERS POWER COMPANY</b>
	<i>REMOVED</i>
	<i>REMOVED</i>
	<i>REMOVED</i>
	<b>CEMIP LOC - AURE BLOCK</b>
	<b>RADIATION MONITORIZATIONS</b>
	<b>PLAN BY E.I. 644-18</b>
	<i>REMOVED</i>

10/22/96  
1215

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

## STEAM GENERATOR TUBE RUPTURE PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

Steaming  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Steam plume  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

Shine from jail house  
Contact mRem/hr

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 3.8

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

Steam cloud coming out of jailhouse window.

Vision poor. Steam being drawn out by roof  
exhaustor up stair well and other penetrations.

6. X Use room reading  $\div 10$  in plume  
Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)

,065

steam filled confinement around jail windows and equate


around jail windows






THIS DRAWING WAS FURNISHED  
M-603 REV. 12

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION ALPHABETIC AND  
REACTOR BLDG. HIGH-LEVEL IRRADIATION  
PLATE FOR L-1 BLDG B'



Plume -  
influence east  
turbine bldg which  
is unshielded



plume by fuel Pool  
EL. 625' ACCESS HATCH TO EL 330' D'

NOTE:

649'

10/22/96  
1230

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

## STEAM GENERATOR TUBE RUPTURE PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

*Steaming*  
mRem/hr X

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr X

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr X

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*Shine from jail house*

Contact mRem/hr  

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 3.6

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:


*Steam cloud coming out of jailhouse window.*


*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*

6. *X* Use room reading  $\div 10$  in plume  
Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)





THIS DRAWING WAS FURNISHED BY  
M-ED3 REV.12

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION ASSEMBLY AND  
MANUFACTURER BLDG. RADWASTE MODIFICATION  
PLAN FOR EL 607-6



Plume -  
influence east  
turbine bldg which  
is unshielded

625'



10/22/96  
1245

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

Steamin S  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Steam plume  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

shine from jail house  
Contact mRem/hr

3. Flash Tank T-29A:

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

use room reading

4. Off gas line:

Contact mRem/hr 3.4

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

Steam cloud coming out of jailhouse window.

Vision poor. Steam being drawn out by roof  
exhaustor up stair well and other penetrations.

6. X Use room reading  $\div 10$  in plume  
Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)


steam filled containment around joint windowed equipment

around 1.1 windups

,065

۱۴۵






Turbine Bldg  
radiation around  
jail window -  
Contamination on  
east turbine bldg

- steam filled  
high temp


607'



Plume -  
influence east  
turbine bldg which  
is unshielded

625'

16	8-38	RELIANCE IND CHI PHE DUE 12-1974
45	44	RELIANCE IND CHI PHE DUE 12-1974
		RELIANCE IND CHI PHE DUE 12-1974
CONSUMERS POWER COMPANY DETROIT, MICHIGAN PLANT DETROIT, MICHIGAN		
EQUIP. LOC.: - REACTOR & AUX. BLDG. RAO-HASTIC MODIFICATIONS PL. 14N ON E. 629 S. DETROIT, MICHIGAN 48226 M 4		



ACCESS HATCH TO EL 330' D<sup>2</sup>  
- plume by fuel Pool  
NOTE: 1000' NNE of Point M-622 A

NOTE:  
HOMESTEAD DRG. M.G.O.S. RIV. 0

1-17	POLE 1000' LIFTED & SET IN GROUND ACROSS FROM TOWER 1000' E. PER - FC-1000-D-A-10-122
1-18	METHOD IN PLANE PER FC-1000-D-A-10-137
1-19	REMARKS
CONSUMERS POWER COMPANY PARIS, MICHIGAN 49070	
EQUIP. LOC. #1000 BLDG. RAWWASTE MODIFICATIONS PLAN OF USE EL. 649-8	
DRAFTS BY: [Signature]	

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter: *Steamin S*  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr \*

b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*Shine from jail house*  
Contact mRem/hr

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 3.2

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*

*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*

*Use room reading ÷ 10 in plume*

6. Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)


590


steam filled  
contamination around  
jail windowed equip

radiation high  
around jail window



N






Plume -  
influence east  
turbine bldg which  
is unshielded

625'

FORMERLY DNG M-604 REV 16



ACCESS HATCH TO EL 330' D<sup>2</sup>  
-plume by fuel Pool  
EL. 665' D<sup>2</sup> NOTE:

NOTE :  
MONTHLY DRG. NO 605 REV D

649'

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

*Steaming*  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

*Shine from jail house*  
Contact mRem/hr

3. Flash Tank T-29A:

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 3.0

LOCATION: Above Condensate Pump Pit,

590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:


*Steam cloud coming out of jailhouse window.*


*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*

6. *\* Use room reading ÷ 10 in plume*  
Return survey to Shift Supervisor.

Completed By: \_\_\_\_\_


Reviewed By: \_\_\_\_\_ (SS)






THIS DRAWING WAS FORMERLY  
M-603 REV. 12

CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION ALTERNATIVE AND  
REACTOR BLDG. HIGHWASTE MODIFICATION  
PLAN OF M-607-12  
M-3



Plume -  
influence east  
turbine bldg which  
is unshielded

625'



*- plume by fuel Pool*

NOTE :  
FORMERLY DRG. M GOS REV 10

10491

14	<p>1.10 PULL OUT PLATE FOR REPAIR REJIN &amp; JIM FRAMES L &amp; C PER FC-545 &amp; DLR 95-1242</p> <p>1.11 MELTING IN PLACE PER FC-545 &amp; DLR 95-1242</p>
	<b>CONSUMERS POWER COMPANY</b>
	DETROIT, MICHIGAN 48226
	EDITION 10 - APR 82 RADIAL TIRE IDENTIFICATION PLAN OF USE 644-B
	PRINT NAME

1330  
10/22/96

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

*Steamings*  
mRem/hr

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*Shine from jail house*  
Contact mRem/hr \_\_\_\_\_

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 2.8

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:


Steam cloud coming out of jailhouse window.

Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.

6.  Use room reading ÷ 10 in plume  
Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)



N

P



Turbine Bldg  
radiation around  
jail window -  
Contamination on  
east turbine bldg


THIS DRAWING WAS FORMERLY  
M 203 REV. 12


607'  
CONSUMERS POWER COMPANY  
EQUIPMENT LOCATION SURVEY AND  
REACTOR BLDG. WASTE MULTIFICATION  
PLANT IN EL 607' E'

OEEL

—Plume — influence east  
turbine blade which is washed off

١٤٩





ACCESS HATCH TO EL 330' DT  
- plume by fuel Pool  
NOTE: 1000 ft. below M-21

NOTE :  
POMERELLY DWG. NO 625 REV A

1049'

14	PERMIT NUMBER: 100-100-0000 PERIOD OF EXPIRATION: DEA 03-2022 PERIOD OF EXPIRATION: MAR 03-2022 PERIOD OF EXPIRATION: MAR 03-2022 PERIOD OF EXPIRATION: MAR 03-2022
	EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022
	EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022
	EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022 EXPIRATION DATE: MAR 03-2022

**CONSUMERS POWER COMPANY**  
Michigan's electric utility  
Consumers Power

EXPIRATION DATE: MAR 03-2022  
WASTEWATER MODIFICATIONS  
PLAN OF EL 644-B  
DRAFT NO. 1

1345  
12/96

Proc No EOP Supplement  
Supplement 14  
Revision 0  
Page 1 of 1

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above Blowdown Filter:

*Steaming*  
mRem/hr X

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

*Steam plume*  
Contact mRem/hr X

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr X

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

*Shine from jail house*  
Contact mRem/hr \_\_\_\_\_

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 2.6

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

*Steam cloud coming out of jailhouse window.*

*Vision poor. Steam being drawn out by roof exhauster up stair well and other penetrations.*

*Use room reading ÷ 10 in plume*

6. Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)


590


steam filled  
jail windowed around  
contamination area

radiation high  
around jail window



1345





Plume -  
influence east  
turbine bldg which  
is unshielded

625'



1400  
10/22/85

STEAM GENERATOR TUBE RUPTURE  
PRELIMINARY AREA SURVEY

NOTE: Extendable probe type instrument should be used for surveys.

1. Blowdown Filter F-14 contact reading at floor grating above  
Blowdown Filter:

Steamin g  
mRem/hr \*

LOCATION: 625' Turbine Building about 25' NE Of Main Turbine Pedestal

2. Main Steam Lines above Turbine Building East Mezzanine:

- a. North Steam Line (from 'B' S/G)

Steam plume  
Contact mRem/hr \*

- b. South Steam Line (from 'A' S/G)

Contact mRem/hr \*

LOCATION: By Instrument Air Dryer about 9' above floor grating,

3. Flash Tank T-29A:

Shine from jail house  
Contact mRem/hr \*

LOCATION: 590' Turbine Building, Northeast next to stairs by "jail house" doors.

4. Off gas line:

Contact mRem/hr 2.4

LOCATION: Above Condensate Pump Pit,  
590' Turbine Building

5. Indicate the direction of travel and location of any steam plumes from the Turbine Building:

Steam cloud coming out of jailhouse window.

Vision poor. Steam being drawn out by roof exhaust up stair well and other penetrations.

Use room reading ÷ 10 in plume

6. Return survey to Shift Supervisor.


Completed By: \_\_\_\_\_

Reviewed By: \_\_\_\_\_ (SS)

590

steam filled  
containment around  
jail windowed egypt

radiation high  
around jail window



1400

N

, LQ9

steam filled high temp

Turbine Bldg  
radiation around  
you! windrow -  
Containination on  
east turbine bldg


CONSUMERS HOME COMPANY	
NAME	ADDRESS
Mr.	Mr.


THIS DOCUMENT WAS FORMERLY  
N 603 REV. 12

۱۴۱

1-1 NOV 12 1975

Bkg to 1/e/hr  
Bkg to 50mrem/hr  
when sampled (N)






Plume -  
influence east  
turbine bldg which  
is unshielded

625'

**CONSUMERS POWER COMPANY**  
DETROIT, MICHIGAN  
**EQUIP. LOC. - REACTOR B AUX. BLDG.**  
**RAO-HSTE MODIFICATIONS**  
**PLAN OF ET 629 (B)**  
**RELS. MARCH 1964**



- plume by fuel Pool  
EL. 6810' ACCESS HATCH TO EL 3300' F

NOTE:

14	1-10	PROTEC 1000 LDP 1000 & AUA 1000 PLATE PC-544-8 DLA 90-1122
	1-11	PROTEC 1000 LDP 1000 & AUA 1000 PLATE PC-544-8 DLA 90-1122
		REMARKS
CONSUMERS POWER COMPANY		
DETROIT, MICHIGAN 48226		
EQUIP. LOC.: AUA 1000 MAGNETIC MODIFICATIONS PLAN OF EL. 644-B		
REV. NO. 1		

## LEGEND AND CONTROLLERS NOTES


### EXAMPLE

6-120-6 MREM\H

\* I2 42K OCPM b

\* I2 370K OCPM f

MREM\H ARE CLOSED WINDOW BETA\GAMMA READING AT THE EDGE,  
CENTERLINE AND EDGE OF THE PLUME. WIDTH OF PLUME IS 0.1 X  
DISTANCE FROM PLANT ON EACH SIDE OF CENTERLINE.  
FOR OPEN WINDOWS USE CLOSED WINDOW + 10% IN THE PLUME.



I2 42K OCPM b IS THE OBSERVED NET CPM FOR A 5 CFM AIR SAMPLE AT  
CENTERLINE OF PLUME ON THE BACK OF THE FILTER CARTRIDGE.  
BACKGROUND WILL NEED TO BE ADDED. USE 0-8 HOUR DEFAULT VALUES FOR  
EFFICIENCIES INSTEAD OF THE TABLE.

I2 360K OCPM f IS THE OBSERVED NET CPM FOR SAME SAMPLE ON THE  
FRONT OF THE CARTRIDGE.


THE BACK OF FILTER CARTRIDGE IS THE PREFERRED METHOD.


Divide I<sub>2</sub> readings by 2


0815 →


$10^{30}$


All BKG















1145










1230










1315



1330







## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

0800

> LIQUID  
DISCHARGE  
RADIATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 3.0 deg C

WIND SPEED 13 mph

DIRECTION 227 degrees

STACK GAS RADIATION

VV cpm  
VV cpm

UNIT GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

.10 mrem/hr

CFMS

ENVIRON  
MENTA

METEOROLOGICAL

RADIOLOGICAL

F1

F2


F3

F4

F5

OK

000



## ENVIRONMENTAL OVERVIEW

PAL

10/22/90

0815

LIQUID  
DISCHARGE  
STATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOWER

TEMPERATURE 3.2 deg c

WIND SPEED 13 mph

DIRECTION 222 degrees

## STACK GAS RADIATION

✓ cpm  
✓ cpm

## UNIT GAS RADIATION

3900 cpm

## CONTROL ROOM RADIATION

10 mrem/hr

CFMS

ENVIRON  
MENU

METEOROLOGICAL

RADIOLOGICAL

F1

F2

F3

F4

F5



OK

# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

0830

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

10 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 3.5 deg C

WIND SPEED 18 mph

DIRECTION 229 degrees

STACK GAS RADIATION

V cpm  
V cpm

CHMT GAS RADIATION

3900 cpm

CFMS

F1 ENVIRON  
MENUF2 METEOR-  
LOGICALF3 RADIO-  
LOGICAL

F4

F5

F6

F7

F8

OK

000



# ENVIRONMENTAL OVERVIEW

10/22/86

0845

LIQUID  
DISCHARGE  
STATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 3.5 deg C

WIND SPEED 22 mph

DIRECTION 221 degrees

STACK GAS RADIATION

V cpm  
V cpm

CHIM GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

.10 mrem/hr

CFMS

F1 ENVIRON  
MENU

F2

F3 METEOR-  
LOGICAL

F4 RADIO-  
LOGICAL

F5

F6

F7

F8


F9

F10

F11

MMU

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/92

0900

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

.10 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 3.7 deg C

WIND SPEED 19 mph

DIRECTION 219 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHIM GAS RADIATION

3900 cpm

CFMS

F7 ENVIRON MENU

F8

F9 METEOROLOGICAL

F10 RADIOLOGICAL

F11

F12

F13

F14

F15

000

OK



## ENVIRONMENTAL OVERVIEW

PAE

10/22/96

0915

EQUID  
DISCHARGE  
STATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 4.0 deg C

WIND SPEED 15 mph

DIRECTION 225 degrees

STACK GAS RADIATION

V cpm  
Y cpm

CHIM GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

10 mrem/hr

CFMS

ENVIRON  
MEASMETEOR-  
LOGICALRADIO-  
LOGICAL

F11

F12


F13

F14

F15

OK

000



E S O

## ENVIRONMENTAL OVERVIEW

PAL

10/22/86

0930

LIQUID  
DISCHARGE  
RADIACTION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOWER

TEMPERATURE 45 deg C  
 WIND SPEED 13 mph  
 DIRECTION 230 degrees

## STACK GAS RADIATION

V cpm  
 V cpm

## UNIT GAS RADIATION

3900 cpm

## CONTROL ROOM RADIATION

.10 mrem/hr

CFMS

ENVIRON  
MENU

METEOROLOGICAL

RADIOLOGICAL

F1

F2

F3

F4

F5

OK

000



1/10/76  
0945

UID  
CHARGE  
STATION


454 cpm

KI RAD

KE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 4.6 deg C

WIND SPEED 15 mph

DIRECTION 224 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHMT GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

.10 mrem/hr

MS

ENVIRON  
MEN

METEOR

RADIO-

F1

F2

F3

F4

F5

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1000

LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

.10 rem/hr



METEOROLOGICAL TOWER

TEMPERATURE 4.9 deg C

WIND SPEED 12 mph

DIRECTION 219 degrees

STACK GAS RADIATION

V  
V  
cpm  
cpm

CHIM GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

METEOROLOGICAL

RADIOLOGICAL

F11

F12

F13

F14

F15  
1000

OK



# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1015

LIQUID  
DISCHARGE  
RADIACTION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 5.2 deg C

WIND SPEED 8 mph

DIRECTION 224 degrees

STACK GAS RADIATION

V cpm  
Y cpm

CHMT GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

.10 mrem/hr

CFMS

ENVIRON  
MENUMETEOR-  
LOGICALRADIO-  
LOGICAL

F11

F12


F13

F14

F15

OK

MMU



# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1030

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD

LAKE MICHIGAN




PLANT

CONTROL ROOM RADIATION

.10 mrem/hr

N



METEOROLOGICAL TOWER

TEMPERATURE 5.5 deg C

WIND SPEED 9 mph

DIRECTION 223 degrees

STACK GAS RADIATION

V

cpm

V

cpm

CHIMNEY GAS RADIATION

3900

cpm

CFMS

F1 ENVIRON  
MENU

F2 METEOROLOGICAL

F3 RADIOLOGICAL

F4

F5

F6

F7

F8

F9

F10

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1045

LIQUID  
DISCHARGE  
RADIATION

454


cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOREE

TEMPERATURE 6 deg c

WIND SPEED 7 mph

DIRECTION 221 degrees

## STACK GAS RADIATION

V cpm

V cpm

## CHUT GAS RADIATION

3900 cpm

## CONTROL ROOM RADIATION

.54 mrem/hr

CFMS

F7 ENVIRON  
MENUF8 METEOR-  
LOGICALF9 RADIO-  
LOGICAL

F10

F12

F13

F14

F15

OK



550

## ENVIRONMENTAL OVERVIEW

10/22/86

1100

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

.78 mrem/hr



## METEOROLOGICAL TOWER

TEMPERATURE 6.2 deg C

WIND SPEED 5 mph

DIRECTION 226 degrees

## STACK GAS RADIATION

V cpm  
V cpm

## CHIM GAS RADIATION

3900 cpm

CFMS

F1 ENVIRON  
MENU

F2

F3 METEOR-  
LOGICALF4 RADIO-  
LOGICAL

F5

F6

F7

F8

F9



OK

# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1115

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

4.7 mrem/hr



## METEOROLOGICAL TORE

TEMPERATURE 6.8 deg C  
WIND SPEED 4 mph  
DIRECTION 227 degrees

## STACK GAS RADIATION

✓ cpm  
✓ cpm

## CNMT GAS RADIATION

3900 cpm

CFMS

F7 ENVIRON  
MENU

F8

F9 METEORO-  
LOGICALF10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1130

LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

10.3 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 7.1 deg C

WIND SPEED 5 mph

DIRECTION 223 degrees

STACK GAS RADIATION

V cpm

Y cpm

CHNUIT GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

F1

METEOR-  
LOGICALRADIO-  
LOGICAL

F11

F12

F13

F14

F15

000

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/86

1145

LIQUID  
DISCHARGE  
PLATFOM


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOWER

TEMPERATURE 7.3 deg C

WIND SPEED 6 mph

DIRECTION 228 degrees

## STACK GAS RADIATION

✓ cpm  
✓ cpm

## CHIMNEY GAS RADIATION

3900 cpm

## CONTROL ROOM RADIATION

9.7 mrem/hr

CFMS

ENVIRON  
MENUMETEOR  
LOGICALRADIO  
LOGICAL

F11

F12

F13

F14

F15

OK

000



## ENVIRONMENTAL OVERVIEW

PAL

10/22/86

1200

LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

6.6 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 7.3 deg C

WIND SPEED 5 mph

DIRECTION 225 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHIMNEY GAS RADIATION

3900 cpm

CFMS

F7 ENVIRON  
MENU

F8 METEORO-

LOGICAL

F9

RADIO-

LOGICAL

F10

F11

F12

F13

F14

F15  
1000

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96  
12:15LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

5.3 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 7.5 deg C

WIND SPEED 3 mph

DIRECTION 229 degrees

STACK GAS RADIATION

✓  
✓

cpm  
cpm

CHIMNEY GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

METEOROLOGICAL

RADIOLOGICAL

F1

F2

F3

F4

F5

F6



OK

# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1230

LIQUID  
DISCHARGE  
RADIATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 8.2 deg C

WIND SPEED 5 mph

DIRECTION 225 degrees

STACK GAS RADIATION

V  
V  
cpm  
cpm

CHIM GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

4.4 mrem/hr

CFMS

F1 ENVIRON  
MENU

F2

F3 METEOROLOGICAL

F4 RADIOLOGICAL

F5

F6

F7

F8

F9

F10

OK



PAL

10/22/96

1245

LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

3.5 mrem/hr



## METEOROLOGICAL TOURE

TEMPERATURE 8.5 deg C

WIND SPEED 8 mph

DIRECTION 223 degrees

## STACK GAS RADIATION

V cpm  
Y cpm

## CNHGT GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

F1

F2 METEOR-  
LOGICALF3 RADIO-  
LOGICAL

F4

F5

F6

F7

F8

OK

1000



# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1300

LIQUID  
DISCHARGE  
RADIATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOWER

TEMPERATURE 8.7 deg C  
WIND SPEED 9 mph  
DIRECTION 219 degrees

## STACK GAS RADIATION

✓ cpm  
✓ cpm

## CHIM GAS RADIATION

3900 cpm

## CONTROL ROOM RADIATION

3.1 mrem/hr

CFMS

ENVIRON  
MENTMETEOR-  
LOGICALRADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

1000



# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1315

LIQUID  
DISCHARGE  
RADIATION


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 9.3 deg C

WIND SPEED 8 mph

DIRECTION 230 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHMT GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

2.7 mrem/hr

CFMS

ENVIRON  
MENUMETEOR-  
LOGICALRADIA-  
LOGICAL

F11

F12

F13

F14

F15

OK

WUW



# ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1330

LIQUID  
DISCHARGE  
RADIATION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

2.7 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 9.2 deg C

WIND SPEED 11 mph

DIRECTION 225 degrees

STACK GAS RADIATION

V cpm

V cpm

CHMT GAS RADIATION

3900 cpm

CFMS

F1 ENVIRON  
MENU

F2

F3 METEOR-  
LOGICALF4 RADIO-  
LOGICAL

F5

F6

F7

F8

F9

F10

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1345

LIQUID  
DISCHARGE  
RADIACTION

454 cpm

HI RAD


LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

2.2 mrem/hr



METEOROLOGICAL TOWER

TEMPERATURE 9.5 deg C

WIND SPEED 10 mph

DIRECTION 228 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHIM GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

F1

METEOR-  
LOGICALRADIO-  
LOGICAL

F11

F12


F13

F14

F15

MMU

OK



## ENVIRONMENTAL OVERVIEW

PAL

10/22/96

1400


LIQUID  
DISCHARGE  
RADIACTION

454

cpm

HI RAD

LAKE MICHIGAN



PLANT

CONTROL ROOM RADIATION

1.8 rem/hr

METEOROLOGICAL TOWER

TEMPERATURE 9.1 deg C

WIND SPEED 12 mph

DIRECTION 221 degrees

STACK GAS RADIATION

 cpm  
 cpm

CHIMNEY GAS RADIATION

3900 cpm

CFMS

ENVIRON  
MENU

F1

METEOROLOGICAL

RADIOLOGICAL

F2


F3

F4

F5

1000

OK



# ENVIRONMENTAL OVERVIEW

10/22/96

1445

Liquid  
Discharge  
Radiation


454 cpm

HI RAD

LAKE MICHIGAN



PLANT



METEOROLOGICAL TOWER

TEMPERATURE 8.9 deg C

WIND SPEED 13 mph

DIRECTION 223 degrees

STACK GAS RADIATION

✓ cpm  
✓ cpm

CHIMNEY GAS RADIATION

3900 cpm

CONTROL ROOM RADIATION

1.4 mrem/hr

CFMS

F1 ENVIRON  
MENT

F2 METEOROLOGICAL

F3 RADIOLOGICAL

F4

F5

F6

F7

F8

F9

OK



# ENVIRONMENTAL OVERVIEW

PAL

10/22/86

1430

LIQUID  
DISCHARGE  
RADIATION

454


cpm

HI RAD

LAKE MICHIGAN



PLANT



## METEOROLOGICAL TOWER

TEMPERATURE 8.0 deg C

WIND SPEED 7 mph

DIRECTION 226 degrees

## STACK GAS RADIATION

V

cpm

V

cpm

## CHUM GAS RADIATION

3900

cpm

## CONTROL ROOM RADIATION

1.1 mrem/hr

CFMS

F1 ENVIRON  
MENUF2 METEOR-  
LOGICALF3 RADIO-  
LOGICAL

F4

F5

F6


F7

F8

F9

MMU


OK



PAL

10/22/96

0800



HEIGHT 60 METERS

WIND DIRECTION	227	CIRCULAR DEGREES
STD DEVIATION	7.2	CIRCULAR DEGREES
WIND SPEED	17	MPH

DELTA TEMPERATURE	-0.4	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	227	CIRCULAR DEGREES
STD DEVIATION	7.2	CIRCULAR DEGREES
WIND SPEED	13	MPH
TEMPERATURE	3.0	DEG C




PAL

10/22/96

0815

HEIGHT 60 METERS



WIND DIRECTION	222	CIRCULAR DEGREES
STD DEVIATION	11.2	CIRCULAR DEGREES
WIND SPEED	17	MPH

DELTA TEMPERATURE	-0.9	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	222	CIRCULAR DEGREES
STD DEVIATION	11.2	CIRCULAR DEGREES
WIND SPEED	13	MPH
TEMPERATURE	3.2	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F2

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

000



351


## METEOROLOGICAL DATA

PAL

10/22/96

0830

HEIGHT 60 METERS



WIND DIRECTION	229	CIRCULAR DEGREES
STD DEVIATION	9.5	CIRCULAR DEGREES
WIND SPEED	23	MPH

DELTA TEMPERATURE	-1.1	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	229	CIRCULAR DEGREES
STD DEVIATION	9.5	CIRCULAR DEGREES
WIND SPEED	18	MPH
TEMPERATURE	3.5	DEG C

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9

F10 RADIO  
LOGICAL

F11

F12

F13

F14

F15

1010

JOB SENT TO PRINTER



## METEOROLOGICAL DATA

PAL

10/22/96

0845


HEIGHT 60 METERS

WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	12	CIRCULAR DEGREES
WIND SPEED	28	MPH

DELTA TEMPERATURE	-1.2	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	12	CIRCULAR DEGREES
WIND SPEED	22	MPH
TEMPERATURE	3.5	DEG C



CFMS

F2 ENVIRON  
MENU

F3 ENVIRON

F4

F5 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

JOB SENT TO PRINTER



351


## METEOROLOGICAL DATA

PAL

10/22/96

0900

HEIGHT 60 METERS



WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	10.4	CIRCULAR DEGREES
WIND SPEED	24	MPH

DELTA TEMPERATURE	-1.3	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	10.4	CIRCULAR DEGREES
WIND SPEED	19	MPH
TEMPERATURE	3.7	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F9

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

1000




## METEOROLOGICAL DATA

PAL

10/22/96

0915

HEIGHT 60 METERS



WIND DIRECTION 225 CIRCULAR DEGREES  
STD DEVIATION 9.2 CIRCULAR DEGREES  
WIND SPEED 20 MPH

DELTA TEMPERATURE -1.1 DEG C  
STABILITY D PASQ

HEIGHT 10 METERS

WIND DIRECTION 225 CIRCULAR DEGREES  
STD DEVIATION 9.2 CIRCULAR DEGREES  
WIND SPEED 15 MPH  
TEMPERATURE 4.0 DEG C

CFMS

F1 ENVIRON  
MENU

F3 ENVIRON

F9

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

COP

JOB SENT TO PRINTER

1000



351


## METEOROLOGICAL DATA

PAL

10/22/96

0930

HEIGHT 60 METERS



WIND DIRECTION

230

CIRCULAR DEGREES

STD DEVIATION

7.9

CIRCULAR DEGREES

WIND SPEED

17

MPH

DELTA TEMPERATURE

-0.9

DEG C

STABILITY

D

PASQ

HEIGHT 10 METERS

WIND DIRECTION

230

CIRCULAR DEGREES

STD DEVIATION

7.9

CIRCULAR DEGREES

WIND SPEED

13

MPH

TEMPERATURE

4.5

DEG C

GEMS

ENVIRON  
MNU

ENVIRON

F1

RADIO  
LOGICAL

F11

F12

F13

F14

F15



JOB SENT TO PRINTER

351

## METEOROLOGICAL DATA


PAL

10/22/96

0945

HEIGHT 60 METERS

WIND DIRECTION	224	CIRCULAR DEGREES
STD DEVIATION	8.3	CIRCULAR DEGREES
WIND SPEED	20	MPH



DELTA TEMPERATURE	-0.8	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	224	CIRCULAR DEGREES
STD DEVIATION	8.3	CIRCULAR DEGREES
WIND SPEED	15	MPH
TEMPERATURE	4.6	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F9

F19 RADIO  
LOGICAL

F11

F12

F13

F14

F15

F100

JOB SENT TO PRINTER



351


## METEOROLOGICAL DATA

PAL

10/22/96

1000

HEIGHT 60 METERS



WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	8.1	CIRCULAR DEGREES
WIND SPEED	16	MPH

DELTA TEMPERATURE	-0.7	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	8.1	CIRCULAR DEGREES
WIND SPEED	12	MPH
TEMPERATURE	4.9	DEG C

CFMS

F<sub>1</sub> ENVIRON  
MENUF<sub>2</sub> ENVIRONF<sub>3</sub>F<sub>10</sub> RADIO-  
LOGICALF<sub>11</sub>F<sub>12</sub>F<sub>13</sub>F<sub>14</sub>F<sub>15</sub>

1000


OK

JOB SENT TO PRINTER



10/22/96

1015



HEIGHT 60 METERS

WIND DIRECTION	224	CIRCULAR DEGREES
STD DEVIATION	7.2	CIRCULAR DEGREES
WIND SPEED	10	MPH

DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	224	CIRCULAR DEGREES
STD DEVIATION	7.2	CIRCULAR DEGREES
WIND SPEED	8	MPH
TEMPERATURE	5.2	DEG C



351

## METEOROLOGICAL DATA


PAL

10/22/96

1030

HEIGHT 60 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	11	MPH



DELTA TEMPERATURE	-0.2	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	9	MPH
TEMPERATURE	5.5	DEG C

351

## METEOROLOGICAL DATA


PAL

10/22/96

1045

HEIGHT 60 METERS

WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	6.9	CIRCULAR DEGREES
WIND SPEED	9	MPH



DELTA TEMPERATURE	-0.4	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	6.9	CIRCULAR DEGREES
WIND SPEED	7	MPH
TEMPERATURE	6.0	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F9

RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

1001



351

## METEOROLOGICAL DA


PAL

10/22/96

1100

HEIGHT 60 METERS

WIND DIRECTION	226	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	7	MPH



DELTA TEMPERATURE	-0.5	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	226	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	5	MPH
TEMPERATURE	6.2	DEG C

PAL

10/22/96

1115


HEIGHT 6.0 METERS

WIND DIRECTION	227	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	5	MPH

DELTA TEMPERATURE	-0.4	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	227	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	4	MPH
TEMPERATURE	6.8	DEG C



GEMS

F ENVIRON  
MENU

F ENVIRON

F2

F10 RADIO  
LOGICAL

F11

F12

F13

F14

F15

F16




JOB SENT TO PRINTER

10/22/96

10/22/96

HEIGHT 60 METERS



WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	6.8	CIRCULAR DEGREES
WIND SPEED	7	MPH

DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	6.8	CIRCULAR DEGREES
WIND SPEED	5	MPH
TEMPERATURE	7.1	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F2

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

10/22/96

JOB SENT TO PRINTER



351

## METEOROLOGICAL DATA


PAL

10/22/96

1145

HEIGHT 60 METERS

WIND DIRECTION	228	CIRCULAR DEGREES
STD DEVIATION	6.5	CIRCULAR DEGREES
WIND SPEED	8	MPH



DELTA TEMPERATURE	-0.2	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	228	CIRCULAR DEGREES
STD DEVIATION	6.5	CIRCULAR DEGREES
WIND SPEED	6	MPH
TEMPERATURE	7.3	DEG C

351

## METEOROLOGICAL DATA


PAL

10/22/96

1200

HEIGHT 60 METERS

WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	7	MPH



DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	7.0	CIRCULAR DEGREES
WIND SPEED	5	MPH
TEMPERATURE	7.3	DEG C


351

## METEOROLOGICAL DATA

PAL

10/22/96

1215



HEIGHT 60 METERS

WIND DIRECTION	229	CIRCULAR DEGREES
STD DEVIATION	6.7	CIRCULAR DEGREES
WIND SPEED	4	MPH

DELTA TEMPERATURE	-0.5	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS


WIND DIRECTION	229	CIRCULAR DEGREES
STD DEVIATION	6.7	CIRCULAR DEGREES
WIND SPEED	3	MPH
TEMPERATURE	7.5	DEG C

## METEOROLOGICAL DATA

PAL

10/22/96

125



HEIGHT 60 METERS

WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	6.9	CIRCULAR DEGREES
WIND SPEED	7	MPH

DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	6.9	CIRCULAR DEGREES
WIND SPEED	5	MPH
TEMPERATURE	8.2	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F1

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

100




351

## METEOROLOGICAL DATA

PAL

10/22/96

1245



HEIGHT 60 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	6.0	CIRCULAR DEGREES
WIND SPEED	10	MPH

DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ


HEIGHT 10 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	6.0	CIRCULAR DEGREES
WIND SPEED	8	MPH
TEMPERATURE	8.5	DEG C

10/22/96

1300

HEIGHT 60 METERS



WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	6.2	CIRCULAR DEGREES
WIND SPEED	11	MPH

DELTA TEMPERATURE	-0.4	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS


WIND DIRECTION	219	CIRCULAR DEGREES
STD DEVIATION	6.2	CIRCULAR DEGREES
WIND SPEED	9	MPH
TEMPERATURE	8.7	DEG C

10/22/96

1315

HEIGHT 60 METERS

WIND DIRECTION	230	CIRCULAR DEGREES
STD DEVIATION	5.5	CIRCULAR DEGREES
WIND SPEED	10	MPH



DELTA TEMPERATURE	-0.3	DEG C
STABILITY	E	PASQ

HEIGHT 10 METERS

WIND DIRECTION	230	CIRCULAR DEGREES
STD DEVIATION	5.5	CIRCULAR DEGREES
WIND SPEED	8	MPH
TEMPERATURE	9.3	DEG C




PAL

10/22/96

1330

HEIGHT 60 METERS



WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	8.2	CIRCULAR DEGREES
WIND SPEED	14	MPH

DELTA TEMPERATURE	-0.6	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	225	CIRCULAR DEGREES
STD DEVIATION	8.2	CIRCULAR DEGREES
WIND SPEED	11	MPH
TEMPERATURE	9.2	DEG C



351

## METEOROLOGICAL DATA

PAL

10/22/96

1345

HEIGHT 60 METERS

WIND DIRECTION

228

CIRCULAR DEGREES

STD DEVIATION

8.9

CIRCULAR DEGREES

WIND SPEED

13

MPH

DELTA TEMPERATURE

-0.8

DEG C

STABILITY

D

PASQ

HEIGHT 10 METERS

WIND DIRECTION

228

CIRCULAR DEGREES

STD DEVIATION

8.9

CIRCULAR DEGREES

WIND SPEED


10

MPH

TEMPERATURE

9.5

DEG C



CFMS

ENVIRON  
MENU

ENVIRON

F5

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

1011




## METEOROLOGICAL DATA

PAL

10/22/96

1700

HEIGHT 60 METERS



WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	8.2	CIRCULAR DEGREES
WIND SPEED	16	MPH

DELTA TEMPERATURE	-0.6	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	221	CIRCULAR DEGREES
STD DEVIATION	8.2	CIRCULAR DEGREES
WIND SPEED	12	MPH
TEMPERATURE	9.1	DEG C

CFMS

ENVIRON  
MENU

ENVIRON

F10 RADIO-  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER

1000



PAL

10/22/96

1415


HEIGHT 60 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	8.1	CIRCULAR DEGREES
WIND SPEED	17	MPH

DELTA TEMPERATURE	-0.7	DEG C
STABILITY	D	PASQ

HEIGHT 10 METERS

WIND DIRECTION	223	CIRCULAR DEGREES
STD DEVIATION	8.1	CIRCULAR DEGREES
WIND SPEED	13	MPH
TEMPERATURE	8.9	DEG C



CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9

F10 RADIO  
LOGICAL

F11

F12

F13

F14

F15

OK

JOB SENT TO PRINTER


PAL

10/22/96

130

HEIGHT 60 METERS

WIND DIRECTION 226 CIRCULAR DEGREES  
 STD DEVIATION 7.1 CIRCULAR DEGREES  
 WIND SPEED 9 MPH



DELTA TEMPERATURE -0.5 DEG C  
 STABILITY E PASQ

HEIGHT 10 METERS

WIND DIRECTION 226 CIRCULAR DEGREES  
 STD DEVIATION 7.1 CIRCULAR DEGREES  
 WIND SPEED 7 MPH  
 TEMPERATURE 8.8 DEG C

## RADIOLOGICAL

PAI

10/22/96

080

STACK MONITORS

QUID RADIATION  
MONITORSCOMPONENT COOLING  
TER

130 cpm

SERVICE WATER

380 cpm

D WASTE DISCHG

454 cpm

GEN BLOWDOWN

1300 cpm

EXISTING BASIN

280 cpm

MAILED FUEL



2.47E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

20 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12


F13

F14

F15

OK

0000



PAI

10/22/96 0815

## STACK MONITORS

QUID RADIATION  
MONITORCOMPONENT COOLING  
TER

130 cpm

&gt; SERVICE WATER

380 cpm

&gt; D WASTE DISCHG

454 cpm

GEN BLOWDOWN

1300 cpm

EXISTING BASIN

280 cpm

SWAILED FUEL



247E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

20 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR.  
LOGICAL

F10

F11

F12

F13

F14

F15

OK



PAI

10/22/96

0030

## STACK MONITORS

LO RNG NOBLE GASES

61.7

cpm

HI RNG NOBLE GASES

1.10 E-01

mrem/hr

GAS RAD INTR A

V

cpm

GAS RAD INST B

V

cpm

## CONTROL ROOM RAD

.10

mrem/hr

## SPENT FUEL POOL

## NORTH

0.12

mrem/hr

## SOUTH

0.10

mrem/hr

## CONDENSER OFFGAS

25

cpm

## Ö RAD WASTE PLENUM

&lt; 100

cpm

## Ö EAST ENG SAFE GUARDS

220

cpm

## Ö WEST ENG SAFE GUARDS

220

cpm

## RAD WASTE VENT

38

cpm

OK

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

130 cpm

SERVICE WATER

380 cpm

AD WASTE DISCHG

454 cpm

TM GEN BLOWDOWN

1300 cpm

FIXING BASIN

280 cpm

BAILED FUEL


2.47E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

20 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

1010



PAL

10/22/96

C

STACK MONITORS

QUID RADIATION  
MONITORSCOMPONENT COOLING  
TER

130 cpm

KVIECE WATER

380 cpm

D WASTE DISCHG

454 cpm

&gt;M GEN BLOWDOWN

2.28E04 cpm

EXISTING BASIN

280 cpm



REILLED FUEL

2.38E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

PEAK AT  
400 → 48 cpmDECADe DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

PAI

10/22/96

09C

STACK MONITORS

QUID RADIATION  
MONITORSCOMPONENT COOLING  
JER

130 cpm

SERVICE WATER

380 cpm

WASTE DISCHG

454 cpm

GEN BLOWDOWN

2.55E04 cpm

XING BASIN

280 cpm

ILLED FUEL


1.17E04 cpm

IN STEAM A

40 cpm

IN STEAM B

48 cpm

DECAYE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

63.8 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

.10 mrem/hr

SPENT FUEL POOL

NORTH

0.12 mrem/hr

SOUTH

0.10 mrem/hr

CONDENSER OPPGAS

5.95 E06 cpm

Ö RAD WASTE PLENUM

&lt; 100 cpm

Ö EAST ENG SAPE GUARDS

220 cpm

Ö WEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

PAL

10/22/96

## STACK MONITOR

QUID RADIATION  
MONITORSCOMPONENT COOLING  
TER

130 cpm

SERVICE WATER

380 cpm

D. WASTE DISCHG

454 cpm

GEN BLOWDOWN

0.94 cpm

EXISTING BASIN

280 cpm

MAILED FUEL



2.4E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

48 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

OK



PAL

10/22/96

0,00

## STACK MONITORS

LO RNG NOBLE GASES

61.6 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

.10 mrem/hr

SPENT FUEL POOL

NORTH

0.12 mrem/hr

SOUTH

0.10 mrem/hr

CONDENSER OFFGAS

2.5E03 cpm

ORAD WASTE PLENUM

&lt; 100 cpm

OEAST ENG SAFE GUARDS

220 cpm

OWEST ENG SAFE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

OK

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

130 cpm

SERVICE WATER

380 cpm

AD WASTE DISCHG

454 cpm

TM GEN BLOWDOWN

0.94 cpm

FIXING BASIN

280 cpm

BAILED FUEL



2.45 E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

48 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

10/22/96

09

## STACK MONITORS

QUID RADIATION  
MONITORSCOMPONENT COOLING  
THERMISTOR

130 cpm

SERVICE WATER

380 cpm

D WASTE DISCHG

454 cpm

DM GEN BLOWDOWN

05H cpm

EXISTING BASIN

280 cpm

BAILED FUEL

2.44E04 cpm

MAIN STEAM A

40 cpm



MAIN STEAM B

47 cpm

DECADE DEPENDENT ON

CONTROL ROOM SWITCH

POSITION



PAL

10/22/96

1000

## STACK MONITORS

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

130 cpm

SERVICE WATER

380 cpm

AD WASTE DISCHG

454 cpm

TM GEN BLOWDOWN

0.9H cpm

FIXING BASIN

280 cpm

MAILED FUEL



1.36 E04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

47 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

10/22/96

## STACK MONITORS

LO RNG NOBLE GASES

61.7

cpm

HI RNG NOBLE GASES

1.10 E-01

mrem/hr

GAS RAD INTR A

V

cpm

GAS RAD INST B

V

cpm

## CONTROL ROOM RAD

.10

mrem/hr

## SPENT FUEL POOL

## NORTH

0.12

mrem/hr

## SOUTH

0.10

mrem/hr

## CONDENSER OFFGAS

2.5E03

cpm

## ORAD WASTE PLENUM

&lt; 100

cpm

## OEAST ENG SAFE GUARDS

220

cpm

## OWEST ENG SAFE GUARDS


220

cpm

## RAD WASTE VENT

38

cpm

QUID RADIATION  
MONITORSCOMPONENT COOLING  
TER

130 cpm

SERVICE WATER  
380 cpmD WASTE DISCHG  
454 cpmH GEN BLOWDOWN  
0SH cpmEXISTING BASIN  
280 cpmREMAILED FUEL  
2.42E04 cpmMAIN STEAM A  
40 cpmMAIN STEAM B  
47 cpmDECade dependent on  
control room switch  
position

CFMS

F1 ENVIRON  
MENU

F2 ENVIRON

F3 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15



PAI

10/22/96

10.

STACK MONITORS

QUID RADIATION  
MONITORCOMPONENT COOLING  
TER

130 cpm

KVIEZ WATER

380 cpm

D WASTE DISCHG

454 cpm

H GEN BLOWDOWN

05H cpm

EXISTING BASIN

280 cpm

REMOVED FUEL


2.4HE04 cpm

MAIN STEAM A

40 cpm

MAIN STEAM B

47 cpm

DECade DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

60.5 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

.10 mrem/hr

SPENT FUEL POOL

NORTH

0.12 mrem/hr

SOUTH

0.10 mrem/hr

CONDENSER OFFGAS

2.5E03 cpm

Ö RAD WASTE PLENUM

&lt; 100 cpm

Ö EAST ENG SAPE GUARDS

220 cpm

Ö WEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15



## RADIOLOGICAL

PAL

10/22/96

10

## STACK MONITORS


QUID RADIATION  
MONITORCOMPONENT COOLING  
TER

OSH cpm

SERVICE WATER  
380 cpmWASTE DISCHG  
454 cpm

GEN BLOWDOWN

OSH cpm

EXISTING BASIN  
280 cpmMAILED FUEL  
1.00 E05 cpmMAIN STEAM A  
50 cpmMAIN STEAM B  
7550 cpmDECAYE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

60.5 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

.54 mrem/hr

SPENT FUEL POOL

NORTH

50 mrem/hr

SOUTH

50 mrem/hr

CONDENSER OFFGAS

EEEEEEE cpm

RAD WASTE PLENUM

&lt; 100 cpm

EAST ENG SAPE GUARDS

220 cpm

WEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

CFMS

F1 ENVIRON  
MENU

F2 ENVIRON

F3 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

OK



10/22/96

## STACK MONITORS


LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

OSH cpm

SERVICE WATER  
380 cpmRAD WASTE DISCHG  
454 cpm

TM GEN BLOWDOWN

OSH cpm

FIXING BASIN  
280 cpmMAILED FUEL  
9.0E05 cpmMAIN STEAM A  
140 cpmMAIN STEAM B  
9.050 cpmDECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES  
60.9 cpm

HI RNG NOBLE GASES  
1.10 E-01 mrem/hr

GAS RAD INTR. A  
V cpm

GAS RAD INST B  
V cpm

CONTROL ROOM RAD  
.78 mrem/hr

SPENT FUEL POOL

NORTH  
70 mrem/hr

SOUTH  
70 mrem/hr

CONDENSER OFFGAS  
EEEEEE cpm

ORAD WASTE PLENUM  
< 100 cpm

EAST ENG SAFE GUARDS  
220 cpm

WEST ENG SAFE GUARDS  
220 cpm

RAD WASTE VENT  
38 cpm



PAI

10/22/96

## STACK MONITORS

LO RNG NOBLE GASES

61.0

cpm

HI RNG NOBLE GASES

1.10 E-01

mrem/hr

GAS RAD INTR A

V

cpm

GAS RAD INST B

V

cpm

## CONTROL ROOM RAD

4.7

mrem/hr

## SPENT FUEL POOL

NORTH

430

mrem/hr

SOUTH

430

mrem/hr

## CONDENSER OFFGAS

EEEEEE

cpm

## Ö RAD WASTE PLENUM

&lt; 100

cpm

## Ö EAST ENG SAFE GUARDS

220

cpm

## Ö WEST ENG SAFE GUARDS

220

cpm

## RAD WASTE VENT

38

cpm

## FUEL HANDLING AREAS

MONITOR 1 V mrem/hr

MONITOR 2 V mrem/hr

## CONTAINMENT ISOLATION

RIA-1805 .898 rem/hr

RIA-1806 .898 rem/hr

RIA-1807 8.08 rem/hr

RIA-1808 4.02 rem/hr


HI RANGE LEFT 1.55E-02 rem/hr

HI RANGE RIGHT 1.45 E-02 rem/hr

## DIRTY WASTE DRAIN TANKS

T-60 WEST LVL 14.2

T-60 EAST LVL 8.9

DECAY DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

8811

OK





PAL

10/22/96

STACK MONITORS

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

OSH cpm

SERVICE WATER  
380 cpmAD WASTE DISCHG  
454 cpmTM GEN BLOWDOWN  
OSH cpmFIXING BASIN  
280 cpmBAILED FUEL  
OSH cpmMAIN STEAM A  
13000 cpmMAIN STEAM B  
140 cpmDECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

1010



10/22/86

120

STACK MONITORS

QUID RADIATION  
MONITORSCOMPONENT COOLING  
THERMISTOR

OSH cpm

SERVICE WATER

380 cpm

RAD. WASTE DISCHG

454 cpm

EM GEN BLOWDOWN

OSH cpm

FIXING BASIN

280 cpm

MAILED FUEL


OSH cpm

MAIN STEAM A

130 cpm

MAIN STEAM B

12000 cpm

DECAYE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

63.1 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

6.6 mrem/hr

SPENT FUEL POOL

NORTH

600 mrem/hr

SOUTH

600 mrem/hr

CONDENSER OFFGAS

EEEEEE cpm

ORAD WASTE PLENUM

&lt; 100 cpm

OEAST ENG SAPE GUARDS

220 cpm

OWEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

10/22/96

## STACK MONITORS

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

0SH cpm

SERVICE WATER

380 cpm

AD WASTE DISCHG

454 cpm

TM GEN BLOWDOWN

0SH cpm

FIXING BASIN

280 cpm

MAILED FUEL



0SH cpm

MAIN STEAM A

130 cpm

MAIN STEAM B

1100 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

PAI

10/22/96

STACK MONITOR

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

OSH cpm

SERVICE WATER

380 cpm

RAD WASTE DISCHG

454 cpm

TH GEN BLOWDOWN

OSH cpm

FIXING BASIN

280 cpm

BAILED FUEL



OSH cpm

MAIN STEAM A

130 cpm

MAIN STEAM B

10000 cpm

DECAYE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

PAI

10/22/96

16

## STACK MONITORS

LO RNG NOBLE GASES

61.5 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

3.5 mrem/hr

SPENT FUEL POOL

NORTH

320 mrem/hr

SOUTH

320 mrem/hr

CONDENSER OFFGAS

EEEEEE cpm

Ø RAD WASTE PLENUM

&lt; 100 cpm

Ø EAST ENG SAPE GUARDS

220 cpm

Ø WEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

## FUEL HANDLING AREAS

MONITOR 1	V	mrem/hr
MONITOR 2	V	mrem/hr

## CONTAINMENT ISOLATION

RIA-1805	.798	rem/hr
RIA-1806	.798	rem/hr
RIA-1807	7.08	rem/hr
RIA-1808	3.52	rem/hr
HI RANGE LEFT	1.55E-02	rem/hr
HI RANGE RIGHT	1.45 E-02	rem/hr

## DIRTY WASTE DRAIN TANKS

T-60 WEST LVL	14.2	•
T-60 EAST LVL	8.9	•

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
STER

OSH cpm

SERVICE WATER  
380 cpmRAD WASTE DISCHG  
454 cpm

TH GEN BLOWDOWN

OSH cpm

FIXING BASIN  
280 cpm

MAILED FUEL

OSH cpm

MAIN STEAM A  
130 cpmMAIN STEAM B  
9000 cpmDECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15



PAL

10/22/96

1-

## STACK MONITORS

LO RNG NOBLE GASES

62.5 cpm

HI RNG NOBLE GASES

1.10E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

3.1 mrem/hr

SPENT FUEL POOL

NORTH

275 mrem/hr

SOUTH

275 mrem/hr

CONDENSER OFFGAS

EEEEEE cpm

RAD WASTE PLENUM

&lt; 100 cpm

EAST ENG SAFE GUARDS

220 cpm

WEST ENG SAFE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

OK

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

OSH cpm

SERVICE WATER  
380 cpmAD WASTE DISCHG  
454 cpm

TM GEN BLOWDOWN

OSH cpm

WASHING BASIN  
280 cpmPAILED FUEL  
OSH cpmMAIN STEAM A  
130 cpmMAIN STEAM B  
8500 cpmDECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

## FUEL HANDLING AREAS


MONITOR 1	V	mrem/hr
MONITOR 2	V	mrem/hr

## CONTAINMENT ISOLATION

RIA-1805	.698	rem/hr
RIA-1806	.698	rem/hr
RIA-1807	6.08	rem/hr
RIA-1808	3.02	rem/hr
HI RANGE LEFT	1.55E-02	rem/hr
HI RANGE RIGHT	145E-02	rem/hr

## DIRTY WASTE DRAIN TANKS

T-60 WEST LVL	14.2	
T-60 EAST LVL	8.9	



CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

OK




10/22/96

15

STACK MONITORS

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
ER

OSH cpm

DEVICE WATER  
380 cpmWASTE DISCHG  
454 cpmGEN BLOWDOWN  
OSH cpmXING BASIN  
280 cpmILLED FUEL  
OSH cpmIN STEAM A  
130 cpmIN STEAM B  
8000 cpmDECAYE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

63.5 cpm

HI RNG NOBLE GASES

1.10 E-01 rem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

2.7 rem/hr

SPENT FUEL POOL

NORTH

245 rem/hr

SOUTH

245 rem/hr

CONDENSER OFFGAS

EEEEEE cpm

RAD WASTE PLUM

&lt; 100 cpm

EAST ENG SAPE GUARDS

220 cpm

WEST ENG SAPE GUARDS

220 cpm

RAD WASTE VENT

38 cpm



## RADIOLOGICAL

10/22/96

STACK MONITORS

QUID RADIATION  
MONITORCOMPONENT COOLING  
THERMISTOROSH CPM  
SERVICE WATER

380 CPM

D WASTE DISCHG

454 CPM

H GEN BLOWDOWN

OSH CPM

XING BASIN

280 CPM

ILLED FUEL


OSH CPM

MAIN STEAM A

130 CPM

MAIN STEAM B

7500 CPM

DECade DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

LO RNG NOBLE GASES

62.9 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

2.7 mrem/hr

SPENT FUEL POOL

NORTH

245 mrem/hr

SOUTH

245 mrem/hr

CONDENSER OFFGAS

EEEEEE CPM

ORAD WASTE PLENUM

&lt; 100 cpm

OEAST ENG SAFE GUARDS

220 cpm

OWEST ENG SAFE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

UUU

OK



## RADIOLOGICAL

PAI



10/22/96

12

STACK MONITORS

QUID RADIATION  
MONITORCOMPONENT COOLING  
FAN

OSH cpm

SERVICE WATER cpm  
380 cpmWASTE DISCHG  
454 cpmGEN BLOWDOWN  
OSH cpmXING BASIN  
280 cpmILLED FUEL  
OSH cpmMAIN STEAM A  
130 cpmMAIN STEAM B  
7000 cpmDECADe DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

CFMS

F7 ENVIRON  
MENU

F8 ENVIRON

F9 METEORO-  
LOGICAL

F10

F11

F12

F13

F14

F15

UUU

OK



10/22/96

STACK MONITORS

LO RNG NOBLE GASES

61.0

cpm

HI RNG NOBLE GASES

1.10 E-01

mrem/hr

GAS RAD INTR A

V

cpm

GAS RAD INST B

V

cpm

CONTROL ROOM RAD

1.8

mrem/hr

SPENT FUEL POOL

NORTH

160

mrem/hr

SOUTH

160

mrem/hr

CONDENSER OPP GAS

EEEEEEEEE

cpm

RAD WASTE PLENUM

&lt; 100

cpm

EAST ENG SAPE GUARDS

220

cpm

WEST ENG SAPE GUARDS

220

cpm

RAD WASTE VENT

38

cpm

OK

QUID RADIATION  
MONITORSCOMPONENT COOLING  
FIR

OSH cpm

WATER 380 cpm

WASTE DISCHG 454 cpm

GEN BLOWDOWN



OSH cpm

XING BASIN 280 cpm

ILLED FUEL OSH cpm

IN STEAM A 130 cpm

MAIN STEAM B 6500 cpm

DECADE DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

## RADIOLOGICAL

10/22/96

14.

STACK MONITORS

QUID RADIATION  
MONITORCOMPONENT COOLING  
TER

OSH cpm

SERVICE WATER

380 cpm

D WASTE DISCHG

454 cpm

H GEN BLOWDOWN

OSH cpm

XING BASIN

280 cpm

OILED FUEL



OSH cpm

MAIN STEAM A

130 cpm

MAIN STEAM B

6000 cpm

DECADe DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

PAI

10/22/96

X30

## STACK MONITORING

LO RNG NOBLE GASES

60.4 cpm

HI RNG NOBLE GASES

1.10 E-01 mrem/hr

GAS RAD INTR A

V cpm

GAS RAD INST B

V cpm

CONTROL ROOM RAD

1.1 mrem/hr

SPENT FUEL POOL

NORTH

100 mrem/hr

SOUTH

100 mrem/hr

CONDENSER OFFGAS

EEEEEE cpm

RAD WASTE PLENUM

&lt; 100 cpm

EAST ENG SAFE GUARDS

220 cpm

WEST ENG SAFE GUARDS

220 cpm

RAD WASTE VENT

38 cpm

(OK)

LIQUID RADIATION  
MONITORSCOMPONENT COOLING  
WATER

OSH cpm

SERVICE WATER cpm

380 cpm

AD WASTE DISCHG

454 cpm

TM GEN BLOWDOWN

OSH cpm

FIXING BASIN

280 cpm

BAILED FUEL

OSH cpm

MAIN STEAM A

130 cpm

MAIN STEAM B

5500 cpm

DECade DEPENDENT ON  
CONTROL ROOM SWITCH  
POSITION

## FUEL HANDLING AREAS

MONITOR 1	V	mrem/hr
MONITOR 2	V	mrem/hr

## CONTAINMENT ISOLATION

RIA-1805	.698	rem/hr
RIA-1806	.698	rem/hr
RIA-1807	6.08	rem/hr
RIA-1808	3.02	rem/hr
HI RANGE LEFT	1.55E-02	rem/hr
HI RANGE RIGHT	1.45E-02	rem/hr

## DIRTY WASTE DRAIN TANKS

T-60 WEST LVL	14.2	
T-60 EAST LVL	8.9	

CFMS

F1 ENVIRON  
MENU

F2 ENVIRON

F3 METEOR-  
LOGICAL

F10

F11

F12

F13

F14

F15

UUU

