

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO 50-255
 UNIT Palisades
 DATE 06/03/97
 COMPLETED BY KAKobiata
 TELEPHONE (616)764-2572

MONTH May

AVERAGE DAILY POWER LEVEL (MWe Net)		DAY	AVERAGE DAILY POWER LEVEL (MWe Net)	
1.	<u>771</u>	17.	<u>771</u>	
2.	<u>772</u>	18.	<u>766</u>	
3.	<u>771</u>	19.	<u>769</u>	
4.	<u>772</u>	20.	<u>773</u>	
5.	<u>768</u>	21.	<u>772</u>	
6.	<u>771</u>	22.	<u>772</u>	
7.	<u>771</u>	23.	<u>771</u>	
8.	<u>768</u>	24.	<u>768</u>	
9.	<u>771</u>	25.	<u>767</u>	
10.	<u>772</u>	26.	<u>771</u>	
11.	<u>769</u>	27.	<u>771</u>	
12.	<u>772</u>	28.	<u>768</u>	
13.	<u>773</u>	29.	<u>766</u>	
14.	<u>770</u>	30.	<u>768</u>	
15.	<u>772</u>	31.	<u>768</u>	
16.	<u>771</u>			

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-NET for each day in the reporting month. Compute to the nearest whole megawatt.

9706090229 970603
 PDR ADOCK 05000255
 R PDR

SUMMARY OF OPERATING EXPERIENCE FOR MAY 1997

The Unit operated at 100 percent power the entire month.

REPORT MONTH MAY 1997

DOCKET NO 50-255
UNIT Palisades
DATE 06/03/97
COMPLETED BY KAKobiata
TELEPHONE 616-764-2572

UNIT SHUTDOWNS AND POWER REDUCTIONS

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
-----	------	-------------------	---------------------	---------------------	--	-------------------------------	-----------------------------	--------------------------------	---

NONE

1.	2.	3.	4.	5.
F: Forced	Reason :	Method:	Exhibit G - Instructions	Exhibit I - Same Source
S: Scheduled	A-Equipment Failure (Explain)	1-Manual	for Preparation of Data	
	B-Maintenance or Test	2-Manual Scram	Entry Sheets for Licensee	
	C-Refueling	3-Automatic Scram	Event Report (LER) File	
	D-Regulatory Restriction	4-Other (Explain)	(NUREG-0161)	
	E-Operator Training & License Examination			
	F-Administrative			
	G-Operational Error (Explain)			
	H-Other (Explain)			

OPERATING DATA REPORT

DOCKET NO 50-255
 DATE 6-2-97
 COMPLETED BY KAKobiata
 TELEPHONE (616)764-2572

OPERATING STATUS:

- | | |
|--|---------------|
| 1. UNIT NAME | Palisades |
| 2. REPORTING PERIOD: | 970501-970531 |
| 3. LICENSED THERMAL POWER (Mwt) | 2530 |
| 4. NAMEPLATE RATING (GROSS MWe) | 811.7 |
| 5. DESIGN ELECTRICAL RATING (NET MWe) | 805 |
| 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe) | **770 |
| 7. MAXIMUM DEPENDABLE CAPACITY (NET MWe) | **730 |
| 8. IF CHANGES OCCUR IN CAPCITY RATINGS (ITEM NUMBERS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: | |

NOTES:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe):
 10. REASONS FOR RESTRICTIONS, IF ANY:

	This Month	Yr-to-Date	Cumulative
11. HOURS IN REPORTING PERIOD	744.0	3623.0	223094.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	3097.2	131194.4
13. REACTOR RESERVE SHUTDOWN HOURS	----	----	----
14. HOURS GENERATOR ON-LINE	744.0	2957.2	126182.7
15. UNIT RESERVE SHUTDOWN HOURS	----	----	----
16. GROSS THERMAL ENERGY GENERATED (MWH)	1874999.8	7185951.3	278789949.8
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	602085	2305768	88372503
18. NET ELECTRICAL ENERGY GENERATED (MWH)	572972	2191040	83458800
19. UNIT SERVICE FACTOR	100.0%	81.6%	56.6%
20. UNIT AVAILABILITY FACTOR	100.0%	81.6%	56.6%
21. UNIT CAPACITY FACTOR (USING MDC NET)	105.5%	82.8%	54.8%*
22. UNIT CAPACITY FACTOR (USING DER NET)	95.7%	75.1%	46.5%
23. UNIT FORCED OUTAGE RATE	0.0%	18.4%	27.5%
24. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:
 26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

** Based on condenser backpressure

* Weighted Average (635 MWe used as MDC Net prior to October 1985)