

**ATTACHMENT III**  
**PROPOSED TECHNICAL SPECIFICATION CHANGES (MARK-UP)**

TABLE OF CONTENTS

3.7	PLANT SYSTEMS .....	3.7-1
3.7.1	Main Steam Safety Valves (MSSVs).....	3.7-1
3.7.2	Main Steam Isolation Valves (MSIVs) and MSIV Bypass Valves.....	3.7-5
3.7.3	Main Feedwater Isolation Valves (MFIVs) and Main Feedwater Regulating Valves (MFRVs) and MFRV Bypass Valves.....	3.7-9
3.7.4	Atmospheric Relief Valves (ARVs).....	3.7-13
3.7.5	Auxiliary Feedwater (AFW) System.....	3.7-15
3.7.6	Condensate Storage Tank (CST) .....	3.7-18
3.7.7	Component Cooling Water (CCW) System.....	3.7-20
3.7.8	Essential Service Water System (ESW).....	3.7-22
3.7.9	Ultimate Heat Sink (UHS).....	3.7-24
3.7.10	Control Room Emergency Ventilation System (CREVS).....	3.7-26
3.7.11	Control Room Air Conditioning System (CRACS).....	3.7-29
3.7.12	Emergency Core Cooling System (ECCS) Pump Room Exhaust Air Cleanup System - Not Used.....	3.7-32
3.7.13	Emergency Exhaust System (EES).....	3.7-33
3.7.14	Penetration Room Exhaust Air Cleanup System (PREACS) – Not Used.....	3.7-37
3.7.15	Fuel Storage Pool Water Level.....	3.7-38
3.7.16	Fuel Storage Pool Boron Concentration.....	3.7-39
3.7.17	Spent Fuel Assembly Storage.....	3.7-41
3.7.18	Secondary Specific Activity.....	3.7-43
3.7.19	Secondary System Isolation Valves (SSIVs).....	3.7-44
3.7.20	Class 1E Electrical Equipment Air Conditioning (A/C) System.....	3.7-46
3.8	ELECTRICAL POWER SYSTEMS.....	3.8-1
3.8.1	AC Sources - Operating.....	3.8-1
3.8.2	AC Sources - Shutdown.....	3.8-18
3.8.3	Diesel Fuel Oil, Lube Oil, and Starting Air.....	3.8-21
3.8.4	DC Sources - Operating.....	3.8-24
3.8.5	DC Sources - Shutdown.....	3.8-28
3.8.6	Battery Cell Parameters.....	3.8-30
3.8.7	Inverters - Operating.....	3.8-34
3.8.8	Inverters - Shutdown.....	3.8-35
3.8.9	Distribution Systems - Operating.....	3.8-37
3.8.10	Distribution Systems - Shutdown.....	3.8-39
3.9	REFUELING OPERATIONS.....	3.9-1
3.9.1	Boron Concentration.....	3.9-1
3.9.2	Unborated Water Source Isolation Valves.....	3.9-2
3.9.3	Nuclear Instrumentation.....	3.9-3
3.9.4	Containment Penetrations.....	3.9-5
3.9.5	Residual Heat Removal (RHR) and Coolant Circulation - High Water Level.....	3.9-7
3.9.6	Residual Heat Removal (RHR) and Coolant Circulation - Low Water Level.....	3.9-9

3.7 PLANT SYSTEMS

3.7.20 Class 1E Electrical Equipment Air Conditioning (A/C) System

LCO 3.7.20 Two Class 1E electrical equipment A/C trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One Class 1E electrical equipment A/C train inoperable.	A.1 Initiate action to implement mitigating actions.	Immediately
	<u>AND</u>	
	A.2 Verify room area temperatures $\leq 90^{\circ}\text{F}$ .	1 hour <u>AND</u> Once per 4 hours thereafter
	<u>AND</u>	
	A.3 Restore Class 1E electrical equipment A/C train to OPERABLE status.	30 days
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u>	
	B.2 Be in MODE 5.	36 hours
C. Two Class 1E electrical equipment A/C trains inoperable.	C.1 Enter LCO 3.0.3.	Immediately

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.20.1	Verify each Class 1E electrical equipment A/C train actuates on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.7.20.2	Verify each Class 1E electrical equipment A/C train has the capability to remove the assumed heat load.	In accordance with the Surveillance Frequency Control Program

5.5 Programs and Manuals

---

5.5.11 Ventilation Filter Testing Program (VFTP) (continued)

- e. Demonstrate at least once per 18 months that the heaters for each of the ESF systems dissipate the value specified below when tested in accordance with ANSI 510-1975 and corrected to design nameplate voltage settings.

ESF Ventilation System  
Control Room Pressurization  
Emergency Exhaust System

Wattage

$5 \pm 1$

~~$15 \pm 2$  KW~~  
 $37 \pm 3$  KW

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the VFTP test frequencies.

5.5.12 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Gaseous Radwaste System, the quantity of radioactivity contained in gas storage tanks and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks. The gaseous radioactivity quantities shall be determined following the methodology in Branch Technical Position (BTP) ETSB 11-5, "Postulated Radioactive Release due to Waste Gas System Leak or Failure, Revision 0". The liquid radwaste quantities shall be determined in accordance with Standard Review Plan, Section 15.7.3, "Postulated Radioactive Release due to Tank Failures, Revision 2".

The program shall include:

- a. The limits for concentrations of hydrogen and oxygen in the Gaseous Radwaste System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion);
- b. A surveillance program to ensure that the quantity of radioactivity contained in each gas storage tank is less than the amount that would result in a whole body exposure of  $\geq 0.5$  rem to any individual in an unrestricted area, in the event of an uncontrolled release of the tanks' contents; and

- c. A surveillance program to ensure that the quantity of radioactivity contained in the outdoor liquid radwaste tanks listed below that are not

(continued)

---

CALLAWAY PLANT

5.0-16

Amendment No. 215 |