

Automatic Switch Co.

FLORHAM PARK, NEW JERSEY 07932

TEST REPORT NO. AQS21678/TR

QUALIFICATION TESTS OF SOLENOID VALVES BY ENVIRONMENTAL EXPOSURE TO ELEVATED TEMPERATURE, RADIATION, WEAR AGING, SEISMIC SIMULATION, VIBRATION ENDURANCE, ACCIDENT RADIATION AND LOSS - OF - COOLANT ACCIDENT

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE

50-311

RETURN TO REACTOR DOCKET

FILES

w/ ltr. 3/6/79

7903130384

RECORDS FACILITY BRANCH

CONFIDENTIAL

Property of Automatic Switch Company

7903130390

This data is for the sole use of Automatic Switch Company personnel and representatives and remains the property of Automatic Switch Company. This book must be returned immediately upon request.

NOTICE:

This report may not be reproduced without authorization from Automatic Switch Company, nor may excerpts be printed and distributed.

| | |
|-------------|-----------------------|
| BOOK NO. | <u>64</u> |
| ASSIGNED TO | <u>J. Schubel</u> |
| COMPANY | <u>Public Service</u> |
| DATE | <u>2/21/79</u> |



TEST REPORT NO.

AQS21678/TR

QUALIFICATION TESTS OF SOLENOID VALVES BY ENVIRONMENTAL EXPOSURE TO ELEVATED TEMPERATURE, RADIATION, WEAR AGING, SEISMIC SIMULATION, VIBRATION ENDURANCE, ACCIDENT RADIATION AND LOSS-OF-COOLANT ACCIDENT (LOCA) SIMULATION.

Performed for
AUTOMATIC SWITCH CO.
Florham Park, New Jersey

By the
COMPONENT TESTING DIVISION
of
ISOMEDIX, INC.
Parsippany, New Jersey

March, 1978

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

CHICAGO DIVISION • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160

ABSTRACT

Qualification Type Tests on Automatic Switch Company Solenoid Valves were performed in accordance with the requirements of "ASCO Qualification Specification AQS-21678/Revision B" in order to provide a family of generically similar valves for safety related use in Nuclear Power Generating Stations.

The valves were subjected to successive environments of elevated temperature, radiation, accelerated operational cycling, seismic and vibration exposures, accident radiation and a simulated loss-of-coolant accident (LOCA) environmental exposure.

The performance of the valves was periodically monitored during the program and compared with baseline data representative of ASCO specification requirements.

Three and four-way, direct and internal pilot-operated solenoid valves were included in the type test program.

CONCLUSIONS: The valves tested for qualification completed the type tests and baseline/functional tests successfully. Minor anomalies observed are detailed and explained fully in the text.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

TABLE OF CONTENTS

| Section | Page |
|--|------|
| 1. Introduction..... | 1-1 |
| 2. Description of Test Samples..... | 2-1 |
| 3. Test Program..... | 3-1 |
| 4. Test Procedure and Results..... | 4-1 |
| 4.1 Baseline/Functional Testing..... | 4-1 |
| 4.2 Thermal Aging..... | 4-1 |
| 4.3 Radiation..... | 4-2 |
| 4.4 Wear Aging..... | 4-3 |
| 4.5 Seismic Simulation/Vibration Endurance..... | 4-3 |
| 4.6 Accident Radiation..... | 4-4 |
| 4.7 LOCA Simulation..... | 4-4 |
| 4.8 Summary of Performance of Valve Samples..... | 4-5 |
| 5. Summary..... | 5-1 |
| 6. Certification..... | 6-1 |

Appendix

- A "ASCO" Qualification Specification AQS-21678/Revision B
- B Test Procedure Bulletins
- C Instruments used for Baseline/Functional Tests
- D Radiation Certificate
- E 'Dayton T. Brown' Test Report
- F Operational data at 'Dayton T. Brown'
- G 'ASCO' Seismic Tests Summary and operational data

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
 Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

LIST OF TABLES

| Table No. | Page |
|---|------|
| 1. DESCRIPTION OF TEST SAMPLES..... | 2-1 |
| <u>BASELINE/FUNCTIONAL TESTS</u> | |
| 2A Valve Sample No. 1..... | 4-6 |
| 2B Valve Sample No. 2..... | 4-8 |
| 2C Valve Sample No. 3..... | 4-10 |
| 2D Valve Sample No. 4..... | 4-12 |
| 2E Valve Sample No. 5..... | 4-13 |
| 2F Valve Sample No. 6..... | 4-14 |
| 2G Valve Sample No. 7..... | 4-15 |
| 2H Valve Sample No. 8..... | 4-17 |
| 2I Valve Sample No. 9..... | 4-19 |
| 3. CYCLING DATA DURING LOCA SIMULATION..... | 4-22 |
| 4. SUMMARY OF VALVE PERFORMANCE..... | 4-24 |

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
 Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

LIST OF FIGURES

| Figure No. | Page |
|---|------|
| 1. LOCA SIMULATION PROFILE (S/C)..... | 3-3 |
| 2. ACTUAL LOCA SIMULATION TEST PROFILE (^o F/PSIG).... | 4-21 |

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

SECTION 1-- INTRODUCTION

Qualification tests on solenoid valves were performed for Automatic Switch Company according to test outline contained in "ASCO Qualification Specification AQS-21678 Revision B". This test outline is based on the suggestions contained in IEEE 323-1974 "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations", IEEE 382-1972 "IEEE Trial-Use Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations", IEEE 344-1975 "IEEE Recommended Practices for Seismic Qualifications of Class 1E Equipment for Nuclear Power Generating Stations" and IEEE 382/ANSI N278.2.1 (Draft 3, Rev. 1 June 1977) "Draft American National Standard for the Qualification of Safety Related Valve Actuators".

Seven valve samples were selected to represent six generic families of valves. Two more valve samples were added to the test program to obtain resultant test information only. The samples were subjected to sequential exposures of elevated temperature, radiation, wear aging, seismic simulation, vibration endurance, accident radiation and a 30-day loss-of-coolant accident (LOCA) simulation. Baseline operational test data was obtained and recorded for all the valves before the start and after each sequence of the test exposures with the exception of coil dielectric and insulation resistance measurements which were taken before thermal aging and after accident radiation and after LOCA exposures. The valves were energized and de-energized at high and low pressures during the test phases (except radiation) and leakage from the valves was monitored.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

At the conclusion of the LOCA period, the valves were returned to Automatic Switch Co. for further inspection and evaluation.

The tests were conducted during the period from August, 1977 through January, 1978 at the test facilities of Isomedix, Inc., Parsippany, New Jersey with the exception of seismic simulation and vibration endurance tests which were conducted at the facilities of Dayton T. Brown, Inc., Bohemia, New York and Automatic Switch Company, Florham Park, New Jersey.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

SECTION 2 DESCRIPTION OF TEST SAMPLES

The following description of the valve samples was provided by Automatic Switch Co. Isomedix numbers were marked on valve housing with a marker pen.

TABLE 1

VALVE DESCRIPTION LIST

| <u>Isomedix No.</u> | <u>ASCO Cat. No.</u> | <u>Description</u> |
|---------------------|----------------------|---|
| 1 | HVA-206-381-6F | DC, Class H leaded coil, Nema 4, 7 and 9 solenoid enclosure, metal seats, normally closed construction. |
| 2 | NP8344A71E | DC, Class H leaded coil, Nema 4, 7 and 9 solenoid enclosure. |
| 3 | XFT831654V | AC, Class F (molded) leaded coil, Nema 1 solenoid enclosure, normally closed construction. |
| 4 | HVA-206-380-3RF | AC, Class H screw terminal coil, Nema 6 solenoid enclosure, resilient seats, normally closed construction. |
| 5 | NP8320A184E | AC, Class H leaded coil, Nema 6 solenoid enclosure, normally closed construction. |
| 6 | NP831665E | DC, Class H leaded coil, Nema 4, 7 and 9 solenoid enclosure, normally closed construction. |
| 7 | HV-202-300-2RF | DC, Class H leaded coil, Nema 1 solenoid enclosure, normally closed construction. |
| 8 | NP8321A5E | DC, Class H leaded coil, Nema 4, 7 and 9 solenoid enclosure, normally closed construction. |
| 9 | NP8323A39E | (Solenoid A) AC, Class H leaded coil, (Solenoid B) DC, Class H screw terminal coil, Nema 6 solenoid enclosures, normally closed construction. |

Samples 3 and 7 are for information only.

SECTION 3 TEST PROGRAM

3.1 PURPOSE:

The purpose of the program is to provide qualification tests on seven selected valves to represent six generic families of valves for safety related applications in Nuclear Power Generating Stations.

3.2 DISCUSSIONS:

3.2.1 Baseline/Functional Testing:

Baseline Tests consist of measurement of coil excitation, seat leakages at high and low pressure, noise test, operational test, external leakage test before and after all phases of type tests. Measurement of insulation resistance and coil dielectric test are to be performed in as received condition and after completion of accident radiation and LOCA Simulation phases. The valve samples are to be energized and de-energized and their operation monitored during type test phases (except radiation).

3.2.2 Thermal Aging:

The valve samples are to be thermally aged for a period and at temperature simulating a design life of 4 years for elastomers and coil materials at an ambient temperature of 140°F. The valves are to be cycled (de-energize and energize) during the thermal aging phase to simulate one operation a month at 140°F ambient temperature.

3.2.3 Radiation:

The valve samples are to be exposed to gamma radiation at dose rate of less than 1 megarad per hour for an accumulated dose of 50 megarads.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

3.2.4 Wear Aging:

The valves are to be cycled 40,000 times at maximum operating pressure differential. The valves are to be monitored continuously during wear aging phase.

3.2.5 Seismic Simulation/Vibration Endurance:

The valves are to be mounted on a vibratory table thru test fixture. They are to be vibrated 10^6 times divided evenly in 3 axes by vibrating at a non-resonant frequency between 50 and 100 Hz at an input of .75 g or higher. The valves are to be monitored and cycled during this test phase.

The valves are to be mounted on a seismic shaker and subjected to Seismic Simulation tests per 9.4.2.4.2 of "ASCO Qualification Specification AQS-21678 Revision B" (Appendix A). The valves are to be monitored and cycled during this test phase also.

3.2.6 Accident Radiation:

The valve samples are to be exposed to gamma radiation once again to receive an additional accumulated dose of 150 megarads at a dose rate of less than 1 megarad per hour.

3.2.7 LOCA Environmental Simulation:

The valve samples are to be exposed to a Simulated Loss-of-Coolant Accident (LOCA) environment by application of steam and chemical-spray for a period of 30 days, based upon the suggested temperature/pressure profile shown in Figure 1A of Appendix A IEEE 323-1974, Figure 1 of IEEE 382-1972, and as shown in Figure 1.

During the LOCA environment exposure, the valves are to be monitored and cycled.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 956-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (501) 327-8015




FIGURE 1
LOCA SIMULATION BY ENVIRONMENTAL
EXPOSURE (STEAM/CHEMICAL)

Temperature/Pressure Profile for simulation of loss-of coolant accident (LOCA) design basis event (DBE) by steam/chemical-spray environmental exposure.

SECTION 4 TEST PROCEDURE AND RESULTS

4.1 BASELINE/FUNCTIONAL TESTING:

Baseline data was obtained before and after every phase of the Type-Test sequence. This consists of recording coil excitation, seat leakages at high and low pressures both in energized and de-energized state, noise test, operational test 10 times, external leakage both in energized and de-energized state before and after the phases of thermal aging, radiation, wear aging, vibration endurance and seismic simulation, accident radiation and LOCA simulation. Measurement of insulation resistance and coil dielectric tests were performed before thermal aging and after completion of accident radiation and LOCA simulation phases. The valve samples were energized and de-energized and their performance monitored during all the test phases with the exception of the two radiation phases.

The test data was obtained by following ASCO test procedure bulletins attached as Appendix B. The data obtained from these tests is presented in Tables 2A thru 2I of this section. The list of instruments used to record this data is attached as Appendix C.

4.2 THERMAL AGING:

The valves were exposed to temperature environment of 268°F for a period of 12 days. They were cycled (de-energize for 5 minutes and then energize) every 6 hours. All the valves (except Valve No. 8) functioned satisfactorily for the full thermal aging period of 12 days.

Valve No. 8 malfunctioned after 7 days. The valve developed excessive seat leakage (50 SCFH) both in energized and de-energized states. At the end of the test, it was determined that

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

the excessive leakage was caused by dirt in the valve. The source of the dirt was the iron pipe used in the cylinder port as piping and an additional length used to simulate an accumulator.

A new unit of valve No. 8 was substituted. This new unit was instead thermally aged at 295°F for 100 hours and was cycled every 2 hours. This higher temperature and lower thermal aging period was chosen to accelerate the test program. After approximately 60 hours of this test, the valve started leaking in energized state. The leakage was 40 SCFH at 200 psig, 17 SCFH at 125 psig and 3 SCFH at 10 psig. The valve shifted properly and had no leakage in de-energized state.

It was postulated that the rubber exhaust orifice disc pulled off the piston assembly due to the pressure load on the disc and softening of the disc caused by the high temperature of 295°F. Normal 140°F ambient temperature would not cause noticeable softening of this disc. When the valve was disassembled at the completion of the qualification testing program, this postulation proved to be true. As the valve performed its safety function, the thermal aging continued and other phases of type tests and baseline/functional tests were conducted on this valve in the same manner as on the Balance 8 valves. This No. 8 valve is normally used on air systems of 125 psig maximum. Therefore the maximum operating pressure differential has been changed from 200 psig to 150 psig. This results in a 25% load reduction on the disc.

4.3 RADIATION:

All the 9 valve samples were subjected to a Cobalt

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

source of gamma radiation at an exposure rate of less than 1 megarad per hour. The samples were removed after having received an accumulated minimum dose of 50 megarads. Appendix D contains the certification of radiation exposure.

4.4 WEAR AGING:

The valve samples were electrically cycled 40,000 times at maximum operating pressure differential using a control circuit.

4.5 SEISMIC SIMULATION/VIBRATION ENDURANCE:

The valve samples were mounted on fixtures and subjected to Seismic Simulation/Vibration Endurance tests as outlined in paragraphs 9.4.2.3.4 and 9.4.2.4.2 of "ASCO Qualification Specification AQS-21678 Revision B" (Appendix A).

All the valves successfully completed vibration portion and the seismic simulation tests conducted at the facilities of Dayton T. Brown, Inc., Bohemia, New York. Their Test Report No. DTB04R77-1651 Revision A of November 7, 1977 is attached as Appendix E. Operational data obtained during these tests at Dayton T. Brown is attached as Appendix F.

Further successful seismic tests at higher g-level were conducted at the facilities of Automatic Switch Company. A summary of these tests along with operational data obtained during these tests is attached as Appendix G.

Baseline and functional tests conducted during this test phase indicate that all the valves (with the exception of Valve No.7) passed the functional requirements to the extent of paragraphs 9.4.2.3.4 and 9.4.2.4.2 and Figure 9.1 of "ASCO Qualification Specification AQS-21678 Revision B" (Appendix A).

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
 Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

4.6 ACCIDENT RADIATION:

The samples were placed in a radiation facility to receive gamma radiation exposure at a dose rate of less than 1 megarad per hour. The samples were removed when they had received an additional dose of 150 Megarads. Thus all the samples received a total of 200 Megarads in two stages.

4.7 LOCA SIMULATION:

The valve samples mounted on a plate were placed in a horizontal pressure vessel. All the samples were energized electrically and with pressure from nitrogen gas cylinder. Prior to initiation of steam exposure, the ambient conditions in the vessel were brought to 140°F at atmospheric pressure.

To initiate the exposure, steam was rapidly admitted, raising the temperature and pressure to 346°F/110 psig within 12 minutes. These conditions were maintained for a 3-hour period. At the end of this time, a controlled temperature drop was initiated that reduced the conditions to the pre-start ambient over the next two hours.

Approximately the time when the temperature was 288°F during the first transient, a chemical solution consisting of 3000 ppm boron as boric acid in solution with 0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH value of 10 at room temperature was sprayed on the samples at a rate corresponding to 0.306 gpm per square foot of area covered by the spray.

The chemical-spray solution pH was maintained between 9.5 and 10.5. The spray remained on throughout the entire phase of the LOCA simulation.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

After returning to the pre-test ambient condition, a second transient of the LOCA simulation was initiated by again introducing steam that raised the temperature and pressure to 346°F/110 psig within 8 minutes and was held at the point for the next three hours.

At this time, the conditions were then reduced to 320°F/75 psig and maintained at this point for 3 hours before being reduced to 250°F/15 psig and held at these conditions for 4 days.

At this time, a controlled drop in temperature and pressure was initiated that further reduced the conditions to 200°F/10 psig for the remaining 30 days of exposure. Fig. 2 represents the actual LOCA Profile obtained.

The samples were cycled (energize and de-energize) during the LOCA exposure. Their leakage was checked at various time periods of the LOCA exposure. The results of this test are given in Table 3 of this section.

4.8 SUMMARY OF PERFORMANCE OF VALVE SAMPLES:

A summary of pass/fail performance of the valve samples is given in Table 4 of this section.

A check of this table indicates that all the valves (except valve No:7) met the test requirements of "ASCO Qualification AQS-21678/Revision B" (Appendix A).

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

SECTION 4

TABLE NO. 2A
VALVE SAMPLE NO. 1
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN <u>TP-3-046</u> TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|---|---------------|------|-----------|------------|-------------------------------|--------------------|------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS _____ DC AMPS <u>X</u> | .154 | .154 | .154 | .154 | .154 | .154 | .154 |
| COIL DIELECTRIC TEST @ <u>1250</u> Volts | OK | TNC | TNC | TNC | TNC | OK | * |
| SEAT High Pressure Energized LEAKAGE @ <u>125</u> PSI Deenergized | 40cc/ min. | 0 | 50cc/min. | 2.5 SCFH | 3SCFH | 4.2SCFH | 0 |
| SEAT Low Pressure Energized LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 100cc/min. | 0 | 60cc/min. | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>140</u> PSI FROM <u>140</u> TO <u>1/4</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>500</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 20K | TNC | TNC | TNC | TNC | 160K | 5 * |

TNC = Test not conducted.

* = See attached

SECTION 4

TABLE NO. 2A
VALVE SAMPLE NO. 1

- * At the end of LOCA Simulation, the coil had insulation resistance of less than one megohm, so the coil dielectric test was not performed.

During the LOCA phase, the solenoid enclosure was wired through Liquatite, type L.T. flexible electrical conduit manufactured by Electri-Flex Co., Roselle, Illinois. This conduit is rated for 120°F and during the 30-day LOCA test, plastic liquid-tight covering broke down allowing the spray solution to enter the solenoid and degrade the coil insulation, resulting in current leakage to ground. The valve solenoid enclosure was full of spray solution when it was disassembled.

The coil was dried out for 7 days at room temperature. At this stage the insulation resistance was measured to be 5 megohms and coil dielectric test indicated some leakage current at 200 Volts 60 Hz and no breakdown at 1250 Volts 60 Hz. The coil was operable.

Since the coil had satisfactory insulation resistance and passed the dielectric test prior to LOCA phase, it may be hypothesized that the coil would have been satisfactory but for the adverse effect of the spray solution. This condition was abnormal and is not expected during actual use.

SECTION 4

TABLE NO. 2B
VALVE SAMPLE NO. 2
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP 8344 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|---|------------------|------|-----------|---------------|-------------------------------------|-----------------------|---------------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS _____ DC AMPS <u> X </u> | .074 | .074 | .074 | .074 | .074 | .074 | .074 |
| COIL DIELECTRIC TEST @ <u>1250</u> Volts | OK | TNC | TNC | TNC | TNC | OK | OK |
| SEAT High Pressure LEAKAGE @ <u>140</u> PSI Energized | 40cc/ min. | 0 | 0 | 50cc/min. | 1.1SCFH | 0 | 2SCFH |
| SEAT High Pressure LEAKAGE @ <u>140</u> PSI Deenergized | 50cc/ min. | 0 | 0 | 0 | 0 | 0 | * |
| SEAT Low Pressure LEAKAGE @ <u>20</u> PSI Energized | 0 | 0 | 0 | 0 | 0 | 25cc/min. | 50cc/ min. |
| SEAT Low Pressure LEAKAGE @ <u>20</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | * |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>140</u> PSI FROM <u>140</u> TO <u>10</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>500</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 80K | TNC | TNC | TNC | TNC | 500K | 20K |

TNC = Test not conducted.

* = See attached

SECTION 4

TABLE NO. 2B
VALVE SAMPLE NO. 2

* Leak in Accumulator Tank @ port B, due to the steel tank rusting through. It was impossible to check leakage deenergized, as the internal vessel pressure was leaking into port B and out the exhaust.

SECTION 4

TABLE NO. 2C
VALVE SAMPLE NO. 3
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP8316 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|---------------|------------|-----------|------------|-------------------------------|--------------------|------------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS <u>X</u> DC AMPS _____ | 102/ 60 | 102/ 60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/ 60 |
| COIL DIELECTRIC TEST @ <u>1240</u> Volts | OK | TNC | TNC | TNC | TNC | OK | * |
| SEAT High Pressure LEAKAGE @ <u>125</u> PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 80cc/min. | 0 |
| SEAT High Pressure LEAKAGE @ <u>125</u> PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>140</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| FROM <u>140</u> TO <u>10</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>200</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 20K | TNC | TNC | TNC | TNC | 800K | 10* |

TNC = Test not conducted.
* = See attached

4-10

SECTION 4

TABLE NO. 2C
VALVE SAMPLE NO. 3

* At the end of LOCA Simulation, the coil had insulation resistance of less than one megohm, so the coil dielectric test was not performed.

During the LOCA phase, the solenoid enclosure was wired through Liquatite, type L.T. flexible electrical conduit manufactured by Electri-Flex Co., Roselle, Illinois. This conduit is rated for 120°F and during the 30-day LOCA test, plastic liquid-tight covering broke down allowing the spray solution to enter the solenoid and degrade the coil insulation, resulting in current leakage to ground. The valve solenoid enclosure was full of spray solution when it was disassembled.

The coil was dried out for 7 days at room temperature. At this stage the insulation resistance was measured to be 10 megohms and coil dielectric test indicated some leakage current at 1100 Volts 60 Hz and no breakdown at 1240 Volts 60 Hz.

This valve is for information only. Its test results do not affect the generic families of valves tested for qualification.

Since the coil had satisfactory insulation resistance and passed the dielectric test prior to LOCA phase, it may be hypothesized that the coil would have been satisfactory but for the adverse effect of the spray solution. This condition was abnormal and is not expected during actual use.



SECTION 4

TABLE NO. 2 D
VALVE SAMPLE NO. 4
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP-3-046 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|---------------|--------|-----------|------------|-------------------------------|--------------------|--------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS <u>X</u> DC AMPS _____ | 102/ 60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 |
| COIL DIELECTRIC TEST @ <u>1240</u> Volts | OK | TNC | TNC | TNC | TNC | OK | OK |
| SEAT High Pressure Energized LEAKAGE @ <u>150</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure Energized LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>165</u> PSI FROM <u>165</u> TO <u>1/4</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>500</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 200K | TNC | TNC | TNC | TNC | 180K | 20K |

4-12

TNC = Test not conducted.

SECTION 4

TABLE NO. 2 E
VALVE SAMPLE NO. 5
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP NP-8320 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|---------------|--------|-----------|------------|-------------------------------|--------------------|--------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS <u>X</u> DC AMPS _____ | 102/ 60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 |
| COIL DIELECTRIC TEST @ <u>1240</u> Volts | OK | TNC | TNC | TNC | TNC | OK | OK |
| SEAT High Pressure LEAKAGE @ <u>150</u> PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>1/4</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT High Pressure LEAKAGE @ <u>150</u> PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>1/4</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>165</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| FROM <u>165</u> TO <u>1/4</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>500</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 20K | TNC | TNC | TNC | TNC | 600K | 100K |

TNC = Test not conducted.

4-13

SECTION 4

TABLE NO. 2F
VALVE SAMPLE NO. 6
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP NP 8316 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|------------------|------|-----------|---------------|-------------------------------------|-----------------------|------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS DC AMPS <u>X</u> | .074 | .074 | .074 | .074 | .074 | .074 | .074 |
| COIL DIELECTRIC TEST @ <u>1250</u> Volts | OK | TNC | TNC | TNC | TNC | OK | OK |
| SEAT High Pressure LEAKAGE @ <u>175</u> PSI Energized | 0 | 0 | 0 | 0 | .4SCFH | 0 | 0 |
| SEAT High Pressure LEAKAGE @ <u>175</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Energized | 0 | 0 | 0 | 0 | .9SCFH | 0 | 0 |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>195</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| FROM <u>195</u> TO <u>10</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>275</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 20K | TNC | TNC | TNC | TNC | 800K | 12 |

TNC = Test not conducted.

SECTION 4

TABLE NO. 2G
VALVE SAMPLE NO. 7
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP NP 3-046 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|---|---------------|-------|-----------|------------|-------------------------------|--------------------|------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS DC AMPS <u>X</u> | .177 | .177 | .177 | .177 | .177 | .177 | .177 |
| COIL DIELECTRIC TEST @ <u>1250</u> Volts | OK | TNC | TNC | TNC | TNC | OK | * |
| SEAT High Pressure Energized LEAKAGE @ <u>200</u> PSI | 0 | 2SCFH | 60SCFH | 120SCFH | 100SCFH | 60SCFH | TNC |
| SEAT Low Pressure Energized LEAKAGE @ <u>10</u> PSI | 0 | 0 | 6SCFH | 16SCFH | 9SCFH | 12SCFH | TNC |
| SEAT High Pressure Deenergized LEAKAGE @ <u>200</u> PSI | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT Low Pressure Deenergized LEAKAGE @ <u>10</u> PSI | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>220</u> PSI | OK | OK | OK | OK | OK | OK | ≠ |
| FROM <u>220</u> TO <u>1/4</u> PSI | OK | OK | OK | OK | OK | OK | ≠ |
| EXTERNAL LEAKAGE @ <u>500</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 20K MEGS. | TNC | TNC | TNC | TNC | 400K MEGS | * |

TNC = Test not conducted.

* = See attached.

≠ = See attached.

SECTION 4

TABLE NO. 2G
VALVE SAMPLE NO. 7

- * At the end of LOCA Simulation, the coil had insulation resistance of less than one megohm, so the coil dielectric test was not performed.

During the LOCA phase, the solenoid enclosure was wired through Liquatite, type L.T. flexible electrical conduit manufactured by Electri-Flex Co., Roselle, Illinois. This conduit is rated for 120°F and during the 30-day LOCA test, plastic liquid-tight covering broke down allowing the spray solution to enter the solenoid and degrade the coil insulation, resulting in current leakage to ground. The valve solenoid enclosure was full of spray solution when it was disassembled.

The coil was dried out for 7 days at room temperature. At this stage the coil was found to be open.

This valve is for information only. Its test results do not affect the generic families of valves tested for qualification.

- ≠ Valve was energized twice satisfactorily. Subsequently it could not be re-energized. The coil was found to be open.

Since the coil had satisfactory insulation resistance and passed the dielectric test prior to LOCA phase, it may be hypothesized that the coil would have been satisfactory but for the adverse effect of the spray solution. This condition was abnormal and is not expected during actual use.

SECTION 4

TABLE NO. 2H
VALVE SAMPLE NO. 8
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP NP 8321 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|------------------|------|-----------|---------------|-------------------------------------|-----------------------|---------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS DC AMPS <u>X</u> | .074 | .074 | .074 | .074 | .074 | .074 | .074 |
| COIL DIELECTRIC TEST @ <u>1250</u> Volts | OK | TNC | TNC | TNC | TNC | OK | OK |
| SEAT High Pressure LEAKAGE @ <u>200</u> PSI Energized | 0 | * | 20SCFH | 20SCFH | 5.5SCFH | 4.7SCFH | 2SCFH |
| SEAT High Pressure LEAKAGE @ <u>200</u> PSI Deenergized | 0 | 0 | 8SCFH | 5SCFH | .6SCFH | 3.6SCFH | 2.5SCFH |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Energized | 0 | * | 3.5SCFH | 2.5SCFH | 1.2SCFH | 200cc/min. | 1SCFH |
| SEAT Low Pressure LEAKAGE @ <u>10</u> PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 1cc/min. | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ <u>220</u> PSI FROM <u>220</u> TO <u>10</u> PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ <u>300</u> PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MEGOHOMS) | 200K | TNC | TNC | TNC | TNC | 400K | 14 |

TNC = Test not conducted.

* = See attached.

4-17

SECTION 4

TABLE NO. 2H
VALVE SAMPLE NO. 8

* While exposing this valve to temperature environment of 268°F for a period of 12 days (for thermal aging) and cycling it once every 6 hours, it developed excessive leakage in energized and deenergized states. At the end of the test, it was determined that the excessive leakage was caused by dirt in the valve. The source of the dirt was the iron pipe used in the cylinder port as piping and an additional length to simulate an accumulator.

A new unit was substituted, which was thermally aged at 295°F for 100 hours and cycled once every 2 hours. This higher temperature and lower thermal aging period was chosen to accelerate the test program. After approximately 60 hours of this test, the valve started leaking in the energized state. The leakage was 40 SCFH at 200 psig, 17 SCFH at 125 psig and 3 SCFH at 10 psig. The valve shifted properly and had no leakage in de-energized state.

It was postulated that the rubber exhaust orifice disc pulled off the piston assembly due to the pressure load on the disc and softening of the disc caused by high temperature of 295°F. Normal 140°F ambient temperature would not cause noticeable softening of this disc. When the valve was disassembled at the completion of the qualification testing program, this postulation proved to be true. As the valve performed its safety function, the thermal aging continued. Further Type-Tests and Baseline/Functional tests were performed on this valve.

This valve is normally used on air systems of 125 psig maximum. Therefore the maximum operating pressure differential has been changed from 200 psig to 150 psig which would result in a 25% load reduction on the disc.

4-18

SECTION 4

TABLE NO. 2 I
VALVE SAMPLE NO. 9
BASELINE/FUNCTIONAL TESTS

| TESTS CONDUCTED PER ASCO TEST PROCEDURE BULLETIN TP NP 8323 TEST MEDIUM: NITROGEN GAS | THERMAL AGING | | RADIATION | WEAR AGING | VIBRATION END. & SEISMIC SIM. | ACCIDENT RADIATION | LOCA |
|--|---------------|--------|-----------|------------|-------------------------------|--------------------|---------------------------------|
| | PRE | POST | POST | POST | POST | POST | POST |
| COIL EXCITATION AC VOLTS <u>X</u> DC AMPS <u>X</u> | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 | 102/60 |
| | .074 | .074 | .074 | .074 | .074 | .074 | .074 |
| COIL DIELECTRIC TEST 1240 AC Volts @ 1250 DC Volts | OK | TNC | TNC | TNC | TNC | OK | * OK |
| SEAT LEAKAGE High Pressure @ 40 PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT LEAKAGE @ 40 PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT LEAKAGE Low Pressure @ 1/4 PSI Energized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SEAT LEAKAGE @ 1/4 PSI Deenergized | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| NOISE TEST | OK | OK | OK | OK | OK | OK | OK |
| OPERATIONAL TEST 10 TIMES @ 44 PSI FROM 44 TO 1/4 PSI | OK | OK | OK | OK | OK | OK | OK |
| EXTERNAL LEAKAGE @ 500 PSI (Energized & Deenergized) | OK | OK | OK | OK | OK | OK | TNC |
| INSULATION RESISTANCE (MFG OHMS) | 100K | TNC | TNC | TNC | TNC | 400K | Less than 1 meg AC 6 megs DC |

4-19

TNC = Test not conducted.
* = See attached.

SECTION 4

TABLE NO. 2I
VALVE SAMPLE NO. 9


*At the end of LOCA Simulation, the coils had insulation resistance of less than one megohm, so the coil dielectric test was not performed.

During the LOCA phase, the solenoid enclosures were wired through Liquatite, type L.T. flexible electrical conduit manufactured by Electri-Flex Co., Roselle, Illinois. This conduit is rated for 120°F and during the 30-day LOCA test, plastic liquid-tight covering broke down allowing the spray solution to enter the solenoids and degrade the coils insulation, resulting in current leakage to the ground. The valve solenoid enclosure was full of spray solution when it was disassembled.

The coils were dried for 7 days at room temperature. At this state the insulation resistance was measured to be 6 megohms (DC) and less than 1 megohm (AC). Coil dielectric test was satisfactory for DC, while it indicated some current leakage at 600 Volts/60Hz and no breakdown at 1240 Volts/60 Hz for AC. The coils were operable.

Since the coils had satisfactory insulation resistance and passed the dielectric test prior to LOCA phase, it may be hypothesized that the coils would have been satisfactory but for the adverse effect of the spray solution. This condition was abnormal and is not expected during the actual use.

FIGURE 2
 ACTUAL LOCA SIMULATION BY ENVIRONMENTAL
 EXPOSURE (STEAM/CHEMICAL)



Temperature/Pressure Profile for simulation of loss-of-coolant accident (LOCA) design basis event (DBE) by steam/chemical-spray environmental exposure.

CYCLING DATA DURING LOCA SIMULATION

| VALVE NO. | OPERATION | ELAPSED TIME | 8 MIN. | 1 HR. | 2 HR. | 5 HR. 5 MIN. | 6 HR. | 8 HR. | 9 HR. | 11 HR. | 12 HR. | 22 HR. | 4 DAYS | 15 DAYS | 30 DAYS | |
|-----------|-----------|--------------|--------|----------------------|----------------------|-----------------|----------------------|-------|-------|--------|--------|----------------------|-------------|---------------------|-----------------------|------------|
| | | | | | | | | | | | | | | | LC DE-EN | LC ENER. |
| 1 | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 0 | OK 0 0 | |
| 2 | CY LC | | OK | OK 210cc/ min. | OK 210cc/ min. | OK | OK 170cc/ min. | OK | OK | OK | OK | OK 230cc/ min. | OK 0 | OK(4) 15SCFH | (4) | 2SCFH |
| 3 | CY LC | | OK | OK 50cc/ min. | OK 15cc/ min. | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 20cc/ min. | (5) 0 (6) | |
| 4 | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 0 | OK 0 0 | |
| 5 | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 0 | OK 0 0 | |
| 6 | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 0 | OK 0 0 | |
| 7 | CY LC | | (1) | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | (2) 0 | (3) 0 | (5) 0 (7) | |
| 8 | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 65CFH | OK 12SCFH | OK 2.5 SCFH 2 SCFH | |
| 9AC | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | (3) 0 | (3) 0 | (5) (6) |
| 9DC | CY LC | | OK | OK 0 | OK 0 | OK | OK 0 | OK | OK | OK | OK | OK 0 | OK 0 | OK 0 | (5) 0 0 | |

SECTION 4

TABLE NO. 3 cont.

CY = Cycling
LC = Leak Check

ENER = Energized
DE-EN = De-energized

ALL VALVES (EXCEPT NO. 7) ENERGIZED AT .4 HOUR 35 MINUTES ELAPSED TIME. FOR VALVE NO. 7 SEE FOLLOWING NOTES 1 & 2.

LEAKAGE CHECKED DE-ENERGIZED EXCEPT AT 30 DAYS WHERE IT WAS CHECKED BOTH ENERGIZED AND DE-ENERGIZED.

- NOTE (1) : Valve had failed closed by blowing 2 amp fuse in line. By failing closed, it performed its safety function. Resistance measured to be 10 ohms from the coil lead to ground. Valve would shift but continued to blow fuses.
- NOTE (2) : Valve No. 7 was momentarily energized at each check until 4 day elapsed time when it was energized continuously for 5 minutes without blowing the fuse. The resistance from the coil leads to ground varied during this period from 200 to 1300 ohms.
- NOTE (3) : The valves blew 2 amp fuses. Resistances measured on valve Nos. 7 and 9 (AC) were low. These valves would shift but continued to blow fuses.
- NOTE (4) : Valve No. 2 showed a leakage of 15 SCFH. At the completion of the LOCA Simulation, the valve inspection revealed that the leakage was caused by the steel tank which was piped to port "B" to be rusted through. In other words, the leakage was not seat leakage but leakage of the vessel pressurized environment through port "B" to exhaust.
- NOTE (5) : The valves blew 2 amp fuses. When they were replaced with 2 amp slow-blow fuses, they worked satisfactorily.
- NOTE (6) : The valves blew the slow-blow fuses before a leakage check could be taken. Although no actual leakage was measured, there appeared to be no leakage.
- NOTE (7) : The valve could not be energized. Subsequent inspection revealed that the coil was open.

SUMMARY OF VALVES PERFORMANCE

| Valve No. | Baseline/ Functional Tests | Thermal Aging | Radiation | Wear Aging | Seismic Sim. & Vib. Endurance Tests | Accident Radiation | LOCA Simulation |
|-----------|----------------------------------|------------------|-----------|---------------|---|-----------------------|--------------------|
| 1 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 2 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 4 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 5 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 6 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 7 | Pass | Pass | Pass | Pass | Fail | Pass | Fail |
| 8 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 9 | Pass | Pass | Pass | Pass | Pass | Pass | Pass |

The valves which experienced minor difficulties explained by acceptable reasons, in the notes of this report are indicated as having, 'Pass' performance in this table.

SECTION 5 SUMMARY

Seven solenoid valves to represent six generic families of valves and two additional valves for information only were subjected to environmental exposure for the purpose of providing qualification for safety related use in Nuclear Power Generating Stations in accordance with the outline contained in 'ASCO Qualification Specification AQS-21678 Revision B'. This test outline is based on the suggestions contained in IEEE 323-1974 "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations", IEEE 382-1972 "IEEE Trial-Use Guide for Type Test of Class 1 Electrical Valve Operators for Nuclear Power Generating Stations", IEEE 344-1975 "IEEE Recommended Practices for Seismic Qualifications of Class 1E Equipment for Nuclear Power Generating Stations" and IEEE 382/ANSI N278.2.1 (Draft 3, Rev. 1, June 1977) "Draft American National Standard for the Qualification of Safety Related Valve Actuators".

The valves were subjected to accelerated aging by exposure to elevated temperature of 268°F for a period of 12 days and cycled every 6 hours (or a temperature of 295°F for a period of 100 hours and cycled every 2 hours). Baseline/functional tests were performed before, during and after this aging phase. This was followed by exposure to gamma radiation from a Cobalt-60 Source to an accumulated dose of 50 megarads. Baseline/functional tests were again performed after this radiation exposure. Seismic Simulation and vibration endurance tests were performed to demonstrate performance during simulated earthquake and plant induced vibration.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

Baseline/functional tests were performed during and after seismic simulation/vibration endurance tests. The valves were again exposed to gamma radiation from Cobalt-60 source to receive additional accumulated dose of 150 megarads. Baseline/functional tests were conducted after this radiation exposure.

The valves were finally subjected to a simulated loss-of-coolant accident (LOCA) by exposure to steam and chemical-spray for a period of 30 days. During the LOCA exposure, the valves were cycled and leakage checked. Baseline/functional tests were conducted after LOCA exposure.

RESULTS: The valves (except No. 7 which was tested for information only) successfully completed the sequential type tests and the baseline/functional tests. Minor anomalies observed are detailed and explained fully in text and/or footnotes of the tables in Section 4.

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700


Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

SECTION 6 CERTIFICATION

The undersigned certifies that this report presents a true account of the tests conducted and the results obtained.



Tejinder S. Sachdeva
Manager
Component Testing



George R. Dietz
President

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015
©Automatic Switch Co. 1987


APPENDIX A

ASCO QUALIFICATION SPECIFICATION AQS-21678/REVISION B

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015



QUALIFICATION SPECIFICATION FOR
AUTOMATIC SWITCH CO. (ASCO) OF FLORHAM PARK, N.J.
FOR SOLENOID VALVES

SPECIFICATION NO. AQS-21678/REV. B

PREPARED BY

THE COMPONENT TESTING DIVISION

OF

ISOMEDIX, INC.
PARSIPPANY, N.J.

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

CHICAGO DIVISION • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160

REVISION SHEET

Revised areas are highlighted for your convenience by a vertical black line in the margin.

| | | |
|--------|-----------|---|
| REV. A | PAGE 9-4 | Added note at bottom of page |
| | PAGE 9-12 | "until the end of 4 days" was "for a period of 14 hours" |
| | PAGE 9-13 | Added note at bottom of page |
| | PAGE 9-19 | Fig. 9-2 redrawn |

| | | |
|--------|--------------------------|------------------------------------|
| REV. B | PAGE I-1 (Appendix I) | Changed HVA-206-382 to HVA-206-832 |
|--------|--------------------------|------------------------------------|

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

TABLE OF CONTENTS FOR ASCO QUALIFICATION SPECIFICATION

| Section | Page |
|---|------|
| 1. Introduction..... | 1-1 |
| 2. Scope..... | 2-1 |
| 3. Equipment Description..... | 3-1 |
| 4. Installation Requirements..... | 4-1 |
| 4.1 Mounting Orientation..... | 4-1 |
| 4.2 Connections..... | 4-1 |
| 4.3 Interfaces..... | 4-1 |
| 4.4 Fixturing..... | 4-2 |
| 5. Specification of Valve Life..... | 5-1 |
| 5.1 Design Life..... | 5-1 |
| 5.2 Installed Life..... | 5-1 |
| 5.3 Qualified Life Objective..... | 5-1 |
| 6. Performance Specification..... | 6-1 |
| 6.1 Acceptable Limits of Operation..... | 6-1 |
| 6.2 Safety Function To be Demonstrated..... | 6-2 |
| 7. Loading..... | 7-1 |
| 7.1 Method of Load Simulation..... | 7-1 |
| 7.2 Verification of Operability..... | 7-1 |

| Section | Page |
|--|------|
| 8. Environmental Service Condition..... | 8-1 |
| 8.1 Normal and Abnormal Ambient..... | 8-1 |
| 8.1.1 Temperature..... | 8-1 |
| 8.1.2 Pressure..... | 8-1 |
| 8.1.3 Relative Humidity..... | 8-1 |
| 8.1.4 Chemical Composition of Environment.... | 8-1 |
| 8.1.5 Radiologic Environment..... | 8-1 |
| 8.1.6 Seismic and Vibration Environment..... | 8-1 |
| 8.2 Design Basis Event and Post DBE Service Conditions..... | 8-2 |
| 8.2.1 Temperature..... | 8-2 |
| 8.2.2 Pressure..... | 8-2 |
| 8.2.3 Relative Humidity..... | 8-2 |
| 8.2.4 Chemical Composition of Environment.... | 8-2 |
| 8.2.5 Radiologic Environment..... | 8-2 |
| 8.2.6 Resistance to Seismic Disturbance..... | 8-3 |
| 9. Environmental Qualification and Type-Test Procedure..... | 9-1 |
| 9.1 Qualification by Analysis..... | 9-1 |
| 9.2 Qualification by Prior Operating Experience..... | 9-1 |
| 9.3 Other Methods..... | 9-1 |
| 9.4 Qualification Type-Test Procedure..... | 9-1 |
| 9.4.1 Description of Test Items..... | 9-1 |
| 9.4.2 Type-test sequence..... | 9-2 |

| Section | Page |
|---|------|
| 9. - continued - | |
| 9.4.2.1 Inspection of Test Items..... | 9-2 |
| 9.4.2.2 Baseline Data Operation..... | 9-2 |
| 9.4.2.3 Aging Simulation..... | 9-3 |
| 9.4.2.4 DBE and Post DBE Environmental Simulation..... | 9-6 |
| 9.4.3 Post Test Inspection and Disassembly..... | 9-14 |
| 10. Submittals Prior to Test..... | 10.1 |
| 11. Reports and Certification..... | 11-1 |

LIST OF FIGURES

| Figure No. | Page |
|--|------|
| 8.1 Temperature and Pressure in Containment following DBE in PWR Plant..... | 8-4 |
| 8.2 Temperature and Pressure in Drywell following DBE in BWR Plant..... | 8-5 |
| 8.3 Temperature and Pressure in Containment Outside Drywell Following DBE in BWR Plant..... | 8-6 |
| 9.1 Seismic Qualification Required Input Motion..... | 9-18 |
| 9.2 Environmental Qualification Parameters for Loss-of-Coolant Accident (LOCA) Simulation..... | 9-19 |

LIST OF TABLES

| Table No. | Page |
|--|------|
| 9.1 Identification of Test Valves..... | 9-15 |

LIST OF APPENDICES

| Appendix Number | Page |
|--|---------|
| I. Valve Design Specification Sheets (VDSS)..... | I-1 |
| * II. Hypot Test Procedure..... | II-1 |
| Measurement of Insulation Resistance Procedure..... | II-1 |
| Individual Valve Test Procedures..... | II-4 ** |
| III. Installation & Maintenance Procedures... | III-1 |

* High voltage withstand potential
** SEE APPENDIX "B" FOR THESE PROCEDURES.

QUALIFICATION SPECIFICATION FOR
AUTOMATIC SWITCH CO. (ASCO) SOLENOID VALVES

1. INTRODUCTION

This specification for qualification is for the purpose of conducting a program, the ultimate aim of which is to provide generic qualification for a family of solenoid valves for use in Nuclear Power Generating Stations.

This document is divided into two basic parts: Part 1 is the equipment specification, including those items required for demonstration of qualification by the acceptable methods of analysis, operating experience, and type testing; Part 2 is the type test procedure defining the specific environmental parameters during the application of which the equipment must demonstrate satisfactory operation within the constraints of the specifications presented in the first part. Part 1 includes Items 1 through 8, Part 2 includes Items 9 through 11.

2. SCOPE

This program is being conducted in accordance with the suggestions and requirements contained in the following documents. (See Note 1)

- 2.1 IEEE 323-1974 "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations".
- 2.2 IEEE 382-1972 "IEEE Trial-Use Guide for Type Test of Class 1 Electrical Valve Operators for Nuclear Power Generating Stations".
- 2.3 IEEE 344-1975 "IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations".
- 2.4 The following ASCO documents for acceptance and production testing.
 - 2.4.1 Valve Design Specification Sheets
(Appendix I)
 - 2.4.2 Individual Valve Test Procedures
(Appendix II)
 - 2.4.3 Measurement of Insulation Resistance
Procedure (Appendix II)
 - 2.4.4 Hi-pot Test Procedure (Appendix II)
 - 2.4.5 Installation and Maintenance Sheets (I&M)
(Appendix III)

NOTE 1 - The suggestions and requirements contained in IEEE 382/ANSI N278.2.1 (Draft 3, Rev. 1, June 1977) "Draft American National Standard for the Qualification of Safety Related Valve Actuators" have been considered and, where applicable, have been incorporated in this program.

3. EQUIPMENT DESCRIPTION

The following equipment items are included in the qualification program. These items form the generic basis for selection of the specific test units.

3.1 HVA-206-380, HVA-206-381, HVA-208-448, HVA-208-266
HVA-206-832, HVA-210-036

REF: TP-3-046

Bulletin NP-206-380, etc.

VDSS 3.1

3.2 HVA-206-384, HVA-208-279, HVA-208-293

REF: TP-NP8316

Bulletin NP8316

VDSS 3.2

3.3 HVA-206-385, HVA-208-153

REF: TP-NP8320

Bulletin NP8320

VDSS 3.3

3.4 HVA-206-386

REF: TP-NP8321

Bulletin NP8321

VDSS 3.4

3.5 HVA-206-387

REF: TP-NP8323

Bulletin NP8323

VDSS 3.5

3.6 HVA-206-389, HVA-208-264, HVA-208-265, HVA-206-390
HVA-208-267, HVA-208-269

REF: TP-NP8344

Bulletin NP8344

VDSS 3.6

4. INSTALLATION REQUIREMENTS

Unless otherwise noted on the Valve Design Specification Sheet, (Appendix I), all valves will be mounted in position such that the axis of the coil remains in a vertical and upright position. Specific installation requirements are as follows:

- 4.1 Mounting Orientation - As noted above and/or on Valve Design Specification Sheet. Valves shall be mounted in the most severe orientation for seismic qualification.
- 4.2 Connections - All connecting tubing, fittings, and other devices utilized for directing process fluid to valve shall be of a material compatible with the specified operating environments, process fluid and valve body.

Tubing, fittings, conduit, etc., shall be of a material suitable for operation in the expected environments and be of sufficient size and quality so as not to degrade the safety function or classification of the valve.
- 4.3 Interfaces - Connections to the test items shall not degrade its safety function and shall be identified as to type and kind relative to its use for test purposes or suitably identified as an

acceptable device currently in use in a similar plant application. Where appropriate, all such interfaces shall have been proven qualified by a process similar to this.

- 4.4 Fixturing - Fixtures shall be provided to accommodate test valves in accordance with their particular mounting and installation requirements as defined above or in the Valve Design Specification Sheet. Fixtures shall be used solely to facilitate holding test valves and are not to amplify or dampen motions that the valves would be expected to experience in service. Fixtures shall not interfere with the safety function of valves.

5. SPECIFICATION OF VALVE LIFE

- 5.1 Design life - Unless otherwise noted, valves have a design life of 40 years, during which interval satisfactory performance shall be demonstrated for the design service conditions as presented in Section 8.
- 5.2 Installed life - Unless otherwise noted, valves have an installed life of 40 years and 40,000 cycles. Coils and elastomeric components shall be replaced every 4 years as noted in the Valve Design Specification Sheets (Appendix I) based on the solenoid valves being constantly energized at the service conditions presented in Section 8 and provided the installation requirements recommended in the ASCO I&M Sheets (Appendix III) have been met.
- 5.3 Qualified life objective - In accordance with the definition for qualified life as the period of time during which satisfactory performance can be demonstrated for the service conditions, it is the intention of this program to establish the qualified life of the subject valves as coinciding with the plant design life.

6. PERFORMANCE SPECIFICATION

6.1 Acceptable limits of operation

The acceptable limits of operation of the subject valves, unless otherwise specified, are as follows:

- 6.1.1 Valves to operate at 15% below rated AC voltage and for short periods (line surges, etc) at 10% above; battery operated 125 VDC valves to operate from 90-140 VDC.
- 6.1.2 Valves to operate at the minimum and maximum operating pressure differentials as stated in tables of Valve Design Spec. Sheets in Appendix I.
- 6.1.3 Valve coils to operate within the following limits of acceptability below which coils must be replaced.
 - 6.1.3.1 Insulation resistance: 1.0 megohm (minimum) at 500 VDC.
 - 6.1.3.2 Hypot: Leakage current less than 0.5 milliamp at twice rated voltage plus 1000 VAC applied for a period of one minute (Appendix II).

6.2 Safety function to be demonstrated

The required safety function performance verification objective to be demonstrated for the valves, unless otherwise specified, is as follows:

- 6.2.1 Valves are to operate at test voltage or current (85% of nominal AC volts or low DC voltage condition, i.e, 90 VDC for a 125 VDC application) at minimum and maximum operating pressure differential on demand under all postulated environmental conditions.
- 6.2.2 Valves are not to have a pressure build-up at a vented cylinder port or pressure decrease at a pressurized cylinder port in excess of 10% of the nominal inlet supply pressure under all postulated environmental conditions.

7. LOADING

7.1 Method of load simulation

The test valves will be subjected to operational loads by means suitable to duplicate or simulate actual operation with the process fluid as specified in the ASCO Valve Design Specification Sheet and at the valve design service conditions. The test set-up utilized in conjunction with load simulation, shall provide for continuous operation and monitoring of pertinent performance characteristics that include, but are not limited to the following parameters:

- A. Cycle rate and on-off time
- B. Cycle count
- C. Pressure at valve inlet and cylinder port(s)
- D. Seat leakage
- E. Electrical characteristics of coil, as applicable, .e.g. supply voltage, current, power
- F. External leakage
- G. Proper operation

7.2 Verification of operability

The methods and procedures utilized for load simulation operation shall be sufficient to provide proof of operability in accordance with the valve performance specification.

8. ENVIRONMENTAL SERVICE CONDITIONS

8.1 Normal and Abnormal Ambient

8.1.1 Temperature; 60°F to 140°F; Ave 120°F

8.1.2 Pressure; -.5 psig to 15 psig; Ave 0 psig

8.1.3 Relative Humidity; 0% to 100%; Ave 55%

8.1.4 Chemical Composition of environment -
Standard atmospheric composition.

8.1.5 Radiologic environment

| <u>Type</u> | <u>Dose</u> | <u>Dose Rate</u> |
|-------------|-------------------------------|---|
| gamma | 4.5×10^7 rads/40 yr. | 120 R/hr. |
| neutron | 8×10^{16} NVT | 6×10^7 n/cm ² -sec. |

8.1.6 Typical Seismic and Vibration Environment

8.1.6.1 Specification of Operating Basis

Earthquake (OBE). That earthquake which produces the vibratory motion for which those features of the nuclear power plant necessary for continued operation without undue risk to the health and safety of the public are designed to perform their safety function. Typical values, including normal loads, are as follows:

horizontal (both axes): 1.5g

vertical: 1.5g

8.1.6.2 Vibration endurance capability to be demonstrated for anticipated or specified plant locations.

8.2 Design Basis Event and Post DBE Service Conditions

- 8.2.1 Temperature - Maximum of 330°F for a total period of 6 hours followed by post DBE conditions of 200°F up to one year, as shown in Figures 8.1, 8.2 and 8.3.
- 8.2.2 Pressure - maximum of 70 psig; long term post DBE condition of 10 psig up to one year; also shown in Figures 8.1, 8.2 and 8.3.
- 8.2.3 Relative humidity - All steam environment for temperature in excess of 250°F; greater than 90% for other conditions.
- 8.2.4 Chemical composition of environment - Borated water spray with sodium thiosulfate and sodium hydroxide or demineralized water spray.
- 8.2.5 Radiologic Environment - as applicable

| <u>Type</u> | <u>Dose</u> | <u>Dose Rate</u> |
|-------------|------------------------|---|
| gamma | 1.2×10^8 rads | 4×10^6 R/hr to 1×10^2 R/hr after 1 year |
| neutron | NA | NA |

8.2.6 Resistance to Seismic Disturbance -
Safe Shutdown Earthquake (SSE)

That earthquake which produces the maximum vibratory motion for which all Category I structures, systems and components, are designed to perform their safety function. The specification requires demonstration of the ability to withstand the SSE and maintain functionability during and after. Typical values, including normal loads, are as follows:

horizontal (both axes): 3.0g

vertical: 3.0g




FIGURE 8.1 TEMPERATURE AND PRESSURE IN CONTAINMENT FOLLOWING DBE IN PWR PLANT




FIGURE 8.2 TEMPERATURE AND PRESSURE IN DRYWELL FOLLOWING DBE IN BWR PLANT




FIGURE 8.3 TEMPERATURE AND PRESSURE IN CONTAINMENT OUTSIDE DRYWELL
FOLLOWING DBE IN BWR PLANT

9. ENVIRONMENTAL QUALIFICATION AND TYPE-TEST PROCEDURE

9.1 Qualification by analysis - as applicable with suitable justification and documentation.

9.2 Qualification by prior operating experience as applicable with suitable justification and documentation.

9.3 Other methods

Where methods, techniques or procedures are utilized in the qualification process other than those expressly considered in the referenced documents, they shall be completely justified and substantiated in accordance with the philosophy and intent of the referenced documents.

9.4 Qualification Type-Test Procedure

9.4.1 Description of test items

The specific items to be tested are listed in Table 9.1, showing the particular phase associated with each. Reference is made to the Valve Design Specification Sheets for the valve classification and specifications. Any deviation in the actual test item is noted in the footnotes on the table.

9.4.2 Type-test sequence

Four general aging phases have been considered in this qualification program. They are: thermal aging, wear cycling, vibration and irradiation. This takes into account the particular maintenance schedule associated with the equipment wherein organic materials shall be replaced during the installed life period.

9.4.2.1 Inspection of test items

The test items shall be inspected prior to testing to assure that the unit has not been damaged by handling subsequent to manufacture.

Any damage to the unit or disparity between the inspection report and the production sign-off, shall be duly noted and recorded with appropriate follow-up action suggested.

9.4.2.2 Baseline data operation

The test items shall be operated to verify performance specifications and provide baseline data for comparison with performance at other

stages of the test. Specifically, baseline operation shall be performed before and after each phase of the type test, and consist of the following:

- A. insulation resistance of coil at 500 VDC in accordance with Procedure ELP-45 (ref. section 2.4.3 and 6.1.3),
- B. external leakage at 1-1/2 maximum operating pressure differential (MOPD).
- C. seat leakage at MOPD and minimum OPD or 1/4 PSIG for zero minimum valves.
- D. operate valve 10 times at MOPD and test voltage or current.
- E. operate from MOPD to minimum OPD at test voltage or current.

9.4.2.3 Aging Simulation

9.4.2.3.1 Thermal Aging - The basis for thermal aging was determined to be for a period of 4 years at an ambient temperature of 140°F.

This period is simulated by performing an accelerated aging program by exposing the valves to a temperature of 268°F for a period of 12 days. The test temperature and period have been calculated by the 10°C rule (Arrhenius Equation) using 4.4 years as the design life of the elastomer and coil materials.*

9.4.2.3.2 Radiation Aging - Background Thermal aging will be followed by radiation exposure to a cobalt-60 source of gamma radiation at a rate not to exceed 1 megarad per hour until a dose of 50 megarads has been received. Performance shall be monitored to insure that any transitory effects of radiation have been accounted for.

*All valves are to be pressurized at maximum operating pressure differential and energized continuously at nominal voltage. The valves are to be cycled (de-energize and energize) every 6 hours to simulate operation once a month at 140°F ambient temperature.

9.4.2.3.3 Wear Aging - At the conclusion of the radiation aging period, the valves will be cycled 40,000 times at maximum operating pressure differential in accordance with the requirements of 7.1. Baseline tests to be performed at the completion of the wear aging. Perform coil hi-pot test at this point.

9.4.2.3.4 Vibration Endurance

- A. Mount the valves to the shaker table in accordance with installation and orientation requirements.
- B. Attach all electrical and pneumatic supply and control lines in accordance with connection requirements and in conjunction with the interface definitions.
- C. Control the table input motion using accelerometers located at the valve mounting surface.

D. Operate the valve under load before, during and after the test with sufficient monitoring equipment to verify functional operability.

E. Perform vibration endurance testing by subjecting the valves to a total of 10^6 cycles, separated evenly between all three orthogonal axes, by vibrating at a non-resonant frequency between 50 and 100 Hz at an input acceleration level of at least 0.75g. Operate the valve through one complete cycle, at maximum operating pressure differential, every 15 minutes during the exposure period. Perform baseline tests.

9.4.2.4 DBE and Post DBE Environmental Simulation

9.4.2.4.1 Radiation Simulation - Expose the test valves to the DBE radiation dose of 150 megarads in a gamma radiation environment of cobalt-60 at a dose

rate not to exceed 1 megarad per hour. Perform operational tests, as required, to account for transitory effects. Perform baseline tests.

- 9.4.2.4.2 Seismic Event Simulation -
- Mount the test valves as in 9.4.2.3.4 above and provide for performance verification by suitable instrumentation. Perform the seismic simulation by applying:
- 9.4.2.4.2.1 A low level (approximately .2g) frequency sweep search for resonance from 1-35 Hz.
- 9.4.2.4.2.2 OBE vibratory motion as follows:
- Expose the valve to two sinusoidal sweeps at 2/3 of the RIM levels shown in Figure 9-1, in each orthogonal axis. Each sweep shall be from 1-33-1 Hz at a rate of 1 octave per

minute. One sweep shall be performed with the valve open and one with the valve closed. The OBE sweeps in each axis may be followed by the SSE test in that axis. If desired, the actuator may be instrumented, and the data from this test used for the resonance search information. (A general requirement is to perform five OBE tests prior to the SSE. The two sine sweeps are designed to provide the mechanical aging of five OBE's).

9.4.2.4.2.3 SSE vibratory motion as follows:

Expose the valve to a series of single frequency sinusoidal tests at the 1/3 octave interval dwell point frequencies indicated on Figure 9-1. At each dwell test frequency the minimum peak acceleration shall be the RIM value shown in Figure 9-1.

* Record the g-levels at which the cylinder port pressure changes by 0,5 & 10% of the nominal value, which is zero when de-energized and full inlet pressure when energized. The maximum peak acceleration shall be a change of 10% from nominal pressure at the cylinder port, up to 10g maximum. The duration of each dwell will be the period of time required to operate the valve through one complete open/close cycle or 15 seconds, whichever is longer. The open/close cycle will start after the prescribed acceleration level is reached. Apply motion at the same frequencies and acceleration limits in each of the three orthogonal axes separately. Perform baseline tests.

* This testing goes beyond type testing and defines a fragility level at which the valve may be considered to still function properly. This level is dependent on customer requirements as to the pilot valve cylinder port pressure, which causes the main device to shift position.

9.4.2.4.3 Loss-of-Coolant Accident

Environmental Simulation - The test units previously subjected to the above exposures will be installed inside a pressure vessel and subjected to a 30-day exposure to steam and chemical-spray simulating a LOCA event and post-LOCA cool-down.

The electrical lead wires and pneumatic connections for energizing, pressurizing and output monitoring are to be brought out of the chamber and connected to the monitoring equipment for recording the output of the unit during exposure cycle.

Prior to actually starting the exposure, but with the unit in place, the chamber shall be pressurized to check for sealing and the spray system operated to insure proper functioning.

Cycling of the valves shall be performed and measurements of performance made, as in the baseline tests, to insure proper functioning before proceeding.

The LOCA simulation event is to follow the suggestions of IEEE-323-1974 "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations", IEEE 382-1972 "IEEE Trial-Use Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations", and Draft 3, Revision 1, American National Standard for the Qualification of Safety Related Valve Actuators, IEEE 382/ANSI 278.2.1, and in particular, the pressure/temperature profile shown in Figure 9.2. Specifically, steam is to be rapidly admitted, increasing

the temperature from room ambient to 300°F within 60 seconds and to 346°F within 5 minutes. This condition will be maintained for a period of one hour. The first transient is followed by a one-hour drop period to 135°F and a dwell period of one hour maintained at that temperature. The second transient is to commence with a temperature rise to 300°F in 60 seconds and to 346°F within 5 minutes, followed by a dwell period of three hours at 346°F. This dwell period will be followed by a drop in temperature from 346° to 320°F within 30 minutes. This drop is followed by a dwell period of three hours at 320°F. The temperature will then be dropped from 320°F to 250°F within a 30 minute period. This will be followed by a dwell period of 250°F until the end of 4 days,

followed by a drop in temperature from 250°F to 200°F within 30 minutes, followed by a dwell time at that temperature to the conclusion of the test of 30 days. The valves are to be cycled at the times indicated on Figure 9.2.*

A chemical solution, consisting of 3000 ppm of boron as boric acid in solution with 0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH between 9 and 11 at room temperature, is to be sprayed into the chamber after reaching 280°F during the first transient and maintained throughout the entire 30 day period. The spray rate will correspond to 0.306 gpm per square foot of area covered by the spray. The pH of the solution is to be periodically checked and new solution added as

*The valves are assumed to be constantly energized during the normal plant operation. They will, for this test, be energized for 4 hours (to produce coil saturation) prior to the first transient. When the vessel temperature reaches 280°F the valves will perform their safety function by closing (de-energize). They then will be cycled "open - close" at times indicated on p. 9-19.

required to maintain the pH. The pressure followed during this exposure cycle may correspond to the saturation pressure for the particular temperature.

At the conclusion of the 30 day LOCA simulation event, the test valves are to be examined, cycled and inspected prior to removal from the test chamber. Baseline tests and coil hi-pot tests are also to be performed. (Reference Section 6.1.3 and Appendix II.

9.4.3 Post Test Inspection and disassembly -

After completion of the entire test program, the valves shall be disassembled and visually inspected for degradation resulting from the exposure environments. Photographs will be taken at suitable periods during and after the tests as a permanent record of the physical condition of the test valves.

TABLE 9.1

IDENTIFICATION OF TEST VALVES

| <u>VALVE (REF. VDSS)</u> | <u>TEST VALVE NO.</u> | <u>DESCRIPTION</u> | <u>PHASE</u> |
|----------------------------|-----------------------|---|-------------------------------|
| HVA-206-380-3RF | 4 | AC, Class H screw terminal coil, Nema 6 solenoid enclosure, resilient seats, normally closed construction. (Ref. VDSS 3.1, Appendix I) | Para. 9.4 Type Test Procedure |
| HVA-206-381-6F (Note 1) | 1 | DC, Class H leaded coil, Nema 4, 7, and 9 solenoid enclosure, metal seats, normally closed construction. (Ref. VDSS 3.1, Appendix I) | Para. 9.4 Type Test Procedure |
| NP831665E | 6 | DC, Class H leaded coil, Nema 4, 7, and 9 solenoid enclosure, normally closed construction. (Ref. VDSS 3.2, Appendix I) | Para. 9.4 Type Test Procedure |
| NP8320A184E | 5 | AC, Class H leaded coil, Nema 6 solenoid enclosure, normally closed construction. (Ref. VDSS 3.3, Appendix I) | Para. 9.4 Type Test Procedure |
| NP8321A5E | 8 | DC, Class H leaded coil, Nema 4, 7, and 9 solenoid enclosure, normally closed construction. (Ref. VDSS 3.4) | Para. 9.4 Type Test Procedure |
| NP8323A39E | 9 | (Solenoid A) AC, Class H leaded coil, (Solenoid B) DC, Class H screw terminal coil, Nema 6 solenoid enclosures, normally closed construction, (Ref. VDSS 3.5, Appendix I) | Para. 9.4 Type Test Procedure |


| <u>VALVE (REF. VDSS)</u> | <u>TEST VALVE NO.</u> | <u>DESCRIPTION</u> | <u>PHASE</u> |
|--------------------------|-----------------------|---|----------------------------------|
| NP8344A71E (Note 2) | 2 | DC, Class H leaded coil, Nema 4, 7, and 9 solenoid enclosure. (Ref. VDSS 3.6, Appendix I) | Para. 9.4 Type Test Procedure |
| XFT831654V | 3 | Note 3 | Para. 9.4 Type Test Procedure |
| HV-202-300-2RF | 7 | Note 4 | Para. 9.4 Type Test Procedure |

NOTE 1 - Melamine epoxy painted solenoid enclosure

NOTE 2 - Viton main discs (2) and 'U' Cups (2)

NOTE 3 - AC, Class F (molded) leaded coil, Nema 1 solenoid enclosure (melamine epoxy paint) normally closed construction, viton elastomers. This valve was included to obtain information on Class F molded coils and viton elastomers.


NOTE 4 - DC, Class H leaded coil, Nema 1 solenoid enclosure (melamine epoxy paint) normally closed construction, Buna 'N' elastomers. This valve was included to obtain information on the type of solenoid utilized on this valve and Buna 'N' elastomers.



DWELL POINTS

SEISMIC QUALIFICATION REQUIRED INPUT MOTION

FIGURE 9.1



61-6

FIG. 9.2 ENVIRONMENTAL QUALIFICATION PARAMETERS FOR LOSS-OF-COOLANT ACCIDENT (LOCA) SIMULATION

10. SUBMITTALS PRIOR TO TEST

10.1 Diagrams of mounting, loading and seismic fixtures

10.2 Detailed test procedures, as applicable, including monitoring technique and acceptance criteria.

10.3 Installation, instrumentation, interconnection and interface diagrams, as applicable.

10.4 Summary of qualification programs previously performed, as applicable.

10.5 Justification for analysis

11. REPORTS AND CERTIFICATION

At the completion of the entire test program, a report shall be written documenting the program, procedures, methods and results obtained. The report shall be certified as to radiation, seismic and environmental parameter values and also contain a listing of test equipment, recording equipment with calibration date, pertinent diagrams and test data sheets.

All strip chart records are to be maintained and portions may be reproduced in the report, as required.

Comparisons between baseline data and test data are to be made as required and presented as appendices to the main body of the report.

A summary of the results shall be presented, including the conclusion whether the solenoid valves were qualified or not.

APPENDIX I

I-1

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.1 HVA-206-380, HVA-206-381, HVA-208-448, HVA-208-266,
HVA-206-832, HVA-210-036, (Bulletin NP206-380, etc.)

3.1.1 Description: Three-way, direct acting
solenoid valve with packless construc-
tion.

3.1.2 Application: Pilot valve controlling
oil free instrument quality air.

3.1.3 Specifications:

3.1.3.1 Available in normally open,
normally closed and universal
construction

3.1.3.2 1/8 to 1/2 NPT

3.1.3.3 Brass, steel, and austenitic
stainless steel bodies

3.1.3.4 Metal or resilient seated

3.1.3.5 NEMA 6 and NEMA 4, 7 & 9
solenoid enclosures with 3/4
NPT conduit connection

3.1.3.6 Internal parts in contact with
fluid are Type 300 and 400
stainless steel

3.1.3.7 Ethylene propylene elastomers

3.1.3.8 20 watts, A.C., 35.1 watts DC

3.1.3.9 Class H coil

3.1.3.10 Process fluid: instrument
quality, oil free air

3.1.3.11 Ambient: 60-140°F

3.1.3.12 Installation: solenoid
vertical and upright

3.1.3.13 Normal maintenance schedule:
4 years. (Replacement of
coils and elastomeric components).
(Installation and maintenance
sheet packed and shipped with each
valve).

3.1.3.14 Safe body working pressure: 600 psig
for brass construction, 1500 psig
for steel and stainless steel con-
structions.

SPECIFIC VALVE DESIGNATIONS INCLUDED IN VDSS 3.1 GENERIC FAMILY

| NEMA TYPE 4,7,9 SOLENOID ENCLOSURE | NEMA TYPE 6 SOLENOID ENCLOSURE | PIPE | PORT | WATTS | | C V | MOPD | BODY MATERIAL |
|---|---|------|------|-------|------|--------|------|---------------|
| | | | | AC | DC | | | |
| HVA206-832-1 | HVA-206-380-1 | 1/8 | 3/16 | 20 | | .35 | 200 | Brass |
| -2 | -2 | 1/4 | 3/16 | 20 | | .35 | 200 | Brass |
| -3 | -3 | 1/4 | 1/4 | 20 | | .45 | 150 | Brass |
| -4 | -4 | 3/8 | 3/16 | 20 | | .35 | 200 | Brass |
| -5 | -5 | 3/8 | 1/4 | 20 | | .45 | 150 | Brass |
| -6 | -6 | 3/8 | 5/16 | 20 | | .75 | 100 | Brass |
| -7 | -7 | 1/2 | 5/16 | 20 | | .75 | 100 | Brass |
| HVA210-036-1 | HVA208-266-1 | 3/8 | 3/16 | 20 | | .35 | 200 | Steel |
| -2 | -2 | 3/8 | 1/4 | 20 | | .45 | 150 | Steel |
| -3 | -3 | 3/8 | 5/16 | 20 | | .75 | 100 | Steel |
| -4 | -4 | 1/2 | 5/16 | 20 | | .75 | 100 | Steel |
| -5 | -5 | 1/2 | 5/16 | 20 | | .75 | 100 | St. Steel |
| HVA206-381-1 | | 1/8 | 3/16 | | 35.1 | .35 | 200 | Brass |
| -2 | | 1/4 | 3/16 | | 35.1 | .35 | 200 | Brass |
| -3 | | 1/4 | 1/4 | | 35.1 | .45 | 150 | Brass |
| -4 | | 3/8 | 3/16 | | 35.1 | .35 | 200 | Brass |
| -5 | | 3/8 | 1/4 | | 35.1 | .45 | 150 | Brass |
| -6 | | 3/8 | 5/16 | | 35.1 | .75 | 125 | Brass |
| -7 | | 1/2 | 5/16 | | 35.1 | .75 | 125 | Brass |
| HVA208-448-1 | | 3/8 | 3/16 | | 35.1 | .35 | 200 | Steel |
| -2 | | 3/8 | 1/4 | | 35.1 | .45 | 150 | Steel |
| -3 | | 3/8 | 5/16 | | 35.1 | .75 | 125 | Steel |
| -4 | | 1/2 | 5/16 | | 35.1 | .75 | 125 | Steel |
| -5 | | 1/2 | 5/16 | | 35.1 | .75 | 125 | St. Steel |

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.2 HVA-206-384, HVA-208-279, HVA-208-293

(Bulletin NP8316)

- 3.2.1 Description: Three-way, internal pilot, diaphragm, solenoid valve.
- 3.2.2 Application: Pilot valve controlling oil free instrument quality air.
- 3.2.3 Specifications
 - 3.2.3.1. Available in normally closed and normally open construction
 - 3.2.3.2 3/8 to 1 NPT
 - 3.2.3.3 Brass body
 - 3.2.3.4 Resilient seated
 - 3.2.3.5 NEMA 6 and NEMA 4, 7 & 9 solenoid enclosure with 3/4 NPT conduit connection
 - 3.2.3.6 Internal parts in contact with fluid are Type 300 and 400 stainless steel
 - 3.2.3.7 Ethylene propylene elastomers
 - 3.2.3.8 10.5 Watts AC, 17.4 Watts DC
 - 3.2.3.9 Class H coil

3.2.3.10 Process fluid: instrument
quality oil free air

3.2.3.11 Ambient: 60-140°F

3.2.3.12 Installation: can be installed
in any position without affect-
ing operation

3.2.3.13 Normal maintenance schedule:
4 years. (Replacement of coils
and elastomeric components).
(Installation and maintenance
sheet packed and shipped with
each valve).

3.2.3.14 Safe body working pressure
300 psig (250 psig for 1 NPT)

SPECIFIC VALVE DESIGNATIONS INCLUDED IN VDSS 3.2 GENERIC FAMILY

| NEMA TYPE 4,7,9 SOLENOID ENCLOSURE | NEMA TYPE 6 SOLENOID ENCLOSURE | PIPE | PORT | WATTS | | C v | MOPD | | MIN. | FORM |
|---|---|------|-------|-------|------|--------|------|------|------|------|
| | | | | A.C. | D.C. | | A.C. | D.C. | | |
| NP831655E | NP831654E | 3/8 | 5/8 | 10.5 | 17.4 | 3 | 175 | 175 | 10 | N.C. |
| NP831665E | NP831664E | 1/2 | 5/8 | 10.5 | 17.4 | 4 | 175 | 175 | 10 | N.C. |
| NP8316A75E | NP8316A74E | 3/4 | 11/16 | 10.5 | 17.4 | 5.5 | 175 | 175 | 10 | N.C. |
| NP8316E35E | NP8316E34E | 1 | 1 | 10.5 | 17.4 | 13 | 175 | 175 | 10 | N.C. |
| NP831657E | NP831656E | 3/8 | 5/8 | 10.5 | 17.4 | 3 | 175 | 175 | 10 | N.O. |
| NP831667E | NP831666E | 1/2 | 5/8 | 10.5 | 17.4 | 4 | 175 | 175 | 10 | N.O. |
| NP8316A77E | NP8316A76E | 3/4 | 11/16 | 10.5 | 17.4 | 5.5 | 175 | 175 | 10 | N.O. |
| NP8316E37E | NP8316E36E | 1 | 1 | 10.5 | 17.4 | 13 | 175 | 175 | 10 | N.O. |

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.3 HVA-206-385, HVA-208-153 (Bulletin NP8320)

3.3.1 Description: Three-way, direct acting, compact design with all three connections in valve body for in-line piping.

3.3.2 Application: Pilot valve controlling oil free instrument quality air.

3.3.3 Specifications

3.3.3.1 Available in normally open, normally closed, and universal construction.

3.3.3.2 1/4 NPT

3.3.3.4 Resilient seated

3.3.3.5 NEMA 6 and NEMA 4, 7 & 9 solenoid enclosures with 3/4 NPT conduit connection.

3.3.3.6 Internal parts in contact with fluid are Type 300 and 400 stainless steel

3.3.3.7 Ethylene propylene elastomers

3.3.3.8 10.5 Watts AC, 17.4 Watts DC

3.3.3.9 Class H coil

3.3.3.10 Process fluid: instrument quality oil free air

3.3.3.11 Ambient: 60-140°F

3.3.3.12 Installation: can be installed in any position without affecting operation

3.3.3.13 Normal maintenance schedule: 4 years. (Replacement of coils and elastomeric components). (Installation and maintenance sheet packed and shipped with each valve).

3.3.3.14 Safe body working pressure: 500 psig

SPECIFIC VALVE DESIGNATIONS INCLUDED IN VDSS 3.3 GENERIC FAMILY

| NEMA TYPE 4, 7, 9, SOLENOID ENCLOSURE | NEMA TYPE 6 SOLENOID ENCLOSURE | PIPE | PORT | WATTS | | C v | MOPD | | MIN | FORM | BODY MATERIAL |
|--|---|------|-------|-------|------|--------|------|------|-----|------|------------------|
| | | | | A.C. | D.C. | | A.C. | D.C. | | | |
| NP8320A183E | NP8320A182E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 175 | 160 | 0 | N.C. | Brass |
| NP8320A185E | NP8320A184E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 150 | 115 | 0 | N.C. | Brass |
| NP8320A187E | NP8320A186E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 85 | 60 | 0 | N.C. | Brass |
| NP8320A189E | NP8320A188E | 1/4 | 11/64 | 10.5 | 17.4 | .38 | 40 | 25 | 0 | N.C. | Brass |
| NP8320A193E | NP8320A192E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 175 | 135 | 0 | N.O. | Brass |
| NP8320A195E | NP8320A194E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 140 | 100 | 0 | N.O. | Brass |
| NP8320A197E | NP8320A196E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 70 | 55 | 0 | N.O. | Brass |
| NP8320A199E | NP8320A198E | 1/4 | 11/64 | 10.5 | 17.4 | .38 | 40 | 30 | 0 | N.O. | Brass |
| NP8320A173E | NP8320A172E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 125 | 75 | 0 | U | Brass |
| NP8320A175E | NP8320A174E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 75 | 60 | 0 | U | Brass |
| NP8320A177E | NP8320A176E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 35 | 25 | 0 | U | Brass |
| NP8320A179E | NP8320A178E | 1/4 | 11/64 | 10.5 | 17.4 | .38 | 20 | 12 | 0 | U | Brass |
| NP832064E | NP832063E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 125 | 125 | 0 | N.C. | St. St. |
| NP832094E | NP832093E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 110 | 65 | 0 | N.C. | St. St. |
| NP832066E | NP832065E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 40 | 40 | 0 | N.C. | St. St. |
| NP832068E | NP832067E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 125 | 125 | 0 | N.O. | St. St. |
| NP832096E | NP832095E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 110 | 65 | 0 | N.O. | St. St. |
| NP832070E | NP832069E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 40 | 40 | 0 | N.O. | St. St. |
| NP832058E | NP832057E | 1/4 | 1/16 | 10.5 | 17.4 | .09 | 100 | 65 | 0 | U | St. St. |
| NP832060E | NP832059E | 1/4 | 3/32 | 10.5 | 17.4 | .15 | 40 | 40 | 0 | U | St. St. |
| NP832062E | NP832061E | 1/4 | 1/8 | 10.5 | 17.4 | .31 | 30 | 20 | 0 | U | St. St. |

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.4 HVA-206-386 (Bulletin NP8321)

3.4.1 Description: Three-way, internal pilot operated solenoid valve.

3.4.2 Application: Pilot valve controlling oil free instrument quality air.

3.4.3 Specifications

3.4.3.1 Available in normally open and normally closed construction

3.4.3.2 1/4 & 3/8 NPT

3.4.3.3 Brass body

3.4.3.4 Resilient seated

3.4.3.5 NEMA 6 and NEMA 4, 7, & 9 solenoid enclosures with 3/4 NPT conduit connection

3.4.3.6 Internal parts in contact with fluid are Type 300 and 400 stainless steel

3.4.3.7 Ethylene propylene elastomers

3.4.3.8 10.5 watts AC, 17.4 watts DC

3.4.3.9 Class H coil

3.4.3.10 Process fluid: instrument quality oil free air

3.4.3.11 Ambient: 60-140°F

3.4.3.12 Installation: can be installed in any position without affecting operation

3.4.3.13 Normal maintenance schedule: 4 years. (Replacement of coils and elastomeric components). (Installation and maintenance sheet packed and shipped with each valve).

3.4.3.14 Safe body working pressure: 500 psig

SPECIFIC VALVE DESIGNATIONS INCLUDED IN VDSS 3.4 GENERIC FAMILY

| <u>NEMA TYPE</u> 4,7,9, SOLENOID <u>ENCLOSURE</u> | <u>NEMA TYPE</u> 6 SOLENOID <u>ENCLOSURE</u> | <u>PIPE</u> | <u>PORT</u> | <u>WATTS</u> | | <u>C</u> <u>v</u> | <u>MOPD</u> | | <u>MIN</u> | <u>FORM</u> |
|--|---|-------------|-------------|--------------|-------------|----------------------|-------------|-------------|------------|-------------|
| | | | | <u>A.C.</u> | <u>D.C.</u> | | <u>A.C.</u> | <u>D.C.</u> | | |
| NP8321A5E | NP8321A1E | 1/4 | ① | 10.5 | 17.4 | ② | 150 | 150 | 10 | N.C. |
| NP8321A6E | NP8321A2E | 3/8 | ① | 10.5 | 17.4 | ② | 150 | 150 | 10 | N.C. |
| NP8321A7E | NP8321A3E | 1/4 | ① | 10.5 | 17.4 | ② | 150 | 150 | 10 | N.O. |
| NP8321A8E | NP8321A4E | 3/8 | ① | 10.5 | 17.4 | ② | 150 | 150 | 10 | N.O. |

① 9/32 (pressure) & 11/32 (exhaust) ② 0.8 (pressure) & 1.2 (exhaust)

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.5 HVA-206-387 (Bulletin NP8323)

- 3.5.1 Description: Three-way, direct acting, solenoid valve with redundant solenoids.
- 3.5.2 Application: Pilot valves controlling oil free instrument quality air.
- 3.5.3 Specifications
 - 3.5.3.1 Available in normally open and normally closed construction
 - 3.5.3.2 1/4 NPT
 - 3.5.3.3 Brass body
 - 3.5.3.4 Resilient seated
 - 3.5.3.5 NEMA 6 and NEMA 4, 7 & 9 solenoid enclosures with 3/4 NPT conduit connection
 - 3.5.3.6 Internal parts in contact with fluid are Type 300 and 400 stainless steel
 - 3.5.3.7 Ethylene propylene elastomers
 - 3.5.3.8 10.5 watts AC, 17.4 watts DC
 - 3.5.3.9 Class H coil
 - 3.5.3.10 Process fluid: instrument quality oil free air
 - 3.5.3.11 Ambient: 60-140°F

3.5.3.12 Installation: can be installed in any position without affecting operation.

3.5.3.13 Normal maintenance schedule: 4 years. (Replacement of coils and elastomeric components). (Installation and maintenance sheet packed and shipped with each valve).

3.5.3.14 Safe body working pressure: 500 psig

SPECIFIC VALVE DESIGNATION INCLUDED IN VDSS 3.5 GENERIC FAMILY

| <u>NEMA TYPE</u> 4,7,9, <u>SOLENOID</u> <u>ENCLOSURE</u> | <u>NEMA TYPE</u> 6 <u>SOLENOID</u> <u>ENCLOSURE</u> | <u>PIPE</u> | <u>PORT</u> | <u>WATTS</u> | | | <u>C</u> <u>v</u> | <u>MOPD</u> | <u>MIN.</u> | <u>FORM</u> |
|---|--|-------------|-------------|--------------|--------------|-------------|----------------------|-------------|-------------|-------------|
| | | | | <u>SOL.A</u> | <u>SOL.B</u> | | | | | |
| | | | | <u>A.C.</u> | <u>A.C.</u> | <u>D.C.</u> | | | | |
| NP8323A20E | NP8323A19E | 1/4 | 1/16 | 10.5 | 10.5 | | .09 | 125 | 0 | N.C. |
| NP8323A22E | NP8323A21E | 1/4 | 3/32 | 10.5 | 10.5 | | .15 | 110 | 0 | N.C. |
| NP8323A24E | NP8323A23E | 1/4 | 1/8 | 10.5 | 10.5 | | .31 | 40 | 0 | N.C. |
| NP8323A28E | NP8323A27E | 1/4 | 1/16 | 10.5 | 10.5 | | .09 | 125 | 0 | N.O. |
| NP8323A30E | NP8323A29E | 1/4 | 3/32 | 10.5 | 10.5 | | .15 | 110 | 0 | N.O. |
| NP8323A32E | NP8323A31E | 1/4 | 1/8 | 10.5 | 10.5 | | .31 | 40 | 0 | N.O. |
| NP8323A36E | NP8323A35E | 1/4 | 1/16 | 10.5 | | 17.4 | .09 | 125 | 0 | N.C. |
| NP8323A38E | NP8323A37E | 1/4 | 3/32 | 10.5 | | 17.4 | .15 | 110 | 0 | N.C. |
| NP8323A40E | NP8323A39E | 1/4 | 1/8 | 10.5 | | 17.4 | .31 | 40 | 0 | N.C. |
| NP8323A44E | NP8323A43E | 1/4 | 1/16 | 10.5 | | 17.4 | .09 | 125 | 0 | N.O. |
| NP8323A46E | NP8323A45E | 1/4 | 3/32 | 10.5 | | 17.4 | .15 | 110 | 0 | N.O. |
| NP8323A48E | NP8323A47E | 1/4 | 1/8 | 10.5 | | 17.4 | .31 | 40 | 0 | N.O. |

VALVE DESIGN SPECIFICATION SHEET

VDSS 3.6 HVA-206-389, HVA-208-264, HVA-208-265, HVA-206-390, HVA-208-267, HVA-208-269 (Bulletin NP8344)

3.6.1 Description: Four-way, two position, internal pilot operated, poppet type solenoid valve.

3.6.2 Application: Pilot valve controlling oil free instrument quality air.

3.6.3 Specifications

3.6.3.1 Available in single and dual solenoid construction

3.6.3.2 1/4 - 1 NPT

3.6.3.3 Brass body

3.6.3.4 Resilient seated

3.6.3.5 NEMA 6 and NEMA 4, 7 & 9 solenoid enclosures with 3/4 NPT conduit connection

3.6.3.6 Internal parts in contact with fluid are Type 300 and 400 stainless steel.

3.6.3.7 Ethylene propylene elastomers

3.6.3.8 10.5 watt AC, 17.4 watt DC

3.6.3.9 Class H coil

3.6.3.10 Process fluid: instrument quality oil free air

3.6.3.11 Ambient: 60-140°F

3.6.3.12 Installation: can be installed in any position without affecting operation

3.6.3.13 Normal maintenance schedule: 4 years. (Replacement of coils and elastomeric components). (Installation and maintenance sheet packed and shipped with each valve).

3.6.3.14 Safe body working pressure:
1/4 NPT - 500 psig; 3/8 NPT
& 1/2 NPT - 480 psig; 3/4 NPT
& 1 NPT - 300 psig.

SPECIFIC VALVE DESIGNATION INCLUDED IN VDSS 3.6 GENERIC FAMILY

| <u>NEMA TYPE</u> 4,7,9, <u>SOLENOID</u> <u>ENCLOSURE</u> | <u>NEMA TYPE</u> 6 <u>SOLENOID</u> <u>ENCLOSURE</u> | <u>PIPE</u> | <u>PORT</u> | <u>WATTS</u> | | <u>C</u> <u>v</u> | <u>MOPD</u> | | <u>MIN</u> | <u>TYPE</u> |
|---|--|-------------|-------------|--------------|-------------|----------------------|-------------|-------------|------------|-----------------|
| | | | | <u>A.C.</u> | <u>D.C.</u> | | <u>AC</u> | <u>D.C.</u> | | |
| NP8344A71E | NP8344A70E | 1/4 | 1/4 | 10.5 | 17.4 | 0.53 | 125 | 125 | 10 | Single Solenoid |
| NP8344A73E | NP8344A72E | 3/8 | 3/8 | 10.5 | 17.4 | 1.3 | 125 | 125 | 10 | Single Solenoid |
| NP8344A75E | NP8344A74E | 1/2 | 3/8 | 10.5 | 17.4 | 1.3 | 125 | 125 | 10 | Single Solenoid |
| NP8344A77E | NP8344A76E | 3/4 | 3/4 | 10.5 | 17.4 | 5.5 | 125 | 125 | 10 | Single Solenoid |
| NP8344A79E | NP8344A78E | 1 | 3/4 | 10.5 | 17.4 | 5.5 | 125 | 125 | 10 | Single Solenoid |
| NP8344A58E | NP8344B46E | 1/4 | 1/4 | 10.5 | 17.4 | 0.53 | 350 | 125 | 10 | Dual Solenoid |
| NP8344B62E | NP8344B50E | 3/8 | 3/8 | 10.5 | 17.4 | 1.3 | 300 | 125 | 10 | Dual Solenoid |
| NP8344B64E | NP8344B52E | 1/2 | 3/8 | 10.5 | 17.4 | 1.3 | 300 | 125 | 10 | Dual Solenoid |
| NP8344B66E | NP8344B54E | 3/4 | 3/4 | 10.5 | 17.4 | 5.5 | 300 | 125 | 10 | Dual Solenoid |
| NP8344B68E | NP8344B56E | 1 | 3/4 | 10.5 | 17.4 | 5.5 | 300 | 125 | 10 | Dual Solenoid |

APPENDIX II

II-1

2.4.3 Measurement of Insulation Resistance

The solenoid insulation resistance is to be measured prior to the qualification testing and at each baseline test. Insulation resistance is to be measured using a Freed Model 1620 Megohmmeter to be supplied by Automatic Switch Company. The test will be performed in accordance with Automatic Switch Company Procedure ELP-45.

2.4.4 Hypot Test

The Hypot test is to be performed prior to the qualification testing, at the end of the aging sequence, and at the end of the LOCA simulation. Measurement is to be made using an Associated Research Type 404 Hypot Tester to be supplied by Automatic Switch Company. The test voltage is to be twice rated voltage plus 1000 volts AC applied for one minute (the coil leads are to be twisted together and placed in contact with one of the Hypot output leads, the remaining hypot output lead is to be placed in contact with a clean, paint-free metallic part of the solenoid housing).

Automatic Switch Co.

VALVE ENGINEERING LABORATORY


| | | | |
|-------------------------------|------------------------------|-----------------|---------------|
| ACFW <input type="checkbox"/> | ACV <input type="checkbox"/> | ISSUED BY | NO. |
| ACM <input type="checkbox"/> | ACV <input type="checkbox"/> | L. R. Gauthreau | ELP-45 |
| ACH <input type="checkbox"/> | ACA <input type="checkbox"/> | APP. BY | CHANGE LETTER |
| ACV <input type="checkbox"/> | ACV <input type="checkbox"/> | | A |
| <input type="checkbox"/> | <input type="checkbox"/> | DATE ISSUED | PAGE 1 OF 2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 5/17/60 | |

TITLE OPERATION OF FREED MODEL 1620
MEGOHMMETER

PURPOSE:

To establish the method of operating the Freed Model 1620 Megohmmeter used for measuring insulation resistance.


PROCEDURE:



1. Turn Power switch to the "On" position. Allow five minutes warm up period.
2. Turn the Range Selector switch to the "Zero Adjust" position.
3. Press the Push button and turn the "Zero Adjust" control until the "Megohms" panel meter reads infinity.
4. Turn the Range Selector switch to the "Calibration" position.
5. Press the Push button and set the "D.C. Adjust" until the voltmeter reads 500 volts. The megohmmeter should also indicate 500 volts.
6. If the 10K or 100K Range is to be used the following procedure should be used:
 - a. Check the infinity reading of the meter with no leads attached. A slight readjustment of the "Zero Adjust" may be necessary.
 - b. Connect the test leads provided with the instrument to the "X" terminals. These are low leakage leads and no attempt should be made to correct this slight leakage by readjusting the "Zero Adjust" knob.

| | | | | | |
|---|--|------------------------------|-------------------------------|-------------|--------------------|
| Automatic Switch Co. VALVE ENGINEERING LABORATORY | | DEW <input type="checkbox"/> | CONT <input type="checkbox"/> | ISSUED BY | NO. |
| | | AM <input type="checkbox"/> | AM <input type="checkbox"/> | L. Guthreau | ELP-45 |
| TITLE OPERATION OF FREED MODEL 1620 MEGOHMMETER | | PH <input type="checkbox"/> | PA <input type="checkbox"/> | APP. BY | CHANGE LETTER A |
| | | AV <input type="checkbox"/> | <input type="checkbox"/> | DATE ISSUED | PAGE 2 OF 2 |
| | | <input type="checkbox"/> | <input type="checkbox"/> | 5/17/60 | |

7. To measure the leakage resistance of coil proceed as follows:



- a. Connect the "Guard" to the "Ground" terminal with the supplied connecting strip.
 - b. Connect the two leads supplied with the instrument to the "X" terminals.
 - c. Twist the two coil leads together and connect one of the "X" leads to them.
 - d. Clip the other "X" lead to a clean metal part of the housing.
 - e. Set the range selector switch to the range desired.
 - f. Push the button on the megohmmeter and note the reading on each meter.
NOTE: Do not touch the terminals on leads while the "Push" button is depressed.
 - g. The value of the unknown resistance is the product of the meter readings multiplied by the setting of the Range Selector switch.
8. Do not make any adjustments to this instrument other than those listed in this procedure.

NOTE: For information on other tests, consult the instrument manual kept in the Switch Laboratory.

ERV-70668 Chg.Ltr. A No change in procedure 7/17/74 LRG

APPENDIX B
TEST PROCEDURE BULLETINS

| <u>VALVE NO.</u> | <u>BULLETIN</u> |
|------------------|-----------------|
| 1 | TP-3-046 |
| 2 | TP-NP8344 |
| 3 | TP-NP8316 |
| 4 | TP-3-046 |
| 5 | TP-NP8320 |
| 6 | TP-NP8316 |
| 7 | TP-3-046 |
| 8 | TP-NP8321 |
| 9 | TP-NP8323 |

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|-----------------------------|--------------------|
| DEW <input type="checkbox"/> | CONT <input type="checkbox"/> | ISSUED BY R. Powell | NO. TP-3-046 |
| AL <input type="checkbox"/> | AM <input type="checkbox"/> | APP. BY <i>R. Powell</i> | CHANGE LETTER A |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> | DATE ISSUED 6/21/77 | PAGE 1 OF 2 |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> | | |
| AA <input type="checkbox"/> | PS <input type="checkbox"/> | | |

TITLE
TEST PROCEDURE: HVA-206-380, HVA-206-381,
HVA-208-448, HVA-208-266,
HVA-206-832, HVA-210-036

TEST MEDIUM:

These valves contain Ethylene Propylene elastomers...Test on oil free, filtered air only.

GENERAL:

1. Check general construction and appearance of valve.
2. Check nameplate data for conformance to shop order specifications.

TEST FIXTURES

| | | | |
|--------------|------------|--------------|------------|
| TA-981-11448 | P37 Valves | TJ-537-9075 | P38 Valves |
| AT-8300C-F-1 | | TA-905-9984 | |
| | | TJ-905-10168 | |

TEST VOLTAGE AND CURRENT:

1. All D.C. valves are to be tested using the test current listed under the specified voltage on Data Sheet No. 26.
2. All A.C. valves are to be tested using the test voltage listed on Test Procedure TP-1-003.

COIL TESTS:

1. A.C. - Energize solenoid and check milliampere reading. Value should agree with that shown on Data Sheet No. 24.
2. D.C. - Energize solenoid and check voltage reading. Value should agree with that indicated per Note 2 on Data Sheet No. 26.
3. Dielectric test - measure the current leakage at 1000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2) Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

EXTERNAL LEAKAGE:

Apply seamtest solution to all joints and pressurize valve to 500 psig energized and de-energized (do not energize valve above maximum operating pressure). Any bubbling or foaming is reason for rejection. (Ref.: TP-1-009)

NOTE:

To avoid seat leakage or noise caused by the possible presence of dirt or loose chips, blow air at maximum operating pressure thru the valve before proceeding with tests below.

SEAT LEAKAGE (HIGH PRESSURE)

Check valve for seat leakage at maximum operating pressure. Allowable leakage:
Resilient Seats - 0
Metal Seats - 1.5 SCFH.

NOISE TEST:

During the operational tests, check valve for noise. Any chattering or rattling in excess of normal A.C. hum is reason for rejection. Valve should be tested at test voltage first, but voltage may be increased to full line voltage if necessary to pass the Noise Test Only. (Ref. TP-1-015)

Automatic Switch Co.

VALVE ENGINEERING DEPT.

DEW CONT

ISSUED BY

NO.

AL AM

R. Powell

TP-3-046

CH KA

APP. BY

CHANGE LETTER

AV AR

DATE ISSUED

A

AA

6/21/77

PAGE 2 OF 2

TITLE TEST PROCEDURE: HVA-206-380, HVA-206-381
HVA-208-448, HVA-208-266
HVA-206-832, HVA-210-036

OPERATIONAL TESTS:

1. Operate valve at least 10 times at maximum operating pressure.
2. Operate valve from maximum operating pressure down to minimum operating pressure.

SEAT LEAKAGE (LOW PRESSURE)

Check seat leakage at 10 psi. Allowable leakage:

Resilient Seats - 0

Metal Seats - 1.5 SCFH

PREPARATION FOR SHIPMENT

Seal all pipe connections with plastic thread protectors and hank coil leads around bonnet. Attach tag FV-206-825-1.

CORRECTIVE ACTION RECORD:

Maintain Test Log (Form 1109) on all large production runs.

(A) ERV-83338 - Updated - 10/25/77 - R.D.P.
ERV-82135 - Issued - 6/28/77 - R.D.P.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | |
|------------------------------|-------------------------------|
| DEW <input type="checkbox"/> | CONT <input type="checkbox"/> |
| AL <input type="checkbox"/> | AM <input type="checkbox"/> |
| CH <input type="checkbox"/> | CA <input type="checkbox"/> |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> |
| AA <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | PS <input type="checkbox"/> |

ISSUED BY
R. Powell

NO.
TP-NP8316

APP. BY
R. Powell

CHANGE LETTER

DATE ISSUED
6/21/77

PAGE 1 OF 1

TITLE

TEST PROCEDURE: BULLETIN NP8316

TEST MEDIUM:

These valves contain Ethylene Propylene Elastomers...Test on oil free, filtered air only.

GENERAL:

1. Check valves general appearance and construction.
2. Check nameplate data for conformance to shop order specifications.

TEST FIXTURE:

TH-48-4307.

TEST VOLTAGES AND CURRENTS

1. All D.C. valves are to be tested using the proper test current listed under specified voltage on Data Sheet #26.
2. All A.C. valves are to be tested using the proper test voltage listed on Test Procedure TP-1-003.

COIL TEST

1. A.C. - Energize solenoid and check milliampere reading. Reading should agree with the value given on Data Sheet #24.
2. D.C. - Energize solenoid and check voltage reading. Reading should agree with value from Note 2 on Data Sheet # 26.
3. Dielectric test - measure the current leakage at 1000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2). Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

OPERATIONAL TESTS

1. Check all valves at least five (5) times dry at full line voltage for proper solenoid operation and noise level as follows:
 - a. A metallic "click" of the core striking the plugnut should be heard when the solenoid is energized. No "click" indicates a power failure or sticker.
 - b. Chattering, rattling, or A.C. hum in excess of laboratory standards is reason for rejection. (Ref: Test Procedure TP-1-015)
2. Operate valve at least ten (10) times at maximum operating pressure.
3. Operate valve from maximum operating pressure down to minimum operating pressure.

SEAT LEAKAGE:

Check seat leakage with valve energized and de-energized at maximum and minimum operating differential pressure. Seats must be bubbletight. Any leakage is cause for rejection.

EXTERNAL LEAKAGE:

Apply seamtest solution to all joints and fittings and pressurize valve to 1-1/2 times maximum operating pressure. Check valve both energized and de-energized (do not operate valve above maximum operating pressure) Any bubbling or foaming is cause for rejection.

PREPARATION FOR SHIPMENT:

Cap valve pressure, cylinder, and exhaust ports with plastic coated paper plugs and wrap coil leads together. Attach tag FV-206-825-1.

CORRECTIVE ACTION RECORD:

Maintain test log (Form 1109) on all production runs.

ERV-82135 - Issued - 6/28/77 - R.D.P.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|-----------------------------|------------------|
| DEW <input type="checkbox"/> | YONT <input type="checkbox"/> | ISSUED BY E. Powell | NO. TP-NP8320 |
| AL <input type="checkbox"/> | AM <input type="checkbox"/> | APP. BY <i>E. Powell</i> | CHANGE LETTER |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> | DATE ISSUED 6/21/77 | PAGE 1 OF 2 |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> | | |
| AA <input type="checkbox"/> | <input type="checkbox"/> | | |
| <input type="checkbox"/> | PS <input type="checkbox"/> | | |

TITLE
TEST PROCEDURE: BULLETIN NP8320

TEST MEDIUM:

These valves contain Ethylene Propylene Elastomers...Test on oil free, filtered air only.

GENERAL:

1. Check general construction and appearance of valve.
2. Check nameplate data for conformance to shop order specifications.

TEST FIXTURES

Functional and Seat Leakage Tests:

- 1/8 NPT: Adapter TF-332-7301 w/attachment GT-332-6900-4
- 1/4 NPT: Adapter TP-332-7301 w/attachment GT-332-6900-3

External Leakage Tests:

- 1/8 NPT: AT-8320-A-1
- 1/4 NPT: AT-8320-B-1

TEST VOLTAGE AND CURRENT:

1. All D.C. valves are to be tested using the test current listed under the specified voltage on Data Sheet No. 26.
2. All A.C. valves are to be tested using the test voltage listed on Test Procedure TP-1-003.

COIL TESTS:

1. A.C.- Energize solenoid and check milliampere reading. Value should agree with that shown on Data Sheet No. 24.
2. D.C.- Energize solenoid and check voltage reading. Value should agree with that indicated per Note 2 on Data Sheet No. 26.
3. Dielectric test - measure the current leakage at 1,000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2). Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

EXTERNAL LEAKAGE:

All valves are to have external leakage tests performed in Valve Assembly with Solenoid Base Sub-Assembly attached to body but before coil, housing, etc. are assembled.

- a. Brush seamtest solution around all joints.
- b. Pressurize valve to 500 psig. Any bubbling or foaming is reason for rejection. (Ref. TP-1-009)

NOTE:

To avoid seat leakage or noise caused by the possible presence of dirt or loose chips, blow air at maximum operating pressure thru the valve before proceeding with tests below.

SEAT LEAKAGE (HIGH PRESSURE):

With cylinder port closed off, check valve for seat leakage at maximum operating pressure. Valves must be bubbletight.

- a. Normally Closed Construction: Apply pressure at Port #2, check leakage at Port #3, energized and de-energized.
- b. Normally Open Construction: Apply pressure at Port #3, check leakage at Port #2, energized and de-energized.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|-----------------------------|------------------------|
| DEW <input type="checkbox"/> | CONT <input type="checkbox"/> | ISSUED BY F. Powell | NO. TP-NP8320 |
| AL <input type="checkbox"/> | AM <input type="checkbox"/> | APP. BY <i>F. Powell</i> | CHANGE LETTER |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> | | DATE ISSUED 6/21/77 |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> | | PAGE 2 OF 2 |
| AA <input type="checkbox"/> | <input type="checkbox"/> | | |
| <input type="checkbox"/> | PS <input type="checkbox"/> | | |

TITLE

TEST PROCEDURE: BULLETIN NP8320

NOISE TEST:

During the operational tests, check valve for noise. Any chattering or rattling in excess of normal A.C. hum is reason for rejection. Valve should be tested at test voltage first, but voltage may be increased to full line voltage if necessary to pass the NOISE TEST ONLY.
(Ref. TP-1-015)

OPERATIONAL TESTS:

1. Operate valve at least 10 times at maximum operating pressure.
2. Operate valve from maximum operating pressure down to minimum operating pressure.

NOTES: Universal constructions are to be tested for both normally open and normally closed operation.

SEAT LEAKAGE (LOW PRESSURE)

With cylinder port closed off, check seat leakage at 1/4 psi. Valves must be bubbletight.
a. & b. Same as High Pressure.

PREPARATION FOR SHIPMENT:

Seal all pipe connections with plastic coated paper plugs or plastic thread protectors and hank coil leads or wrap leads around bonnet. Attach tag FV-206-825-1.

CORRECTIVE ACTION RECORD:

Maintain test log (Form 1109) on all production runs.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | |
|------------------------------|--------------------------------|
| DEW <input type="checkbox"/> | FRONT <input type="checkbox"/> |
| AL <input type="checkbox"/> | AM <input type="checkbox"/> |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> |
| AA <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | PS <input type="checkbox"/> |

ISSUED BY
R. Powell

NO.
TP-NP8321

APP. BY
R. Powell

CHANGE LETTER

DATE ISSUED
6/21/77

PAGE 1 OF 2

TITLE

TEST PROCEDURE: BULLETIN NP8321

TEST MEDIUM:

These valves contain Ethylene Propylene elastomers...Test on oil free, filtered air only.

GENERAL:

1. Check valves general appearance and construction.
2. Check nameplate data for conformance to shop order specifications.

TEST FIXTURES:

AT 92-623-A1 (Normally Closed)
AT 8321-B1 (Normally open)

TEST VOLTAGES AND CURRENTS:

1. All D.C. valves are to be tested using the test current listed on Data Sheet #26.
2. All A.C. valves are to be tested using the test voltage listed on Test Procedure TP-1-003.

COIL TEST:

1. A.C. - Energize solenoid and check milliampere reading. Reading should agree with the value given on Data Sheet #24.
2. D.C. - Energize solenoid and check voltage reading. Reading should agree with value per Note 2 on Data Sheet #26.
3. Dielectric test - measure the current leakage at 1000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2). Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

OPERATIONAL TESTS:

1. Check all valves at least five (5) times dry at full line voltage for proper solenoid operation and noise level as follows:
 - a. A metallic "click" of the core striking the plugnut should be heard when the solenoid is energized. No "click" indicates a power failure or sticker.
 - b. Chattering, rattling or A.C. hum in excess of laboratory standards is reason for rejection. (Ref: Test Procedure TP-1-015)
2. Operate valve at least ten (10) times at maximum operating pressure.
3. Operate valve from maximum operating pressure down to minimum operating pressure.

SEAT LEAKAGE:

Check seat leakage with valve energized and de-energized at maximum and minimum operating pressure. Allowable leakage: 90 cc/min.

EXTERNAL LEAKAGE:

Apply seamtest to all joints and fittings and pressurize valve to 500 psig. Check valve both energized and de-energized (do not operate valve above maximum operating pressure). Any bubbling or foaming is cause for rejection.(Ref.: TP-1-009)

PREPARATION FOR SHIPMENT:

Cap valve pressure, cylinder, and exhaust ports with plastic coated paper plugs or plastic thread protectors, and wrap coil leads together. Attach tag FV-206-825-1.

Automatic Switch Co.
VALVE ENGINEERING DEPT.

DEW CONT
AL AM
CH CA
AV AR
AA
 PS

ISSUED BY
E. Powell
APP. *R. Powell*
DATE ISSUED
6/21/77

NO.
TP-NP-8321
CHANGE LETTER
PAGE 2 OF 2

TITLE
TEST PROCEDURE: BULLETIN NP8321

CORRECTIVE
ACTION
RECORD:

Maintain test log Form (1109) on all production runs.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|-----------------------------|--------------------|
| DEW <input type="checkbox"/> | CONT <input type="checkbox"/> | ISSUED BY R. Powell | NO. TP-NP8323 |
| AI <input type="checkbox"/> | AM <input type="checkbox"/> | APP. BY <i>R. Powell</i> | CHANGE LETTER A |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> | DATE ISSUED 6/21/77 | PAGE 1 OF 2 |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> | | |
| AA <input type="checkbox"/> | <input type="checkbox"/> | | |
| <input type="checkbox"/> | PS <input type="checkbox"/> | | |

TITLE
TEST PROCEDURE: BULLETIN NP8323
(REDUNDANT SOLENOID)

TEST MEDIUM:

These valves contain Ethylene Propylene elastomers...Test on oil free, filtered air only.

GENERAL:

1. Check the valve for general construction and appearance.
2. Check nameplate data for conformance to shop order specifications.

TEST FIXTURE:

AT-8323-A1 or piped direct to air line.

TEST VOLTAGE AND CURRENT:

1. All D.C. solenoids are to be tested using the test current listed under the specified voltage on Data Sheet No. 26.
2. All A.C. solenoids are to be tested using the test voltage listed on Test Procedure TP-1-003.

COIL TEST:

1. A.C. - Energize each solenoid separately and check the milliampere reading. Reading should agree with value per Data Sheet No. 24.
2. D.C. - Energize each solenoid separately and check the voltage reading. Reading should agree with value from Note 2 on Data Sheet No. 26.
3. Dielectric test - measure the current leakage at 1000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2). Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

OPERATIONAL TESTS:

1. Operate each solenoid at least five times dry at full line voltage and check for proper solenoid operation and noise level as follows:
 - (a) A metallic "click" of the core striking the plugnut should be heard when the solenoid is energized. No "click" indicates a power failure or sticker.
 - (b) Any chattering, rattling, or A.C. humming in excess of Laboratory Standards, is reason for rejection. (Ref.: TP-1-005)
2. For normally closed catalog items apply pressure at "2" and for normally open catalog items apply pressure at #3.
 - (a) Operate valve at least ten times at maximum operating pressure using Solenoid #A; repeat using Solenoid #B.
 - (b) Operate valve from maximum to minimum operating pressure using Solenoid #A; repeat using Solenoid #B.

SEAT LEAKAGE:

- With cylinder port (1) closed check for leakage at 1/4 psi and at maximum operating pressure differential as below:
- (a) For normally closed construction apply pressure at "2" and check for leakage at "3" de-energized, with Solenoid "A" only energized, and with Solenoid "B" only energized. Valves must be bubbletight.
 - (b) For normally open construction apply pressure at "3" and check for leakage at "2" de-energized, with Solenoid "A" only energized, and with Solenoid "B" only energized. Valves must be bubbletight.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|-----------------------------|------------------------|
| <input type="checkbox"/> DEW | <input type="checkbox"/> CONT | ISSUED BY R. Powell | NO. TP-NP8323 |
| <input type="checkbox"/> AL | <input type="checkbox"/> AM | APP. BY <i>R. Powell</i> | CHANGE LETTER A |
| <input type="checkbox"/> CH | <input type="checkbox"/> KA | | DATE ISSUED 6/21/77 |
| <input type="checkbox"/> AV | <input type="checkbox"/> AR | | |
| <input type="checkbox"/> AA | <input type="checkbox"/> | | |
| <input type="checkbox"/> | <input type="checkbox"/> PS | | |





TITLE
TEST PROCEDURE: BULLETIN NP8323
(REDUNDANT SOLENOID)

EXTERNAL LEAKAGE:

With solenoid energized or de-energized as required, pressurize interior of valve to 500 psig, apply seam test to all joints and fittings. Any bubbling or foaming is cause for rejection. (Ref. TP-1-009)

PREPARATION FOR SHIPMENT:

Cap "1", "2", and "3" ports of valve with plastic coated plugs or plastic thread connectors and hank coil leads. Attach tag FV-206-825-1.

| FLOW DIAGRAMS | | CATA. NOS. | |
|---|---|--------------------------------------|--------------------------------------|
| NORMALLY CLOSED | | | |
| SOL. A & B DE-ENERGIZED | EITHER OR BOTH SOLS. ENERGIZED | GP | EP |
|  |  | 832319 21 23 35 37 39 | 832320 22 24 36 38 40 |
| NORMALLY OPEN | | | |
| SOL. A & B DE-ENERGIZED | EITHER OR BOTH SOLS. ENERGIZED | GP | EP |
|  |  | 832327 29 31 43 45 47 | 832328 30 32 44 46 48 |

CORRECTIVE ACTION RECORD:

Maintain test log (Form 1109) on all production runs.

ERV-83712 - Revised - 12/5/77 - R.D.P.
ERV-82135 - Issued - 6/29/77 - R.D.P.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|----------------------------|------------------|
| <input type="checkbox"/> DEW | <input type="checkbox"/> CONT | ISSUED BY E. Powell | NO. TP-NP8344 |
| <input type="checkbox"/> AL | <input type="checkbox"/> AM | APP BY <i>E. Powell</i> | CHANGE LETTER |
| <input type="checkbox"/> CH | <input type="checkbox"/> KA | | |
| <input type="checkbox"/> AV | <input type="checkbox"/> AR | DATE ISSUED 6/21/77 | PAGE 1 OF 2 |
| <input type="checkbox"/> AA | <input type="checkbox"/> | | |
| <input type="checkbox"/> | <input type="checkbox"/> PS | | |

TITLE
TEST PROCEDURE: BULLETIN NP8344

TEST MEDIUM:

GENERAL:

TEST FIXTURES

TEST VOLTAGE AND CURRENT:

COIL TESTS:

EXTERNAL LEAKAGE:

NOTE:

SEAT LEAKAGE: (HIGH PRESSURE)

NOISE TEST:

OPERATIONAL TESTS:

These valves contain Ethylene Propylene Elastomers...Test on oil free, filtered air only.

1. Check general construction and appearance of valve.
2. Check nameplate data for conformance to shop order specifications.

TJ-546-8023
TJ-764-8949
TA-793-9149

1. All D.C. valves are to be tested using the test current listed under the specified voltage on Data Sheet No. 26.
2. All A.C. valves are to be tested using the test voltage on Test Procedure TP-1-003.

1. A.C. - Energize solenoid and check milliampere reading. Value should agree with that shown on Data Sheet No. 24.
2. D.C. - Energize solenoid and check voltage reading. Value should agree with that indicated per Note 2 on Data Sheet No. 26.
3. Dielectric test - measure the current leakage at 1000 volts plus twice the rated voltage in accordance with TP-1-002 (test method #2). Any evidence of damage, arcing, breakdown or current leakage in excess of 0.5 milliampere is cause for rejection.

Apply seamtest solution to all joints and pressurize valve to 500 psig, energized and de-energized (do not operate valve above maximum operating pressure). Any bubbling or foaming is cause for rejection. (Ref.: TP-1-009)

To avoid seat leakage or noise caused by the possible presence of dirt or loose chips, blow air at 10% over maximum operating pressure rating thru the valve before proceeding with tests below.

Check valve for seat leakage at 10% over maximum operating pressure.
Allowable leakage:
Air: 6 SCFH

During the Operational Tests, check valve for noise. Any chattering or rattling in excess of normal A.C. hum is reason for rejection. Valve should be tested at test voltage first, but voltage may be increased to full line voltage if necessary to pass the NOISE TEST ONLY. (Ref. TP-1-015)

Single Solenoid Valves:

Operate valve at least ten (10) times at maximum operating pressure and from maximum operating pressure down to minimum operating pressure, alternately opening cylinder connections after operating to make sure by leak check that proper shifting has occurred.

Automatic Switch Co.

VALVE ENGINEERING DEPT.

| | | | |
|------------------------------|-------------------------------|------------------|---------------|
| DEW <input type="checkbox"/> | CONT <input type="checkbox"/> | ISSUED BY | NO. |
| AI <input type="checkbox"/> | AM <input type="checkbox"/> | P. Powell | TP-MP8344 |
| CH <input type="checkbox"/> | KA <input type="checkbox"/> | APP. BY | CHANGE LETTER |
| AV <input type="checkbox"/> | AR <input type="checkbox"/> | <i>P. Powell</i> | |
| AA <input type="checkbox"/> | <input type="checkbox"/> | DATE ISSUED | PAGE 2 OF 2 |
| <input type="checkbox"/> | PS <input type="checkbox"/> | 6/21/77 | |

TITLE
TEST PROCEDURE - BULLETIN NP8344

OPERATIONAL TESTS:

Dual Solenoid Valves:

1. Test as for single solenoid valves, energizing and de-energizing solenoids alternately.
2. Alternately energize and de-energize solenoids in normal pressure range ending up with solenoid A (Sol #2) last energized. Then increase inlet pressure at least 15 psi or more. If lock-up bleed is not present, valve will leak heavily out of exhaust. This is a defective rejectable valve.
3. Solenoids must be energized at least 0.3 seconds on air service.

SEAT LEAKAGE: (LOW PRESSURE)

Check seat leakage at 20 psi.

Allowable Leakage:

Air: 6 SCFH

PREPARATION FOR SHIPMENT:

Seal all pipe connection with plastic coated paper plugs or plastic thread protectors and hank coil leads. Attach tag FV-206-825-1.

CORRECTIVE ACTION RECORD:

Maintain test log (Form 1109) on all production runs.

APPENDIX C

INSTRUMENTS USED FOR BASELINE/FUNCTIONAL TESTS

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois

Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160

• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

APPENDIX C

| NAME | MANUFACTURER | SERIAL NO. | RANGE | FIRST CALIBRATION DATE | CALIBRATION DONE EVERY | LAST CALIBRATION DUE DATE |
|----------------|---------------------|--------------|-----------------------------|------------------------|------------------------|---------------------------|
| Pressure Gauge | Helicoid | VLPG 600-23 | 0-600 psi | 5/21/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 600-14 | 0-600 psi | 5/18/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 300-13 | 0-300 psi | 5/19/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 300-36 | 0-300 psi | 5/19/77 | 4 months | 2/1/78 |
| Pressure Gauge | Dwyer Mfg. Co. | VLDP 15-4 | 0-15" H ₂ O | 5/25/77 | 4 months | 5/26/78 |
| Pressure Gauge | Helicoid | VLPG 30-28 | 0-30 psi | 5/23/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 300-48 | 0-300 psi | 5/19/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 60-5 | 0-60 psi | 5/4/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 60-13 | 0-60 psi | 5/4/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 200-15 | 0-200 psi | 5/24/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 200-11 | 0-200 psi | 5/23/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 60-4 | 0-60 psi | 5/19/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 60-19 | 0-60 psi | 5/19/77 | 4 months | 2/1/78 |
| Pressure Gauge | Helicoid | VLPG 100-17 | 0-100 psi | 5/23/77 | 4 months | 2/22/78 |
| Differential | Pitney Bowes | VLDP 15-1 | 0-15" H ₂ O | 6/7/77 | 4 months | 5/26/78 |
| Differential | Helicoid | VLPG 30-20 | 0-30 psi | 5/23/77 | 4 months | 2/1/78 |
| Flow Meter | Fischer & Porter | VLFC 200-7 | 0-200 cc/min | 10/19/76 | 1 year | 10/21/78 |
| Flow Meter | Dwyer Mfg. Co. | VLFP 10-7 | 0-1- SCFH | 10/28/76 | 1 year | 10/28/78 |
| Flow Meter | Dwyer Mfg. Co. | VLFP 200-2 | 20-200 SCFH | 10/19/76 | 1 year | 10/20/78 |
| Flow Meter | Dwyer Mfg. Co. | VLFP 50-1 | 0-50 SCFH | 10/27/76 | 1 year | 10/2/78 |
| Flow Meter | Dwyer Mfg. Co. | VLFP 200-7 | 20-200 SCFH | 10/20/76 | 1 year | 10/20/78 |
| Megohmmeter | Freed Transformer | VLMO 20-1 | 0-1000 volts 0-INF. ohms | 12/16/76 | 6 months | 6/17/78 |
| Ammeter | Weston | VLADC 5-2 | 0-5 amps | 2/7/77 | 4 months | 2/15/78 |
| Voltmeter | Weston | VLVAC 300-26 | 0-300 VAC | 5/15/77 | 4 months | 2/16/78 |
| Voltmeter | Weston | VLVAC 300-32 | 0-300 volts | 5/10/77 | 4 months | 2/15/78 |
| Hypot Tester | Associated Research | VLH 4000-1 | 0-4000 volts | 3/14/77 | 4 months | 2/16/78 |

APPENDIX D
RADIATION CERTIFICATE

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

- 7828 Naale Ave., Morton Grove, Illinois 60053 (312) 966-1160
- Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

March 27, 1978

TO: Tejinder S. Sachdeva
Manager, Component Testing

FROM: George R. Dietz,
Manager, Radiation Services

SUBJECT: Radiation Exposure of ASCO Valves

This will summarize parameters pertinent to the irradiation of nine valves for the Automatic Switch Company.

Radiation exposure was conducted in two sequences. In the first, the valves were placed in a cobalt-60 gamma field at an average dose rate of 0.51 Mrad per hour for 99 hours, yielding a total dose of 50.5 Mrad. This step was completed on September 15, 1977.


The valves were again placed into the radiation chamber on October 27, 1977, and exposed for an additional 188.5 hours at an average dose rate of 0.8 Mrad per hour, yielding an additional dose of 150.8 Mrad. Hence the total dose from both exposures was 201.3 Mrad.

During both exposures, the units were rotated at the respective mid-exposure points, in order to obtain the most even dose distribution.

Dosimetry was performed using an Atomic Energy of Canada Limited (AECL) Red Perspex system with Type BC-2 readout. Calibration of the Perspex is made by AECL using Ceric dosimetry traceable to the U. S. National Bureau of Standards. Isomedix regularly cross-calibrates its AECL system with an in-house Harwell Perspex system, and makes semiannual calibrations directly with NBS, using the NBS Radiochromic Dye system. A copy of the dosimetry correlation report is available upon request.

Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but the temperature did not exceed 85°F, as indicated by previous measurements on an oil solution in the same relative position.

GRD:of


George R. Dietz

ISOMEDIX INC.

CORPORATE OFFICES • 80 SOUTH JEFFERSON ROAD, WHIPPANY, NEW JERSEY 07981 • (201) 887-4700


APPENDIX E

'DAYTON T. BROWN' TEST REPORT

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

- 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
- Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015



ENGINEERING AND TEST DIVISION

CHURCH STREET, BOHEMIA, LONG ISLAND,
NEW YORK 11716 / (516) 589-6300

TEST REPORT / PROCEDURE No.DTB04R77-1651 Revision A
DAYTON T. BROWN, INC. JOB No.401797-00-000.....

| | |
|-----------|--|
| CUSTOMER: | ISOMEDIX, INC. 25 EASTMANS ROAD PARSIPPANY, NEW JERSEY 07054 |
| SUBJECT: | SEISMIC TEST PROGRAM PERFORMED ON NINE SOLENOID VALVES |

ATTENTION: MR. N. BURSTEIN

THIS REPORT CONTAINS: FIVE PAGES AND TWO ENCLOSURES

| | |
|----------------|--------------------------------------|
| PREPARED BY | S. J. FRANKLIN <i>S. J. Franklin</i> |
| TEST ENGINEER | W. W. SCHAAF <i>W. W. SchAAF</i> |
| STAFF ENGINEER | R. J. ROTHaug <i>R. J. Rothaug</i> |
| DATE | 7 NOVEMBER 1977 |

THE DATA CONTAINED IN THIS REPORT WAS OBTAINED BY TESTING
IN COMPLIANCE WITH THE APPLICABLE TEST SPECIFICATION AS NOTED

Revision Page

| <u>Page</u> | <u>Change</u> |
|---------------|---|
| Cover Page | Revision A added to Test Report Number; Date updated |
| Enc. 1, Pg. 4 | Notes 1, 2, and 3 added |
| Enc. 1, Pg 5 | Test Condition changed from Lo to Hi in Sequence Number 25 |



TABLE OF CONTENTS

| <u>Subject</u> | <u>Paragraph</u> | <u>Page Number</u> |
|----------------------------|------------------|--------------------|
| Abstract | 1.0 | 2 |
| References | 2.0 | 3 |
| Administrative Information | 3.0 | 4 |
| Test Program Outline | 4.0 | 5 |

Enclosures

- (1) Seismic Test and Results 71 Pages
- (2) Photographs 2 Photos



1.0 ABSTRACT

This test report details the results of a seismic test program conducted on nine solenoid valves under reference (a) to the requirements of reference (c).

Results of the test are detailed in the following text.

The test items were operated during portions of testing.

The test items' operation was the sole responsibility of Isomedix Inc. personnel, and all operational data was retained by same.

Test data pertinent to this test program will remain on file at Dayton T. Brown, Inc. for 90 days.

2.0 REFERENCES

- (a) Customer Purchase Order Number 2019
- (b) Dayton T. Brown, Inc. Job Number 401797-00-000
- (c) Test Specification and ASCO Qualification Specification,
dated January 1977, Revision, September 19, 1977



3.0 ADMINISTRATIVE INFORMATION

Customer: Isomedix Inc.

Test Item Description: Solenoid Valves

Quantity Received: Nine

| <u>Serial Numbers:</u> | <u>ASCO S/N</u> | <u>Dayton T. Brown, Inc. Assigned S/N</u> |
|------------------------|-----------------|---|
| | HV-206-381-6F | 1 |
| | NP-8344-A-71E | 2 |
| | XFT-831654-V | 3 |
| | HV-206-380-3RF | 4 |
| | NP-8320-A-184E | 5 |
| | NP-831665-E | 6 |
| | HVA-202-300-2RF | 7 |
| | NP-8321-A-5E | 8 |
| | NP-8323-A-39E | 9 |

Date Received: 30 September 1977

Date Shipped: 7 October 1977

Customer Representatives Present During Portions of Test:

| <u>Name</u> | <u>Affiliation</u> |
|------------------|--------------------------|
| Mr. D. Gibbons | Isomedix Inc. |
| Mr. N. Burstein | Isomedix Inc. |
| Mr. Conca | Isomedix Inc. |
| Mr. Plaut | Automatic Switch Company |
| Mr. G. Fleishman | Automatic Switch Company |
| Mr. R. D. Powell | Automatic Switch Company |
| Mr. T. R. Hays | Automatic Switch Company |

4.0 TEST PROGRAM OUTLINE

| <u>Test</u> | <u>Test Item Description</u> | <u>Results</u> |
|-------------|------------------------------|-----------------|
| Seismic | Solenoid Valves | See Enclosure 1 |



Enclosure 1
Seismic Test and Results

TEST REQUIREMENT

The seismic test shall be conducted in accordance with reference (c).

TEST PROCEDURE

The nine solenoid valves were subjected to the following procedure in each of the three orthogonal test axes.

- Step 1: A pretest visual inspection of the test items was performed.
- Step 2: The test items were mounted on the test fixture and set up to be energized during testing. A triaxial control accelerometer was mounted on the test fixture and response accelerometers were mounted on the test items.
- Step 3: The test items, energized, were subjected to a sinusoidal vibration survey from 3 to 100 Hz at a sweep rate of 1.0 octave per minute. The applied vibration level was ± 0.2 g.

The accelerometers' output signals were plotted on graphs of acceleration versus frequency.
- Step 4: Step 3 was repeated with the test items de-energized.
- Step 5: The test items, energized, were subjected to a sinusoidal vibration dwell test. The frequency was determined by the representatives: 90 Hz - Z axis, 95 Hz - Y axis, 100 Hz - X axis. The applied level was ± 0.75 g. Dwell testing was performed for 333,333 cycles in each of the three axes. The test items were energized for all testing. Every 15 minutes, the items were de-energized for approximately 15 seconds.
- Step 6: The test items, energized, were subjected to the OBE seismic test. One cycle from 1 to 33 to 1 Hz was performed in 10 minutes. The applied vibration levels are given below:

Table I

| <u>Frequency (Hz)</u> | <u>Applied Level</u> |
|-----------------------|----------------------|
| 1.0 to 1.2 | 6.0 inches d.a. |
| 1.2 to 8.0 | 24 inches per sec. |
| 8.0 to 33 | ± 3.0 g's |

- Step 7: Step 6 was repeated with the test items de-energized.



TEST PROCEDURE - (Continued)

Step 8: The test items were subjected to a combined SSE and fragility test. Each of the following frequencies were maintained for 15 seconds: 1.0, 1.25, 1.6, 2.0, 2.5, 3.2, 4.0, 5.0, 6.3, 8.0, 10.0, 12.5, 16.0, 20.0, 25.0, 32.0, and 33.0 Hz. The applied vibration levels are given below:

Table II - S/N's 1 - 9, Axes Z & X and S/N 6, Axis Y

| <u>Frequency (Hz)</u> | <u>Applied Input Level</u> |
|-----------------------|----------------------------|
| 1.0 | 6.0 in. d.a. |
| 1.25 | 5.5 in. d.a. |
| 1.6 | 4.3 in. d.a. |
| 2.0 | 5.0 in. d.a. |
| 2.5 | 4.5 in. d.a. |
| 3.2 | 4.4 in. d.a. |
| 4.0 | 3.7 in. d.a. |
| 5.0 | 2.8 in. d.a. |
| 6.3 | 2.2 in. d.a. |
| 8.0 | 1.8 in. d.a. |
| 10.0 - 33.0 | <u>± 7.0 g's</u> |

Table III - S/N's 1 - 5, 7, 8, 9, Axis Y

| <u>Frequency (Hz)</u> | <u>Applied Input Level</u> |
|-----------------------|----------------------------|
| 1.0 | 6.0 in. d.a. |
| 1.25 | 4.5 in. d.a. |
| 1.6 | 3.6 in. d.a. |
| 2.0 | 2.7 in. d.a. |
| 2.5 | 2.4 in. d.a. |
| 3.2 | 1.9 in. d.a. |
| 4.0 | 1.6 in. d.a. |
| 5.0 | 1.5 in. d.a. |
| 6.3 | 1.6 in. d.a. |
| 8.0 | 1.0 in. d.a. |
| 10.0 | 0.75 in. d.a. |
| 12.5 - 33.0 | <u>± 4.2 g's</u> |

The test was performed with the valves energized and de-energized and with high and low pressure. The leakage rate was monitored by Automatic Switch Company during testing.



TEST PROCEDURE - (Continued)

Step 9: A post-test visual inspection of the test items was performed.

TEST RESULTS

A pretest visual inspection of the test items revealed no anomalies.

All testing was performed in accordance with the referenced specification. Refer to the vibration test summary for tabulated results.

A post-test visual inspection of the test items revealed no anomalies due to testing.

VIBRATION TEST SUMMARY

| Seq. | Units DTBS/N | Axis | Ener. De-en. | Test Condition | Duration (min.) | Dwell Test Data | | | Page No. of Graph (Enc 1) | Rem. | | | | | |
|------|-----------------|------|-----------------|-------------------|--------------------|-----------------|------------------|---------------|------------------------------|------|------------------|--|--|---------|---------|
| | | | | | | Freq. (Hz) | Input (± g's) | Test Point | | | Response (± g's) | | | | |
| | | | | | | | | Start | Middle | End | | | | | |
| 1 | 1 - 9 | Z | En. | Survey | 5.0 | | | | | | | | | | |
| 2 | 1 - 9 | Z | De-en. | Survey | 5.0 | | | | | | | | | 7 - 17 | Note 1 |
| 3 | 1 - 9 | Z | En. | Dwell | 61.5 | 90 | 0.75 | 1 | 0.68 | 0.66 | 0.64 | | | 18 - 26 | Note 1 |
| | | | | | | | | 2 | 1.1 | 1.1 | 1.1 | | | | |
| | | | | | | | | 3 | 0.80 | 0.79 | 0.76 | | | | |
| | | | | | | | | 4 | 0.90 | 1.0 | 1.0 | | | | |
| | | | | | | | | 5 | 1.1 | 0.85 | 0.80 | | | | |
| | | | | | | | | 6 | 0.81 | 0.80 | 0.78 | | | | |
| | | | | | | | | 7 | 0.60 | 0.68 | 0.66 | | | | |
| | | | | | | | | 8 | 0.70 | 0.82 | 0.80 | | | | |
| | | | | | | | | 9 | 1.0 | 0.95 | 0.90 | | | | |
| 4 | 1 - 9 | Y | En. | Survey | 5.0 | | | | | | | | | 27 - 37 | |
| 5 | 1 - 9 | Y | De-en. | Survey | 5.0 | | | | | | | | | 38 - 46 | |
| 6 | 1 - 9 | Y | En. | Dwell | 58.5 | 95 | 0.75 | 1 | 0.78 | 0.78 | 0.76 | | | | |
| | | | | | | | | 2 | 0.75 | 0.75 | 0.74 | | | | |
| | | | | | | | | 3 | 1.30 | 1.30 | 1.32 | | | | |
| | | | | | | | | 4 | 0.61 | 0.60 | 0.60 | | | | |
| | | | | | | | | 5 | 0.77 | 0.75 | 0.75 | | | | |
| | | | | | | | | 6 | 0.81 | 0.80 | 0.78 | | | | |
| | | | | | | | | 7 | 0.50 | 0.50 | 0.50 | | | | |
| | | | | | | | | 8 | 1.25 | 1.25 | 1.25 | | | | |
| | | | | | | | | 9 | 0.63 | 0.63 | 0.62 | | | | |
| 7 | 1 - 9 | X | De-en. | Survey | 5.0 | | | | | | | | | 47 - 55 | Notes 2 |
| 8 | 1 - 9 | X | En. | Survey | 5.0 | | | | | | | | | 56 - 65 | & 3 |
| 9 | 1 - 9 | X | En. | Dwell | 55.0 | 100 | 0.75 | 1 | 3.2 | 3.2 | 3.2 | | | | |
| | | | | | | | | 2 | 1.3 | 1.4 | 1.3 | | | | |
| | | | | | | | | 3 | 0.9 | 0.9 | 0.9 | | | | |
| | | | | | | | | 4 | 1.4 | 1.3 | 1.3 | | | | |
| | | | | | | | | 5 | 3.1 | 3.1 | 3.1 | | | | |
| | | | | | | | | 6 | 1.0 | 1.0 | 1.0 | | | | |
| | | | | | | | | 7 | 4.1 | 4.1 | 4.0 | | | | |
| | | | | | | | | 8 | 4.3 | 4.2 | 4.2 | | | | |
| | | | | | | | | 9 | 2.8 | 2.8 | 2.8 | | | | |

Note 1 - Data was lost at TP #5 during the survey.

Note 2 - Crosstalk was not recorded at control point for the second horizontal axis.

Note 3 - Data was lost at TP #1 during the survey.

1651A Enc 1 Pg 4

VIBRATION TEST SUMMARY

| Seq. | Units DTBS/N | Axis | Ener. De-en. | Test Condition | Duration (min.) | Dwell Test Data | | | Page No. of Graph (Enc 1) | Rem. |
|------|-----------------|------|-----------------|------------------------|--------------------|-----------------|------------------|---------------|------------------------------|--------|
| | | | | | | Freq. (Hz) | Input (± g's) | Test Point | | |
| 10 | 1 - 9 | Y | En. | OBE | 10.0 | | | | 66 | |
| 11 | 1 - 9 | Y | De-en. | OBE | 10.0 | | | | | |
| 12 | 1 - 9 | Z | De-en. | OBE | 10.0 | | | | | |
| 13 | 1 - 9 | Z | En. | OBE | 10.0 | | | | 67 | |
| 14 | 1 - 9 | X | De-en. | OBE | 10.0 | | | | 68 | |
| 15 | 1 - 9 | X | En. | OBE | 10.0 | | | | 68 | |
| 16 | 6 | X | En./De-en. | SSE - Hi Pres. | 26.0 | | | | 68 | |
| 17 | 6 | X | En./De-en. | SSE - Lo Pres. | 13.0 | | | | | |
| 18 | 6 | Y | En./De-en. | SSE - Hi Pres. | 12.0 | | | | | |
| 19 | 6 | Y | En./De-en. | SSE - Lo Pres. | 45.0 | | | | | |
| 20 | 6 | Z | En./De-en. | SSE - Hi & Lo Pres. | 20.0 | | | | | |
| 21 | 2, 3 | Z | En./De-en. | SSE - Hi & Lo Pres. | 35.0 | | | | | |
| 22 | 2, 3 | Y | En./De-en. | SSE - Hi & Lo Pres. | 15.0 | | | | | |
| 23 | 2, 3 | X | En./De-en. | SSE - Hi & Lo Pres. | 25.0 | | | | | |
| 24 | 1, 7, 8 | Z | En./De-en. | SSE - Lo Pres. | 5.0 | | | | | |
| 25 | 1, 7, 8 | Z | En./De-en. | SSE - Hi Pres. | 3.0 | | | | | |
| 26 | 1, 7, 8 | X | En./De-en. | SSE - Lo Pres. | 6.0 | | | | | |
| 27 | 1, 7, 8 | X | En./De-en. | SSE - Hi Pres. | 4.0 | | | | | |
| 28 | 1, 7, 8 | Y | En./De-en. | SSE - Hi Pres. | 8.0 | | | | | Note 1 |
| 29 | 1, 7, 8 | Y | En./De-en. | SSE - Lo Pres. | 5.0 | | | | | Note 2 |

1651A Enc 1 Pg 5

VIBRATION TEST SUMMARY

| Seq. | Units DTB S/N | Axis | Ener. De-en. | Test Condition | Duration (min.) | Dwell Test Data | | | Page No. of Graph (Enc 1) | Rem. |
|------|------------------|------|-----------------|-------------------|--------------------|-----------------|------------------|---------------|------------------------------|------|
| | | | | | | Freq. (Hz) | Input (± g's) | Test Point | | |
| 30 | 4, 5, 9 | Z | En./De-en. | SSE - Lo Pres. | 3.0 | | | | | |
| 31 | 4, 5, 9 | Y | En./De-en. | SSE - Lo Pres. | 4.0 | | | | | |
| 32 | 4, 5, 9 | Y | En./De-en. | SSE - Hi Pres. | 3.0 | | | | | |
| 33 | 4, 5, 9 | Z | En./De-en. | SSE - Hi Pres. | 3.0 | | | | | |
| 34 | 4, 5, 9 | X | En./De-en. | SSE - Hi Pres. | 2.0 | | | | | |
| 35 | 4, 5, 9 | X | En./De-en. | SSE - Lo Pres. | 2.0 | | | | | |

Note 1: Leakage occurred from Dayton T. Brown, Inc. #7 at 6.3, 12.5, 16.0, 20.0, and 25.0 Hz.


Note 2: Leakage occurred from Dayton T. Brown, Inc. #7 at 10.8 and 6.3 Hz.

1651 Enc 1 Pg 6

Test Item: VALVES
 Serial Number(s): JTB # 1 → 9
 Unit: Operational Non-operational



Plotted by: J. Wetzel
 Checked by: W.B.



Vibration Axis: Z
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 7

Automatic Switch Control as a function

Relative db (20 db/decade)

Graph Number: 17

Lab Form D-24


Pickup Serial Number: 46793 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Z Live Tape Time: 1205

Automatic Switch Co. Instrument Division

Plotted by: *Wetzel*
Checked by: *US*



Test Item: *VALVES*
Serial Number(s): *DTR# 1-9*
Unit: Operational Non-operational



Vibration Axis: *Z*
Test Condition: *ENERGIZED*
 Unfiltered Filtered
F1 *5* Hz Bw (*3* to *10*)
F2 *10* Hz Bw (*10* to *100*)

Relative db (20 db/decade)

Graph Number: *213*

1651 Enc 1 Pg 8

Lab Form D-24

Pickup Serial Number: *1679 X*
Pickup Location: *CONTROL*
Pickup Sensing Axis: *X*

Pickup Sensitivity: *100.0* $\frac{mv\ peak}{g\ peak}$
Sweep Speed: *1.0* oct/minute
 Live Tape

Job Number: *401797*
Date: *10077*
Time: *1205*

Automatic Switch Co. WILMINGTON, DE 19804

Plotted by: R. Mercader


Checked by: W



Test Item: VALVES

Serial Number(s): DTB # 179

Unit: Operational Non-operational



Vibration Axis: Z

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

Relative db (20 db/decade) 60 50 40 30 20 10 0

Graph Number: 2

1651 Enc 1 Pg 9

Lab Form D-24

Pickup Serial Number: 456

Pickup Location: TP1

Pickup Sensing Axis: Z

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 OCT 77

Time: 1205

Plotted by: *J. P. [unclear]*


Checked by: *[unclear]*



Test Item: VALVES

Serial Number(s): DTR # 1-9

Unit: Operational Non-operational



Vibration Axis: *Z*

Test Condition: *ENERGIZED*

Unfiltered Filtered

F1: *5* Hz Bw (*3* to *10*)

F2: *10* Hz Bw (*10* to *100*)

Relative db (20 db/decade) 60 50 40 30 20 10 0

Graph Number: 21

Pickup Serial Number: *224*

Pickup Location: *TP 2*

Pickup Sensing Axis: *Z*

Pickup Sensitivity: *100.0* $\frac{\text{mv peak}}{\text{g peak}}$

Sweep Speed: *1.0* oct/minute

Live Tape

Job Number: *401797*


Date: *1 OCT 77*

Time: *1205*

Test Item: VALVES
 Serial Number(s): DTB# 1-9
 Unit: Operational Non-operational



Plotted by: *J. J. [unclear]*
 Checked by: *[unclear]*



Vibration Axis: Z
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 11

Lab Form D-24

Pickup Serial Number: AB40 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: TP 3 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: Z Live Tape Time: 1205

Relative db (20 db/decade)

Graph Number: 21

Test Item: VALVES
 Serial Number(s): JTR#1 → 9
 Unit: Operational Non-operational


Plotted by: *Watts*
 Checked by: *US*



Automatic Switch Co. Instrument Division

1651 Enc 1 Pg 12

Lab Form D-24



Vibration Axis: Z
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (10 to 100)

Pickup Serial Number: 459 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: TP 4 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Z Live Tape Time: 1205

Relative db (20 db/decade)

Graph Number: 27

Automatic Switch Co. model 41495 Series


1651 Enc 1 Pg 13

Lab Form D-24

Plotted by: Wetzel
Checked by: MS



Test Item: VALVES
Serial Number(s): DTB # 1-9
Unit: Operational Non-operational



Relative db (20 db/decade)

Graph Number: 24

Pickup Serial Number: 246 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 40.1797
 Pickup Location: TP 6 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Z Live Tape Time: 1705

Test Item: VALVES
 Serial Number(s): DTR#1 → 9
 Unit: Operational Non-operational




Plotted by: [Signature]
 Checked by: [Signature]

Automatic Switch Co. Cincinnati, Ohio

1651 Enc I Pg 14

Lab Form D-24



Vibration Axis: Z
 Test Condition: ENVELOPED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

Relative db (20 db/decade)


Graph Number: 24

Pickup Serial Number: 149209 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: TP 7 Sweep Speed: 1.0 oct/minute Date: 1005 77
 Pickup Sensing Axis: Z Live Tape Time: 1205

Plotted by: W. J. Wells
Checked by: WJ



Test Item: VALVE
Serial Number(s): DTR # 1-9
Unit: Operational Non-operational



Vibration Axis: Z
Test Condition: ENERGIZED
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 10 Hz Bw (10 to 100)

Pickup Serial Number: FH-4 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
Pickup Location: TP 8 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
Pickup Sensing Axis: Z Live Tape Time: 1205


Relative db (20 db/decade) 211
Graph Number: 211

Test Item: VALVE
 Serial Number(s): DTR# 179
 Unit: Operational Non-operational



Plotted by: Wetts
 Checked by: WS

Automatic Switch (Acceleration) Amplifier



Vibration Axis: Z
 Test Condition: ENERGETIC
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (1 to 100)

1651 Enc 1 Pg 16

Relative db (20 db/decade)

Graph Number: 24

Pickup Serial Number: CT68 Pickup Sensitivity: 100.0 mv peak / g peak Job Number: 401797
 Pickup Location: TP 9 Sweep Speed: 10 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Z Live Tape Time: 1205

Lab Form D-24

Test Item: UTL VIB
 Serial Number(s): DTB #1-9
 Unit: Operational Non-operational




Plotted by: [Signature]
 Checked by: [Signature]

Automatic Switch (A) with 1000 1000 1000 1000

1651 Enc I Pg 17

Lab Form D-24



Relative db (20 db/decade)

Graph Number: 2K

Pickup Serial Number: 46 79 Y Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Y Live Tape Time: 1205

12

Test Item: VALVE
 Serial Number(s): DTB# 1-9
 Unit: Operational Non-operational




Plotted by: *Watts*
 Checked by: *Watts*

Automatic Switch Co. Instrument, St. Louis, Mo.

1651 Enc 1 Pg 19

Lab Form D-24



Vibration Axis: 8
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (10 to 100)

Relative db (20 db/decade)

Graph Number: 2M

Pickup Serial Number: 224 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: TP2 Sweep Speed: 1.0 oct/minute Date: 1 00 77
 Pickup Sensing Axis: 8 Live Tape Time: 1212

Plotted by: *Watts*


Checked by: *WS*



Test Item: *VALVE*

Serial Number(s): *JTB#199*

Unit: Operational Non-operational



Vibration Axis: *Z*

Test Condition: *DE-ENERGIZED*

Unfiltered Filtered

F1 *5* Hz Bw (*3* to *10*)

F2 *10* Hz Bw (*10* to *100*)

1651 Enc 1 Pg. 20

Lab Form D-24

Pickup Serial Number: *RB40*

Pickup Location: *TP 3*

Pickup Sensing Axis: *Z*

Pickup Sensitivity: *100.0* $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: *1.0* oct/minute

Live Tape

Job Number: *401797*

Date: *1 Oct 77*

Time: *1212*

Relative db (20 db/decade)


Graph Number:

2N1

Plotted by: *[Signature]*
 Checked by: *[Signature]*



Test Item: VALVES
 Serial Number(s): JTR#1 → 9
 Unit: Operational Non-operational



Vibration Axis: Z
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 21

Lab Form D-24

Pickup Serial Number: 459 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: TP 4 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Z Live Tape Time: 1212

Relative db (20 db/decade)


Graph Number: 20

Plotted by: *Wetters*

Checked by: *US*



Test Item: *VALVE*
Serial Number(s): *DTB #1 → 9*
Unit: Operational Non-operational



Vibration Axis: *Z*
Test Condition: *DE-EVER (100)*
 Unfiltered Filtered
F1 *5* Hz Bw (*3* to *10*)
F2 *10* Hz Bw (*10* to *100*)

1651 Enc 1 Pg 22

Lab Form D-24

Pickup Serial Number: *246*
Pickup Location: *TP 6*
Pickup Sensing Axis: *Z*

Pickup Sensitivity: *100.0* $\frac{mv \text{ peak}}{g \text{ peak}}$
Sweep Speed: *1.0* oct/minute
 Live Tape

Job Number: *401797*
Date: *1 OCT 77*
Time: *1212*

Relative db (20 db/decade)


Graph Number:

27

Plotted by: *Wetters*
 Checked by: *W*



Test Item: *VALVE*
 Serial Number(s): *DTR #1-9*
 Unit: Operational Non-operational



1651 Enc 1 Pg 23

Lab Form D-24

Pickup Serial Number: *149209*
 Pickup Location: *TR 7*
 Pickup Sensing Axis: *Z*

Pickup Sensitivity: *100.0* $\frac{mv \text{ peak}}{g \text{ peak}}$
 Sweep Speed: *1.0* oct/minute
 Live Tape

Job Number: *401797*
 Date: *1 OCT 77*
 Time: *1212*

Relative db (20 db/decade)

Graph Number: *29*

Plotted by: *Wetts*


Checked by: *WS*



Test Item: *VALVE*

Serial Number(s): *DTB #1 -> 9*

Unit: Operational Non-operational



Vibration Axis: *B*

Test Condition: *DE-ENEL (R)*

Unfiltered Filtered

F1 *5* Hz Bw (*3* to *10*)

F2 *10* Hz Bw (*10* to *100*)

Pickup Serial Number: *FH04*

Pickup Location: *TP 8*

Pickup Sensing Axis: *Z*

Pickup Sensitivity: *100.0* $\frac{\text{mv peak}}{\text{g peak}}$

Sweep Speed: *1.0* oct/minute

Live Tape

Job Number: *401797*


Date: *1 OCT 77*

Time: *1212*

Plotted by: J. Wetts
Checked by: J. Wetts



Test Item: VALVES
Serial Number(s): JTR#1-9
Unit: Operational Non-operational



Vibration Axis: Z
Test Condition: DE-EMER (R)
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 25

Lab Form D-24

Relative db (20 db/Decade)

Graph Number: 25


Pickup Serial Number: CT68 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 40.1797
Pickup Location: TP 9 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
Pickup Sensing Axis: Z Live Tape Time: 1212

Test Item: VALVE
 Serial Number(s): JTB #1 → 9
 Unit: Operational Non-operational

Plotted by: W. J. [Signature]
 Checked by: WJ



1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1



1651 Enc 1 Pg 26

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 21

Pickup Serial Number: 46794 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 4-1797
 Pickup Location: Control Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: Y Live Tape Time: 1212

Plotted by: G HEINLEIN


Checked by: *WJ*



Test Item: VALVES

Serial Number(s): DTR # 179

Unit: Operational Non-operational



Vibration Axis: *Y*

Test Condition: *SURVEY ENERGIZED*

Unfiltered Filtered

F1 *3* Hz Bw (*3* to *10*)

F2 *10* Hz Bw (*10* to *100*)

1651 Enc 1 Pg 27

Lab Form D-24

Pickup Serial Number: YG79Y

Pickup Location: Control

Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape


Job Number: 401797

Date: 1 Oct 77

Time: 1950

Relative db (20 db/decade)

Graph Number: 49



Plotted by: G. HEINLEIN


Checked by: WS



Test Item: VALUES

Serial Number(s): DTB-1-9

Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: SURVEY ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 28

Lab Form D-24

Pickup Serial Number: YG 79Z

Pickup Location: Control X-Talk

Pickup Sensing Axis: Z

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 1950

Relative db (20 db/decade)

Graph Number: 473

Plotted by: P. Evans


Checked by: US



Test Item: VALVES

Serial Number(s): DTR # 1 - 9

Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 29

Lab Form D-24

Pickup Serial Number: 456

Pickup Location: VALVE 1

Pickup Sensing Axis: Y

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1 oct/minute

Live Tape

Job Number: 401797

Date: 1 OCT 77

Time: 1750


Relative db (20 db/decade)

Graph Number: 4C



Test Item: VALUES
 Serial Number(s): DTB#179
 Unit: Operational Non-operational

Plotted by: G. HEINLEIN
 Checked by: WS



Vibration Axis: Y
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 30

Lab/Form D-24

Pickup Serial Number: 224
 Pickup Location: Value #2
 Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$
 Sweep Speed: 1.0 oct/minute
 Live Tape

Job Number: 401797
 Date: 1 OCT 77
 Time: 1950

Relative db (20 db/decade)


Graph Number:

57

Plotted by: G. HEINLEIN
 Checked by: US



Test Item: VALVES
 Serial Number(s): DTB #1 → 9
 Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 31

Lab Form D-24

Relative db (20 db/decade)


Graph Number: 4E

Pickup Serial Number: A10410 Pickup Sensitivity: 100.0 $\frac{\text{mv peak}}{\text{g peak}}$ Job Number: 401797
 Pickup Location: Valve #3 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Y Live Tape Time: 1950

Plotted by: W. Penner
Checked by: US



Test Item: VALVES
Serial Number(s): JTB#159
Unit: Operational Non-operational



Vibration Axis: Y
Test Condition: ENERGIZED
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 1.0 Hz Bw (10 to 100)

1651 Enc 1 Pg 32

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 45

Pickup Serial Number: 459 Pickup Sensitivity: 100.0 $\frac{mv\ peak}{g\ peak}$ Job Number: 401797
Pickup Location: VALVE 4 Sweep Speed: 1 oct/minute Date: 10/27
Pickup Sensing Axis: Y Live Tape Time: 1950

Plotted by: *L. Heindel*


Checked by: *MS*



Test Item: *VALVES*

Serial Number(s): *DTR #129*

Unit: Operational Non-operational



Vibration Axis: *Y*
 Test Condition: *ENERGIZED*
 Unfiltered Filtered
 F1 *5* Hz Bw (*3* to *10*)
 F2 *10* Hz Bw (*10* to *100*)

1651 Enc 1 Pg 33

Relative db (20 db/decade)


Graph Number: *45*

Lab Form D-24

Pickup Serial Number: *CQ43*
 Pickup Location: *VALVE # 5*
 Pickup Sensing Axis: *Y*

Pickup Sensitivity: *100.0* $\frac{\text{mv peak}}{\text{g peak}}$
 Sweep Speed: *1.0* oct/minute
 Live Tape


Job Number: *401797*
 Date: *1 Oct 77*
 Time: *1950*



Plotted by: G. HEINLEIN
 Checked by: [Signature]



Test Item: VALVES
 Serial Number(s): DTR 2179
 Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: EVER6PRO
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 34

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 44

Pickup Serial Number: 246 Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$ Job Number: 401797
 Pickup Location: VALVE 6 Sweep Speed: 1 oct/minute Date: 10/77
 Pickup Sensing Axis: Y Live Tape Time: 1950

Plotted by: G. HEINLEIN

Checked by: [Signature]



Test Item: VALVES

Serial Number(s): DTB #179

Unit: Operational Non-operational

Vibration Axis: Y

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 35

Lab/Form D-24



Pickup Serial Number: 149 209

Pickup Location: VALVE 7

Pickup Sensing Axis: Y

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 1950

Relative db (20 db/decade)


Graph Number: 4 H



Plotted by: PELLER
 Checked by: [Signature]



Test Item: VALVES
 Serial Number(s): DTR # 179
 Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: ENERGISED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 36

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 47

Pickup Serial Number: FA 04 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 8 Sweep Speed: 1 oct/minute Date: 1 Oct 50
 Pickup Sensing Axis: Y Live Tape Time: 1950

Plotted by: G HEINLEIN
Checked by: MS




Test Item: VALVES
Serial Number(s): DTB #179
Unit: Operational Non-operational

Vibration Axis: Y
Test Condition: ENERGIZED
 Unfiltered Filtered
F1: 6 Hz Bw (3 to 10)
F2: 10 Hz Bw (10 to 10.5)

1651 Enc 1 Pg 37

Lab/Form D-24



Pickup Serial Number: CT68
Pickup Location: 9
Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$
Sweep Speed: 1.0 oct/minute
 Live Tape

Job Number: 401797
Date: 1 Oct 77
Time: 1950


Relative db (20 db/decade)

Graph Number: 4K

Plotted by: P. E. W. R.
 Checked by: W. S.



Test Item: VALVES
 Serial Number(s): DTR #1 → 9
 Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw: (3 to 10)
 F2: 10 Hz Bw: (10 to 100)

1651 Enc I Pg 38

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 47

Pickup Serial Number: 456 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 1 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: Y Live Tape Time: 2000

Plotted by: W. PELCENZ


Checked by: WS



Test Item: VALVES

Serial Number(s): DTB # 1-9

Unit: Operational Non-operational



1651 Enc 1 Pg 39

Lab Form D-24

Pickup Serial Number: 224

Pickup Location: VALVE 2

Pickup Sensing Axis: Y

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 2000

Relative db (20 db/decade)

Graph Number: 40

Plotted by: W. PELLENZ


Checked by: WS



Test Item: VALVES

Serial Number(s): DTB #179

Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition DE-ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 40

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 4M

Pickup Serial Number: AB40

Pickup Location: VALVE #3

Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401.797

Date: 1 Oct 77

Time: 2000

Plotted by: W. PELLENZ


Checked by: WS



Test Item: VALVES

Serial Number(s): DTR #179

Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc I Pg 41

Lab/Form D-24

Relative db (20 db/decade)

Graph Number: 4N

Pickup Serial Number: 459

Pickup Location: VALVE #4

Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv\ peak}{g\ peak}$


Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 2000



Plotted by: W. PELLENZ


Checked by: MS



Test Item: VALVES

Serial Number(s): DTR # 179

Unit: Operational Non-operational



Vibration Axis: Y

Test Condition DE-ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 42

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 419

Pickup Serial Number: CQ43

Pickup Location: VALVE #5

Pickup Sensing Axis: Y

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797


Date: 1 Oct 77

Time: 2000

Plotted by: W. DELLENZ
Checked by: MS



Test Item: VALUES
Serial Number(s): JTB # 179
Unit: Operational Non-operational



Vibration Axis: Y
Test Condition: DA-ENERGIZED
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 43

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 49


Pickup Serial Number: 246 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
Pickup Location: VALVE #C Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
Pickup Sensing Axis: Y Live Tape Time: 2.000



Plotted by: PELLERZ
 Checked by: WS



Test Item: VALVES
 Serial Number(s): JTB 2179
 Unit: Operational Non-operational



Vibration Axis: Y
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 44

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 4R

Pickup Serial Number: 149229 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 7 Sweep Speed: 1.0 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: Y Live Tape Time: 2000


Plotted by: W. Peller
 Checked by: WS



Test Item: VALVES
 Serial Number(s): DTB # 179
 Unit: Operational Non-operational

1651 Enc 1 Pg 45

Lab Form D-24



Vibration Axis: Y
 Test Condition: DEENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

Pickup Serial Number: FA04 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 8 Sweep Speed: 1. oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: Y Live Tape Time: 2000

Relative db (20 db/decade)


Graph Number: 45



Test Item: VALVES
 Serial Number(s): DTB 1199
 Unit: Operational Non-operational



Plotted by: PELLENZ
 Checked by: [Signature]



Vibration Axis: Y
 Test Condition: DE ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 46

Lab Form D-24

Relative db (20 db/decade)


Graph Number: 41

Pickup Serial Number: CT68
 Pickup Location: VALVE 9
 Pickup Sensing Axis: Y
 Pickup Sensitivity: 100.0 $\frac{\text{mv peak}}{\text{g peak}}$
 Sweep Speed: 1.0 oct/minute
 Live Tape
 Job Number: 401797
 Date: 1 Oct 77
 Time: 2000

Plotted by: W. P. RENEW
 Checked by: WS



Test Item: VALVES
 Serial Number(s): STB #1 → 9
 Unit: Operational Non-operational



Vibration Axis: X
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 47

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 69

Pickup Serial Number: Y679X Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401997
 Pickup Location: CONTROL Sweep Speed: 1 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: X Live Tape Time: 2225



Plotted by: PELLENZ


Checked by: US



Test Item: VALVES

Serial Number(s): DTR # 1 → 9

Unit: Operational Non-operational



Vibration Axis: X

Test Condition DE-ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 48

15b Form D-24

Relative db (20 db/decade)

Graph Number: 613

Pickup Serial Number: 224

Pickup Location: VALVE #2

Pickup Sensing Axis: X

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 2225

Plotted by: Pellenz


Checked by: AS



Test Item: VALVES

Serial Number(s): DTB #1-9

Unit: Operational Non-operational



Vibration Axis: X

Test Condition: DEENERGIZED

Unfiltered Filtered

F1: 5 Hz Bw (3 to 10)

F2: 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 49

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 6C

Pickup Serial Number: AB40 Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$ Job Number: 401797

Pickup Location: VALVE 3 Sweep Speed: 1 oct/minute Date: 1 Oct 77

Pickup Sensing Axis: X Live Tape Time: 22 25



Plotted by: PELLERZ


Checked by: WF



Test Item: VALVES

Serial Number(s): DTR # 179

Unit: Operational Non-operational



1651 Enc 1 Pg 50

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 67

Pickup Serial Number: 459

Pickup Location: VALVE 4

Pickup Sensing Axis: X

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797


Date: 1 Oct 77

Time: 0225

Plotted by: PELLENZ
Checked by: WS



Test Item: VALVES
Serial Number(s): DTR # 179
Unit: Operational Non-operational



Vibration Axis: X
Test Condition: DE-ENERGIZED
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 51

Lab Form D-24

Pickup Serial Number: CQ43 Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$ Job Number: 401797
Pickup Location: VALVE 5 Sweep Speed: 1 oct/minute Date: 1 OCT 77
Pickup Sensing Axis: X Live Tape Time: 2225

Relative db (20 db/decade)

Graph Number: 6E

Plotted by: PELLENZ


Checked by: WS



Test Item: VALVES

Serial Number(s): DTB #179

Unit: Operational Non-operational



1651 Enc 1 Pg 52

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 10F

Pickup Serial Number: 246

Pickup Location: VALVE #6

Pickup Sensing Axis: X

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797


Date: 1 Oct 77

Time: 2225

Plotted by: PELLERZ
 Checked by: [Signature]



Test Item: VALVES
 Serial Number(s): JTB # 179
 Unit: Operational Non-operational



Vibration Axis: X
 Test Condition: DE-ENERGIZED
 Unfiltered Filtered
 F1: 5 Hz Bw (3 to 10)
 F2: 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 53

Lab Form D-24


Relative db (20 db/decade)

Graph Number: 65

Pickup Serial Number: 149209 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 7 Sweep Speed: 1 oct/minute Date: 1 OCT 77
 Pickup Sensing Axis: X Live Tape Time: 2225

Test Item: VALUES
 Serial Number(s): DTB # 1-9
 Unit: Operational Non-operational

Plotted by: PELLERZ
 Checked by: WB



1651 Enc 1 Pg 54

Lab Form D-24

Pickup Serial Number: FH04
 Pickup Location: VALUE 8
 Pickup Sensing Axis: X X

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$
 Sweep Speed: 1.0 oct/minute
 Live Tape

Job Number: 401797
 Date: 1 Oct 77
 Time: 2225

Relative db (20 db/decade)

Graph Number: GH


Plotted by: PELLENZ
 Checked by: [Signature]



Test Item: VALVES
 Serial Number(s): DTR #179
 Unit: Operational Non-operational

1651 Enc 1 Pg 55

Lab Form D-24



Vibration Axis: X
 Test Condition: DEENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

Relative db (20 db/decade)

Graph Number: 67

Pickup Serial Number: CT68 Pickup Sensitivity: 1.00 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 9 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: X Live Tape Time: 2225



Plotted by: PELENE


Checked by: WS



Test Item: VAVES

Serial Number(s): DTB # 1 → 9

Unit: Operational Non-operational



Vibration Axis: X

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 56

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 107

Pickup Serial Number: 46772

Pickup Location: Control

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 71

Time: 2240

Plotted by: G. HEINLEIN

Checked by: MS




Test Item: VALVES

Serial Number(s): DTB # 179

Unit: Operational Non-operational

1651 Enc 1 Pg 57

Lab Form D-24



Vibration Axis: X

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

Pickup Serial Number: 224

Pickup Location: VALVE #2

Pickup Sensing Axis: X

Pickup Sensitivity: 100.0 $\frac{mv\ peak}{g\ peak}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77


Time: 2240

Relative db (20 db/decade)

Graph Number: 10K

Test Item: VALVES
 Serial Number(s): DTB #179
 Unit: Operational Non-operational

Plotted by: PELLER
 Checked by: DS



Vibration Axis: X
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 58

Lab Form D-24

Pickup Serial Number: AB40 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 3 Sweep Speed: 1 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: X Live Tape Time: 2240

Relative db (20 db/decade)

Graph Number: 107

Plotted by: G. HEINLEIN


Checked by: [Signature]



Test Item: VALVES

Serial Number(s): DTB #179

Unit: Operational Non-operational



Vibration Axis: X

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (5 to 10)

F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 59

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 100

Pickup Serial Number: 459

Pickup Location: VALVE #21

Pickup Sensing Axis: X

Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77


Time: 2240



Plotted by: PELLENZ
 Checked by: WJ



Test Item: VALVES
 Serial Number(s): DTB #179
 Unit: Operational Non-operational



Vibration Axis: X
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 60

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 421

Pickup Serial Number: C043 Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 5 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: X Live Tape Time: 2240

Plotted by: H. ZINLEN


Checked by: AS



Test Item: VALVES

Serial Number(s): DTR # 1-9

Unit: Operational Non-operational



Vibration Axis: X

Test Condition: ENERGIZED

Unfiltered Filtered

F1 5 Hz Bw (3 to 10)

F2 10 Hz Bw (10 to 100)

Relative db (20 db/decade)

Graph Number: 60

Pickup Serial Number: 246

Pickup Location: VALVE 6

Pickup Sensing Axis: X

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 Oct 77

Time: 2240

1651 Enc 1 Pg 61

Lab Form D-24



Plotted by: PELLENTZ

Checked by: WS



Test Item: VALVES

Serial Number(s): DTR # 1-9

Unit: Operational Non-operational



Vibration Axis: X

Test Condition: ENERGIZED

Unfiltered Filtered

F1: 5 Hz Bw (3 to 10)

F2: 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 62

9

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 10P

Pickup Serial Number: 149209

Pickup Location: VALVE 7

Pickup Sensing Axis: X

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Sweep Speed: 1.0 oct/minute

Live Tape

Job Number: 401797

Date: 1 OCT 77


Time: 2240

Plotted by: G HEINLEIN
Checked by: WB



Test Item: VALVES
Serial Number(s): DIB #1-9
Unit: Operational Non-operational

1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1



Vibration Axis: X
Test Condition ENERGIZED
 Unfiltered Filtered
F1 5 Hz Bw (3 to 10)
F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 63

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 68

Pickup Serial Number: FH04 Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
Pickup Location: VALVE #8 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
Pickup Sensing Axis: X Live Tape Time: 2240




Test Item: VALVES
 Serial Number(s): DTB#179
 Unit: Operational Non-operational

Plotted by: PELLET
 Checked by:



1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1 2 3 4 5 6 7 8 9 1



Vibration Axis: X
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

1651 Enc 1 Pg 64

Lab Form D-24

Relative db (20 db/decade)

Graph Number: 408

Pickup Serial Number: CT68 Pickup Sensitivity: 1.00 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: VALVE 9 Sweep Speed: 1.0 oct/minute Date: 1 Oct 77
 Pickup Sensing Axis: X Live Tape Time: 2740


Plotted by: PELLER
 Checked by: WS



Test Item: VALVES
 Serial Number(s): DTB # 179
 Unit: Operational Non-operational

1651 Enc 1 Pg 65

Lab Form D-24



Vibration Axis: X
 Test Condition: ENERGIZED
 Unfiltered Filtered
 F1 5 Hz Bw (3 to 10)
 F2 10 Hz Bw (10 to 100)

Pickup Serial Number: YG 79 Y Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 40 1797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 10/9/77
 Pickup Sensing Axis: Y Live Tape Time: 2:40


Relative db (20 db/decade)

Graph Number: 65



Test Item: VALVES
 Serial Number(s): JTB# 179
 Unit: Operational Non-operational

Plotted by: R. Rankin
 Checked by: WJ



1651 Enc 1 Pg 66

Lab Form D-24

Relative db (20 db/decade)

Graph Number: SA

Pickup Serial Number: YG79 Y Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 5 OCT 77
 Pickup Sensing Axis: Y Live Tape Time: 1430


Plotted by: B. Park
 Checked by: W



Test Item: VALVES
 Serial Number(s): DTB#179
 Unit: Operational Non-operational

1651 Enc 1 Pg 67

Lab Form D-24




Vibration Axis: Z
 Test Condition: SURVEY
 Unfiltered Filtered
 F1 5 Hz Bw (5 to 5)
 F2 10 Hz Bw (10 to 33)

Relative db (20 db/decade)

Graph Number: 9A

Pickup Serial Number: 4679Z Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 5 Oct 77
 Pickup Sensing Axis: Z Live Tape Time: 1547




Plotted by: W. PELLEZ
 Checked by: US



Test Item: VALVES
 Serial Number(s): DTB #179
 Unit: Operational AS NOTED BELOW Non-operational

1651 Enc 1 Pg 68

Lab Form D-24



Vibration Axis: X
 Test Condition: SURVEY
 Unfiltered Filtered
 F1 3 Hz Bw (5 to 5)
 F2 10 Hz Bw (10 to 33)

Pickup Serial Number: YG 79 X Pickup Sensitivity: 100.0 $\frac{mv \text{ peak}}{g \text{ peak}}$ Job Number: 401797
 Pickup Location: CONTROL Sweep Speed: 1.0 oct/minute Date: 50 OCT 77
 Pickup Sensing Axis: X Live Tape Time: 1700

Relative db (20 db/decade)

Graph Number: 109

TEST EQUIPMENT

TEST: VIBRATION

| ITEM | MANUFACTURER | MODEL | S/N | ACCURACY |
|--------------------|-------------------|----------|----------------|---------------------|
| Vibration Exciter | M. B. Electronics | C-126 | 178 | Transfer Instrument |
| Power Amplifier | M. B. Electronics | 4450 | 205 | Transfer Instrument |
| Sweep Oscillator | Spectral Dynamics | SD104A-5 | 187 | $\pm 2\%$ |
| Servo Monitor | Spectral Dynamics | SD105A | 140 | $\pm 4\%$ |
| TRMS Voltmeter | Ballantine | N321 | 403 | $\pm 4\%$ |
| Electronic Counter | Monsanto | 103A | 503 | ± 1 Count |
| Dynamic Analyzer | Spectral Dynamics | SD101B | 53 | ± 0.25 dB |
| Dynamic Analyzer | Spectral Dynamics | SD101B | 675 | ± 0.25 dB |
| Filter | Spectral Dynamics | AR-5 | 289 | Mfr. Spec. |
| Filter | Spectral Dynamics | AR-5 | 290 | Mfr. Spec. |
| Filter | Spectral Dynamics | AR-10 | 711 | Mfr. Spec. |
| Filter | Spectral Dynamics | AR-10 | 055 | Mfr. Spec. |
| Log Converter | Hewlett Packard | 7562A | 1211A 01452 | ± 1 dB |
| Log Converter | Hewlett Packard | 7562A | 1211A 01452 | ± 1 dB |
| X-Y Recorder | Hewlett Packard | 7035B | 1543A11 724 | $\pm 1\%$ |

Test equipment utilized for the program reported herein was within its assigned interval of calibration. Details are on file at Dayton T. Brown, Inc. and will be made available upon request.

TEST EQUIPMENT

TEST: VIBRATION

| ITEM | MANUFACTURER | MODEL | S/N | ACCURACY |
|------------------|-----------------|---------------|----------------|----------------|
| X-Y Recorder | Hewlett Packard | 7035B | 1320A 07559 | $\pm 1\%$ |
| Timer | Dimco Gray | 171 | 47-120 | ± 1 Second |
| Charge Amplifier | Unholtz Dickie | 11MGV SLF1 | EO-44 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-64 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-66 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-68 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-70 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 11MGV SLF1 | EO 46 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-47 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 8PMCV | 50-53 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 11MGV SLF1 | EO 40 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | 11MGV SLF1 | EO 49 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | D11MSV 82 | C467 | $\pm 5\%$ |
| Charge Amplifier | Unholtz Dickie | D11MSV 82 | C470 | $\pm 5\%$ |
| Accelerometer | Unholtz Dickie | 5D21 | 199 | $\pm 5\%$ |

Test equipment utilized for the program reported herein was within its assigned interval of calibration. Details are on file at Dayton T. Brown, Inc. and will be made available upon request.

TEST EQUIPMENT


TEST: VIBRATION

| ITEM | MANUFACTURER | MODEL | S/N | ACCURACY |
|---------------|------------------|--------|--------|----------|
| Accelerometer | Unholtz Dickie | 5D21 | 224 | ± 5% |
| Accelerometer | Unholtz Dickie | 5D21-8 | 246 | ± 5% |
| Accelerometer | Unholtz Dickie | 5D21 | 456 | ± 5% |
| Accelerometer | Unholtz Dickie | 5D21 | 459 | ± 5% |
| Accelerometer | M.B. Electronics | 303 | 149209 | ± 5% |
| Accelerometer | Endevco | 2226C | AB40 | ± 5% |
| Accelerometer | Endevco | 2226C | CQ43 | ± 5% |
| Accelerometer | Endevco | 2226C | CT68 | ± 5% |
| Accelerometer | Endevco | 2228C | YG79 | ± 5% |
| Accelerometer | Endevco | 2233 | FH04 | ± 5% |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Test equipment utilized for the program reported herein was within its assigned interval of calibration. Details are on file at Dayton T. Brown, Inc. and will be made available upon request.




Enclosure 2
Photographs



TESTED FOR: ISOVEDIX INC. ITEM: SOLENOID VALVES S/N: DTB# 1 - 9
TYPICAL VIBRATION TEST SETUP AXES DESIGNATION
JOB NO: 401797-00-000 FILE NO: 1516 DATE: 1 OCTOBER 1977
DTBOK77-1651 ENCLOSURE: 2 PHOTO: 1

DAYTON T. BROWN INC.
Testing Laboratories



TESTED FOR: ISOHEDEX INC.
JOB NO: 401797-00-000
DTR04877-1651

ITEM: SOLENOID VALVE
TYPICAL VIBRATION TEST SETUP
FILE NO: 1541
ENCLOSURE: 2

S/N: DTR# 6
DATE: 6 OCTOBER 1977
PHOTO: 2

DAYTON T. BROWN INC.
Testing Laboratories

F/12

MA-206-380-3RF

0-150 PSIG

AC Solenoid

pressure at port 2

Solenoid energized - check for pressure decrease at port 1

Solenoid de-energized - check for pressure increase at port 1

check for proper shifting at each cycle.

F/11 G-LEVELS REACHED FOR % BAC / % PRES

| FREQ | MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|--------------------------|--------|----|-----|--------|----|-----|--------|----|-----|--------|----|-----|--------|----|-----|--------|----|-----|
| | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| 1 | 0.30 | OK | | |
| 1 1/3 | .56 | | | | | | | | | | | | | | | | | | |
| 1 2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.2 | | | | | | | | | | | | | | | | | | |
| 2 2/3 | 1.5 | | | | | | | | | | | | | | | | | | |
| 3 1/3 | 1.8 | | | | | | | | | | | | | | | | | | |
| 4 | 2.3 | | | | | | | | | | | | | | | | | | |
| 5 1/3 | 2.9 | | | | | | | | | | | | | | | | | | |
| 6 2/3 | 3.8 | | | | | | | | | | | | | | | | | | |
| 8 | 4.5 | | | | | | | | | | | | | | | | | | |
| 10 2/3 | ↑ | | | | | | | | | | | | | | | | | | |
| 13 1/3 | | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | | |
| 21 1/3 | | | | | | | | | | | | | | | | | | | |
| 26 2/3 | | | | | | | | | | | | | | | | | | | |
| 32 | ↑ | | | | | | | | | | | | | | | | | | |
| 33 | 4.5 | | | | | | | | | | | | | | | | | | |

VALVE NO 4 TYPE: _____ SOLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 0.25 PART* AT D. SHAKK: Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON PARTS 1/2 &

F/10 G-LEVELS REACHED FOR % BACK PRESS.

| MIN PEAK RPM FREQ | Y-AXIS % INCREASES / % DECREASE | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|----------------------------|---------------------------------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|
| | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | 0 | 8 | 15 | 50 | 142 | 135 | 0 | 8 | 15 | 50 | 142 | 135 | 0 | 8 | 15 | 50 | 142 | 135 |
| 1 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1 1/3 | | | | | | | | | | | | | | | | | | |
| 1 2/3 | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | |
| 2 2/3 | | | | | | | | | | | | | | | | | | |
| 3 1/3 | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | |
| 5 1/3 | | | | | | | | | | | | | | | | | | |
| 6 2/3 | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | |
| 10 2/3 | | | | | | | | | | | | | | | | | | |
| 13 1/3 | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | |
| 21 1/3 | | | | | | | | | | | | | | | | | | |
| 26 2/3 | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | |
| 33 | 4.5 | | | | | | | | | | | | | | | | | |

VALVE N° 4 TYPE: HV206-3RD-3RF GLENOID ATTITUDE: Z-AXIS

INLET PRESSURE 150
102 VAC

PART # AT D. SHAKG:
WHEN Y-AXIS

*PART MAY BE: LEVER DIAPHR. &, PISTON, PORTS 1 & 2 &

F/9

XFT 831654V

10-125 PSIG

AC Solenoid

Pressure at port P



Solenoid energized - check for pressure decrease at port A

Solenoid de-energized - check for pressure increase at port A

Check for proper shifting at each cycle

BACK OF F/8

⊙ Z




F/8

G-LEVELS REACHED FOR % BAL PRESS

| REQ | MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|-----------------------|------------|----|------|------------|-----|-----|--------|----|------|--------|-----|-----|--------|----|------|--------|-----|-----|
| | | % INCREASE | | | % DECREASE | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 0 | 6 | 12.5 | 0 | 119 | 112 | 0 | 6 | 12.5 | 0 | 119 | 112 | 0 | 6 | 12.5 | 0 | 119 | 112 |
| 1 | .30 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 1 1/3 | .56 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 1 2/3 | .85 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 2 | 1.2 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 2 2/3 | 1.5 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 3 1/3 | 1.8 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 4 | 2.3 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 5 1/3 | 2.9 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 6 2/3 | 3.8 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 8 | 4.5 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 10 2/3 | A | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 13 1/3 | | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 16 | | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 21 1/3 | | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 26 2/3 | | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 32 | Y | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |
| 33 | 4.5 | OK | | OK | | OK | OK | | OK | | OK | | OK | | OK | OK | | OK | |

NOTE: INSTANTANEOUS PULSATIONS TO 110-120 PSIG
 Note: All testing done at machine limit.

VALVE N°3 TYPE: XFT8316 54V SOLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 125 PART* AT D. SHARK'S WHEN:
 102 VAC Y-AXIS

*PART MAY BE: LEVER, DIAPHR. , PISTON, PORTS 1 & 2 

F/7 G-LEVELS REACHED FOR % BAC PRESS.

| MIN PEAK RIM | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------------|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|
| | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| FREQ | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 |
| PSI | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 |
| D.A | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 |
| 1 | 0.30 | OK | | OK | | |
| 1 1/3 | 0.56 | OK | | OK | | |
| 2 2/3 | 0.85 | OK | | OK | | |
| 2 | 1.2 | OK | | OK | | |
| 2 2/3 | 1.5 | OK | | OK | | |
| 3 1/3 | 1.8 | OK | | OK | | |
| 4 | 2.3 | OK | | OK | | |
| 5 1/3 | 2.9 | OK | | OK | | |
| 6 2/3 | 3.8 | OK | | OK | | |
| 8 | 4.5 | OK | | OK | | |
| 10 2/3 | 4 | OK | | OK | | |
| 13 1/3 | | OK | | OK | | |
| 16 | | OK | | OK | | |
| 21 1/3 | | OK | | OK | | |
| 26 2/3 | | OK | | OK | | |
| 32 | 4 | OK | | OK | | |
| 36 | 4.5 | OK | | OK | | |

Note: All testing done at machine limit

VALVE NO 3 TYPE: XFT8316.54V SOLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 10 PART # AT D. WHEN SHAKK: Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON PARTS 1, 2 & 3

F/6

NP8344A7/E

10-125 PSIG

D.C. Solenoid

pressure at port P

Solenoid energized - check for pressure decrease at port B and increase at port A

Solenoid de-energized - check for pressure increase at port B and decrease at port A.

Check for proper shifting at each cycle.

F/5 G-LEVELS REACHED FOR % BAL PRESS.

| REQ | MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|--------------------------|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|
| | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | |
| | | 0 | 5% | 10% | 0 | 5% | 90% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 0 | 9.5 | 9.0 |
| 1 | .30 | OK | | |
| 1 1/3 | .56 | OK | | |
| 1 2/3 | .85 | OK | | |
| 2 | 1.2 | OK | | |
| 2 2/3 | 1.5 | OK | | |
| 3 1/3 | 1.8 | OK | | |
| 4 | 2.3 | OK | | |
| 5 1/3 | 2.9 | OK | | |
| 6 2/3 | 3.8 | OK | | |
| 8 | 4.5 | OK | | |
| 10 2/3 | ↑ | OK | | |
| 13 1/3 | ↑ | OK | | |
| 16 | ↑ | OK | | |
| 21 1/3 | ↑ | OK | | |
| 26 2/3 | ↑ | OK | | |
| 32 | ↑ | OK | | |
| 33 | 4.5 | OK | | |

Note: All levels direct machine limit

VALVE NO 2 TYPE:


INLET PRESSURE 10

SOLENOID ATTITUDE: Z-AXIS

PART* AT D. SHARK WHEN Y-AXIS

*PART MAY BE: LEVER. DIAPHR. & PISTON PARTS 1 & 2

BACK OF F/4



F/4 G-LEVELS REACHED FOR % BACK PRESS.

| MIN. PEAK RIM FREQ | Y-AXIS % INCREASE | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------------------|-------------------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|
| | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | | DE-EN. | | | ENERG. | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | 0 | 6 | 125 | 0 | 119 | 112 | 0 | 6 | 125 | 0 | 119 | 112 | 0 | 6 | 125 | 0 | 119 | 112 |
| 1 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1 1/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1 2/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 2 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 2 2/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 3 1/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 4 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 5 1/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 6 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 8 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 10 2/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 13 1/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 16 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 21 1/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 26 2/3 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 32 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 33 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |

Note: All testing done at machine direct

VALVE NO 2 TYPE: NP834471E SOLENOID ATTITUDE: Z-AXIS

INLET PRESSURE 125 PART* AT D. SHARK WHEN: Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON PORTS 1 & 2 &

F/3

HVA-206-381-6F

0-125 PSIG

DC Solenoid

pressure at part B

Solenoid energized - check for pressure decrease at part A

Solenoid de-energized - check for pressure increase at part A

check for proper shifting at each cycle

F/2 G-LEVELS REACHED FOR % BAL PRESS

| MIN PEAK RIM FREQ | Y-AXIS % | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|----------------------------|----------|--------|-----|----------|--------|-----|--------|--------|-----|-------|--------|-----|--------|--------|-----|------|----|--|
| | INCREASE | | | DECREASE | | | | | | | | | | | | | | |
| | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | | | |
| PSI | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | |
| 1 | 0.30 | OK | OK | 0.25 | | | 0 | | | 0.25 | | | 0 | | | 0.25 | | |
| 1 1/3 | .56 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 1 2/3 | .85 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 | 1.2 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 2/3 | 1.5 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 3 1/3 | 1.8 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 4 | 2.3 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 5 1/3 | 2.9 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 6 2/3 | 3.8 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 8 | 4.5 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 10 2/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 13 1/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 16 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 21 1/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 26 2/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 32 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 33 | 4.5 | | | | | | OK | | | OK | | | OK | | | OK | | |

VALVE NO 1 TYPE:

INLET PRESSURE 0.25


PART MAY BE: LEVER, DIAPHR. & PISTON PARTS 1 & 2 &

At the point 1/4

SOLENOID ATTITUDE: Z-AXIS

PART # AT D. SHARK
Y-AXIS

BACK OF F/1



APPENDIX F
OPERATIONAL DATA AT 'DAYTON T. BROWN'


Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

BACK

OF F/12



F/13

G-LEVELS REACHED FOR % BACK PRESS.

| MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | | |
|-----------------------------|------------|----|-----|------------|-----|-----|--------|----|-----|--------|-----|-----|--------|----|-----|--------|----|-----|-----|
| | % INCREASE | | | % DECREASE | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | |
| 0 | 8 | 15 | 50 | 142 | 135 | | 0 | 8 | 15 | 50 | 142 | 135 | | 0 | 8 | 15 | 50 | 142 | 135 |
| 1 | | | OK | | | | OK | | | OK | | | | OK | | | OK | | |
| 1 1/3 | .56 | | | | | | | | | | | | | | | | | | |
| 1 2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.2 | | | | | | | | | | | | | | | | | | |
| 2 2/3 | 1.5 | | | | | | | | | | | | | | | | | | |
| 3 1/3 | 1.8 | | | | | | | | | | | | | | | | | | |
| 4 | 2.3 | | | | | | | | | | | | | | | | | | |
| 5 1/3 | 2.9 | | | | | | | | | | | | | | | | | | |
| 6 2/3 | 3.8 | | | | | | | | | | | | | | | | | | |
| 8 | 4.5 | | | | | | | | | | | | | | | | | | |
| 10 2/3 | A | | | | | | | | | | | | | | | | | | |
| 13 1/3 | | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | | |
| 21 1/3 | | | | | | | | | | | | | | | | | | | |
| 26 2/3 | | | | | | | | | | | | | | | | | | | |
| 32 | 4 | | | | | | | | | | | | | | | | | | |
| 33 | 4.5 | | | | | | | | | | | | | | | | | | |


VALVE N° 5 TYPE: NP 8320A184 EG. OLENOID ATTITUDE: Z-AXIS

INLET PRESSURE 150
102 VAC


PART * AT D. WHEN SHAK'G:
Y-AXIS

* PART MAY BE: LEVER, DIAPHR. &, PISTON, PORTS 1 & 2

BACK OF F/13



NON



F/14 G-LEVELS REACHED FOR % BAL PRESS.

| MIN PEAK RIM FREQ | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|----------------------------|--------|--------|--------|----|-----|----|--------|------|--------|-----|----|--------|--------|----|--------|----|----|------|
| | DE-EN | | ENERG. | | | | DE-EN | | ENERG. | | | | DE-EN | | ENERG. | | | |
| | 0 | 5% 10% | 0 | 5% | 10% | 0 | 5% 10% | 0 | 5% | 10% | 0 | 5% 10% | 0 | 5% | 10% | 0 | 5% | |
| 0 | 0 | | 0.25 | | | 0 | | 0.25 | | | 0 | | 0.25 | | | 0 | | 0.25 |
| 1 | 0 | | | | | OK | | OK | | | OK | | OK | | | OK | | OK |
| 1 1/3 | | | | | | | | | | | | | | | | | | |
| 1 2/3 | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | |
| 2 2/3 | | | | | | | | | | | | | | | | | | |
| 3 1/3 | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | |
| 5 1/3 | | | | | | | | | | | | | | | | | | |
| 6 2/3 | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | |
| 10 2/3 | | | | | | | | | | | | | | | | | | |
| 13 1/3 | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | |
| 21 1/3 | | | | | | | | | | | | | | | | | | |
| 26 2/3 | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | |
| 33 | 4.5 | | | | | | | | | | | | | | | | | |

VALVE NO 5 TYPE: GLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 0.25 PSI PART* AT D. SHAKG.
 Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON PARTS 1, 2 &

F/15

NP8320 A184 E

0-150 PSIG

A.C. Solenoid pressure at port 2

Solenoid energized - check for pressure
decrease at port 1

Solenoid de-energized - check for pressure
increase at port 1

check for paper shifting at each
cycle

F/16

G-LEVELS REACHED FOR % BACK PRESS.

| MIN PEAK RPM | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | | | | | | | |
|--------------------|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|--------|-----|-----|-----|-----|---|----|-----|---|
| | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | | | | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | | | | | |
| FREQ | 0 | 1/2 | 1 | 0 | 9.5 | 9 | 0 | 1/2 | 1 | 0 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 0 | 10 | 9.5 | 9 | | | | |
| 1 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 1 1/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 1 2/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 2 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 2 2/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 3 1/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 4 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 5 1/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 6 2/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 8 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 10 2/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 13 1/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 16 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 21 1/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 26 2/3 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 32 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |
| 33 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 | 0 | 1/2 | 1 | 10 | 9.5 | 9 |

Note: all bearings at machine limit

VALVE NO 6 TYPE:

INLET PRESSURE 10

SOLENOID ATTITUDE: Z-AXIS

PART* AT D. WHEN SHAKK
Y-AXIS

*PART MAY BE: LEVER, DIAPHR. &, PISTON, PORTS 1 & 2 &

10-6-77
R Powell F/17 G-LEVELS REACHED FOR % BACK PRESS.


| REQ | MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|-----------------------|--------|------|-----|--------|-----|-----|--------|------|-----|--------|-----|-----|--------|------|-----|--------|-----|-----|
| | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | 0 | 9 | 17.5 | 135 | 166 | 158 | 0 | 9 | 17.5 | 135 | 166 | 158 | 0 | 9 | 17.5 | 135 | 166 | 158 | |
| 1 | .30 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 1 1/3 | .56 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 1 2/3 | .85 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 2 | 1.2 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 2 2/3 | 1.5 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 3 1/3 | 1.8 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 4 | 2.3 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 5 1/3 | 2.9 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 6 | 3.8 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 8 | 4.5 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 0 2/3 | ↑ | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 3 1/3 | | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 6 | | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 21 1/3 | | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 26 2/3 | | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 32 | ↑ | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |
| 33 | 4.5 | OK | OK | OK | | | OK | | OK | | OK | | OK | | OK | | OK | | |

Note: all testing done at machine limit

VALVE N° 6 TYPE: NP 831665E SOLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 175 PART* AT D. WHEN SHAK'G:
 90 VDC Y-AXIS

*PART MAY BE: LEVER, DIAPHR. ⊕, PISTON, PORTS 1 & 2 ⊕

BACK OF F/17



F/18

NP 831665E

10-175 PSIG

DC Solenoid pressure at part P

Solenoid energized - check for pressure decrease at part A

Solenoid de-energized - check for pressure increase at part A

check for proper shifting at each cycle

4A. F19 G-LEVELS REACHED FOR % BACK PRESSURE



| MIN PEAK RIM FREQ | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|-------------------|------------|----|-----|------------|-----|-----|--------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|
| | % INCREASE | | | % DECREASE | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| 1 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 |
| 1 1/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 2/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 3 1/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 4 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 5 1/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 6 2/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 8 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 10 2/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 13 1/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 16 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 21 1/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 26 2/3 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 32 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 33 | 0 | | | | | | OK | | | OK | | | OK | | | OK | | |

VALVE NO 7 TYPE: HY202-300-2RF SOLENOID ATTITUDE: Z-AXIS
 INLET PRESSURE 200 PART* AT D. SHARK WHEN
 90 VDC Y-AXIS

*PART MAY BE: LEVER DIAPHR. &, PISTON, PARTS 1 & 2 &

BACK OF F/19

⊙Z



F/20 G-LEVELS REACHED FOR % BAL. PRESS.

| MIN PEAK RIM FREQ | Y-AXIS % | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|----------------------------|----------|--------|-----|----------|--------|-----|--------|--------|-----|-------|--------|-----|--------|--------|-----|-------|--------|-----|
| | INCREASE | | | DECREASE | | | | | | | | | | | | | | |
| | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | |
| PSI D.A. | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| 1 | 0.30 | OK | | 0.25 | OK | | 0 | | | 0.25 | | | 0 | | | 0.25 | | |
| 1 1/3 | .56 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 1 2/3 | .85 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 | 1.2 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 2/3 | 1.5 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 3 1/3 | 1.8 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 4 | 2.3 | | | | | | OK | | | OK | | | OK | | | OK | | |
| 5 1/3 | 2.9 | ✓ | | | | | OK | | | OK | | | OK | | | OK | | |
| 6 2/3 | 3.8 | - | .04 | | | | OK | | | OK | | | OK | | | OK | | |
| 8 | 4.5 | - | .05 | | | | OK | | | OK | | | OK | | | OK | | |
| 10 2/3 | 1 | - | .07 | | | | OK | | | OK | | | OK | | | OK | | |
| 13 1/3 | | OK | | | | | OK | | | OK | | | OK | | | OK | | |
| 16 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 21 1/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 26 2/3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 32 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 33 | 4.5 | ✓ | | | | | OK | | | OK | | | OK | | | OK | | |

VALVE NO 7 TYPE: *Balance 5th pin AH*
 INLET PRESSURE 0.25 *2nd Douc. Mir. OK* SOLENOID ATTITUDE: Z-AXIS
 PART* AT D. SHARK Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON PARTS 1 & 2

F/21

HV-202-300-2RF

0-200 PSIG

DC Solenoid

Pressure at port 2

Solenoid energized - check for pressure decrease at port 1

Solenoid de-energized - check for pressure increase at port 1

Check for proper shifting at each cycle.

F/22

G-LEVELS REACHED FOR % BACK PRESS.

| FREQ | MIN PEAK RIM PSI D.A. | Y-AXIS | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|-----------------------|------------|----|-----|------------|-----|-----|--------|----|-----|--------|-----|-----|--------|----|-----|--------|-----|-----|
| | | % INCREASE | | | % DECREASE | | | DE-EN | | | ENERG. | | | DE-EN | | | ENERG. | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 |
| 1 | .30 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1 1/3 | .56 | | | | | | | OK | | | OK | | | | | | | | |
| 1 2/3 | .85 | | | | | | | OK | | | OK | | | | | | | | |
| 2 | 1.2 | | | | | | | OK | | | OK | | | | | | | | |
| 2 2/3 | 1.5 | | | | | | | OK | | | OK | | | | | | | | |
| 3 1/3 | 1.8 | | | | | | | OK | | | OK | | | | | | | | |
| 4 | 2.3 | | | | | | | OK | | | OK | | | | | | | | |
| 5 1/3 | 2.9 | | | | | | | OK | | | OK | | | | | | | | |
| 6 2/3 | 3.8 | | | | | | | OK | | | OK | | | | | | | | |
| 8 | 4.5 | | | | | | | OK | | | OK | | | | | | | | |
| 10 2/3 | ↑ | | | | | | | OK | | | OK | | | | | | | | |
| 13 1/3 | | | | | | | | OK | | | OK | | | | | | | | |
| 6 | | | | | | | | OK | | | OK | | | | | | | | |
| 21 1/3 | | | | | | | | OK | | | OK | | | | | | | | |
| 26 2/3 | | | | | | | | OK | | | OK | | | | | | | | |
| 32 | ↑ | | | | | | | OK | | | OK | | | | | | | | |
| 33 | 4.5 | | | | | | | OK | | | OK | | | | | | | | |

PLATE

VALVE NO 2 TYPE: NP 8321A5E SOLENOID ATTITUDE: Z-AXIS

INLET PRESSURE 200 PART* AT D. WHEN SHAKK:



90 VDC

Y-AXIS

*PART MAY BE: LEVER, DIAPHR. & PISTON, PORTS 1 & 2 &

BACK OF F/22

0+



F/23

G-LEVELS REACHED FOR % BACK PRESS.

| FREQ | MIN PEAK RIM PSI D.A. | Y-AXIS % | | | | | | Z-AXIS | | | | | | X-AXIS | | | | | |
|--------|-----------------------|----------|--------|-----|----------|--------|-----|----------|--------|-----|----------|--------|-----|----------|--------|-----|----------|-----|-----|
| | | INCREASE | | | DECREASE | | | INCREASE | | | DECREASE | | | INCREASE | | | DECREASE | | |
| | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | DE-EN | ENERG. | | | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 0 | 0.5 | 1.0 | 10 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 10 | 9.5 | 9.0 | 0 | 0.5 | 1.0 | 10 | 9.5 | 9.0 |
| 1 | 30 | OK | | | OK | | |
| 1 1/3 | .56 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 1 2/3 | .85 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 | 1.2 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 2 2/3 | 1.5 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 3 1/3 | 1.8 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 4 | 2.3 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 5 1/3 | 2.9 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 6 2/3 | 3.8 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 8 | 4.5 | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 10 2/3 | A | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 13 1/3 | | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 16 | | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 21 1/3 | | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 26 2/3 | | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 32 | | | | | | | | OK | | | OK | | | OK | | | OK | | |
| 33 | 4.5 | | | | | | | OK | | | OK | | | OK | | | OK | | |

1 PLATE USED AT THIS POINT

VALVE NO 8 TYPE:

INLET PRESSURE 10

GLENOID ATTITUDE: Z-AXIS

PART * AT D. WHEN SHAKG. Y-AXIS

*PART MAY BE: LEVER, DIAPHR. &, PISTON, PORTS 1 & 2 &

F/24

NP8321A5E

10-200 PSIG

DC Solenoid

pressure at port P

Solenoid energized - check for pressure decrease
at port A

Solenoid de-energized - check for pressure
increase at port A



Check for proper shifting at each
cycle.

F/25 G-LEVELS REACHED FOR % BACK

| MIN | PEAK | RIM | Y-AXIS % | | Z-AXIS | | X-AXIS | |
|------|------|------|----------|----------|--------|--------|--------|--------|
| | | | INCREASE | DECREASE | DE-EN | ENERG. | DE-EN | ENERG. |
| 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1.3 | 1.3 | 1.3 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1.5 | 1.5 | 1.5 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1.8 | 1.8 | 1.8 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2.3 | 2.3 | 2.3 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2.9 | 2.9 | 2.9 | 0 | 0 | 0 | 0 | 0 | 0 |
| 3.8 | 3.8 | 3.8 | 0 | 0 | 0 | 0 | 0 | 0 |
| 4.5 | 4.5 | 4.5 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5.1 | 5.1 | 5.1 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6 | 6 | 6 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10.2 | 10.2 | 10.2 | 0 | 0 | 0 | 0 | 0 | 0 |
| 13 | 13 | 13 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15 | 15 | 15 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18 | 18 | 18 | 0 | 0 | 0 | 0 | 0 | 0 |
| 21.5 | 21.5 | 21.5 | 0 | 0 | 0 | 0 | 0 | 0 |
| 26.5 | 26.5 | 26.5 | 0 | 0 | 0 | 0 | 0 | 0 |
| 32 | 32 | 32 | 0 | 0 | 0 | 0 | 0 | 0 |
| 33 | 33 | 33 | 0 | 0 | 0 | 0 | 0 | 0 |

VALVE NO 9 TYPE: UP 8323A39E GORENOLD ATTITUDE: Z-AXIS
 INLET PRESSURE 0-40
 102 AC/90 DC
 *PART MAY BE: LEVER, DIAPHR. E, PISTON, COILS 1 1/2 E
 PART *AT D. SHAK. WHEN: Y-AXIS

BACK OF F/25



F/27

NP 8323A39E

0-40 PSIG

Sol A AC
Sol B DC

pressure at port 2

Test as follows:

Sol. A energized - check for pressure decrease at port 1

Sol. B energized - check for pressure decrease at port 1

Both Sol. A & B energized - check for pressure decrease at port 1

Both Sol A + B de-energized - check for pressure increase at port 1

check for proper shifting at each cycle

APPENDIX G
'ASCO' SEISMIC TESTS SUMMARY
AND OPERATIONAL DATA

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

- 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 986-1160
- Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

Summary of SEISMIC TESTS conducted at Automatic Switch Co.

The nine valves were seismic fragility tested per Para 9.4.2 .4.2.3 of ASCO Qualification Specification AQS-21678 Revision B (Appendix A). They were individually mounted with solenoids in vertical upright position and rigidly fastened to the seismic shaker for sinusoidal vibration in horizontal and vertical axes.

The valves were connected electrically, inlet to instrument grade air supply, and cylinder port to small reservoir. They were tested with single frequency sinusoidal motion at one-third octave intervals from 1 to 33 Hz to minimum limit shown of Fig. 9.1 of ASCO Qualification Specification AQS-21678 Revision B to a maximum of 10g or onset of malfunction, which is defined as a change of 10% of inlet pressure from the nominal pressure at the cylinder port.

Acceleration forces (g-levels) were limited by the machine capability of 6" maximum displacement, 40"/sec. maximum velocity and an arbitrarily selected 10g maximum acceleration. See Figure attached.

All the valves (except valve No. 7) passed the functional requirements. Following is the summary of the g-levels reached in energized and de-energized states and pressures:

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
Columbus, Mississippi • Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

| Valve No. | Pressure | g-level | |
|-----------|----------|-----------|--------------|
| | | Energized | De-energized |
| 1 | 7" water | 10 | 7.0 |
| | 125 psi | 10 | 5.5 |
| 2 | 10 psi | 10 | 8.5 |
| | 125 psi | 10 | 10 |
| 3 | 10 psi | 9.7 | 10 |
| | 125 psi | 10 | 10 |
| 4 | 7" water | 10 | 4.7 |
| | 150 psi | 10 | 6.5 |
| 5 | 7" water | 10 | 10 |
| | 150 psi | 10 | 10 |
| 6 | 10 psi | 10 | 10 |
| | 175 psi | 10 | 10 |
| 7 | 7" water | 10 | 1.4 |
| | 200 psi | 10 | 3.0 |
| 8 | 10 psi | 10 | 10 |
| | 200 psi | 10 | 10 |
| 9 | 7" water | 10 | 9.0 |
| | 40 psi | 10 | 8.8 |

Isomedix, Inc. • 25 Eastmans Road, Parsippany, New Jersey 07054 (201) 887-4700

Chicago, Illinois
Columbus, Mississippi

• 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160
• Post Office Box 2044, Industrial Park South, Columbus, Mississippi 39701 (601) 327-8015

6B

LG-3303

ACCELERATION, g PEAK

DOUBLE AMPLITUDE - INCHES

6" 4" 2" 1"

VELOCITY IN./SEC.

40 30 20

15# TEST LOAD

20 LB.

10

50 LBS.

FREQUENCY, Hz

ASCO SEISMIC SHAKER

MINIMUM PERFORMANCE

6" STROKE (D.A.)

20g @ 15# TEST LOAD

50# TEST LOAD MAX.

40"/sec. PEAK VELOCITY

DRAWN WERNER

DATE 10-20-77

APPROVED

LG-3303

3 OCTAVE INTERVALS

9/4

| H ₂ | G | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|----------------|------|--------------|-----|------|-----------|------|------|--------------|-----|------|-----------|------|------|--------------|-----|------|-----------|------|------|
| | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 0 | 6 | 12.5 | 12.5 | 11.9 | 11.2 | 0 | 6 | 12.5 | 12.5 | 11.9 | 11.2 | 0 | 6 | 11.7 | 11.5 | 11.7 | 11.2 |
| | | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | ✓ | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | 5.5 | 5.5 | 5.5 | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | 6.0 | 6.0 | 6.0 | | | | | | | | | | | | | | | |
| 16 | 10 | 5.5 | 5.5 | 5.5 | | | | | | | | | | | | | | | |
| 21-1/3 | | 5.5 | 5.5 | 5.5 | | | | | | | | | | | | | | | |
| 26-2/3 | | 5.5 | 5.5 | 5.5 | | | | | | | | | | | | | | | |
| 33 | | 5.5 | 6.3 | 6.7 | | | | | | | | | | | | | | | |
| 40 | | ✓ | 3.5 | 7.0 | 3.5 | ✓ | | ✓ | | | | | | | | | | | |

VALVE # 206-381-6F TYPE DC .154 Amps
 INLET PRESSURE (1X PSI)

IX # 1 LWO 2908
 DATE 10-24-77

9/5

| Hz | ΔP_{ave} P_{in} | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|--------|--|--------------|------|------|-----------|------|------|--------------|------|------|-----------|------|------|--------------|------|------|-----------|------|------|
| | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | "H ₂ O" | 0 | .35" | .70" | 7" | 6.7" | 6.3" | 0 | .35" | .70" | 7" | 6.9" | 6.3" | 0 | .35" | .70" | 7" | 6.9" | 6.3" |
| | | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | 9 | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | |
| 16 | 10 | 9.9 | 10 | OK | | | | | | | | | | | | | | | |
| 21-1/3 | | 7.0 | 10 | OK | | | | | | | | | | | | | | | |
| 26-2/3 | | 7.0 | 7.0 | 7.0 | | | | | | | | | | | | | | | |
| 33 | | OK | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | |

VALVE # 206-381-6 TYPE DC 154 Amps LW0 2907
 INLET PRESSURE 0-125 PSI (7" H₂O) IX# 1 DATE 10-24-77

9/6

7

| | | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|--|------|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| INCREASE IN CYLINDER INLET PRESSURE WITH RESPECT TO INLET PRESSURE | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | g | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | | | | | | ✓ | | | ✓ | | | ✓ | | | ✓ | | |

VALVE # 8344A71E INLET DC 1074 Amps INLET PRESSURE 125 psi IX#2 LWO 2823 DATE 10-19-77

9/7

(8)

| Hz | Y AXIS | | | | | | | | | Z AXIS | | | | | | | | | X AXIS | | | | | | | | |
|--------|--------------|-----|-----|-----------|------|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|-----|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | | |
| | 0 | .5 | 1 | 0 | 9.5 | 9 | 0 | .5 | 1 | 0 | 9.5 | 9 | 0 | .5 | 1 | 0 | 9.5 | 9 | 0 | .5 | 1 | 0 | 9.5 | 9 | 0 | .5 | 1 |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | ↓ | | | | | | | | | | | | | | | | | | | | | | | | | |
| 16 | 10 | 87 | 87 | 9 | | | | | | | | | | | | | | | | | | | | | | | |
| 21-1/3 | | 87 | 87 | 9 | | | | | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | 89 | 89 | 9 | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | 77 | 77 | 85 | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | | ↓ | 9 | 19 | 19.5 | ↓ | | | | | | | | | | | | | | | | | | | | | |

VALVE #8344A71E TESTED INLET PRESSURE

.074 Amps (10 PSI)

IX#2 LWD 2823

DATE 10-19-77

9/8

32740

| INCREASE IN CYLINDER PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| Hz | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | |
| 40 | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ |

VALVE #83/654V TYPE AC 102/60 INLET PRESSURE

(25 PSI)

IX#3

DATE 10-27-70

9/9

31843

| CHANGE IN CYL. OUT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | | | |
|--|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|-----|------------|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | |
| PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | | OK |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | | ↓ |
| 16 | 10 | | | | | | | | | | | | | | | | | | | 9.5 9.5 9. |
| 21-1/3 | | | | | | | | | | | | | | | | | | | | OK |
| 26-2/3 | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | |
| 40 | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ |

VALVE # 831654V TYPE AC 102/60
INLET PRESSURE (10psi.)

IX#3

DATE 10-27-77

G/10

30/0

| CHANGE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | | | |
|---|--------------|-----|------|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | |
| PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | 8 | | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | | OK | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | ✓ | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | 6.8 | 7.2 | 7.5 | | | | | | | | | | | | | | | | |
| 16 | 10 | 6.8 | 9.2 | 9.7 | | | | | | | | | | | | | | | | |
| 21-1/3 | | 7.1 | 9.5 | 10 | | | | | | | | | | | | | | | | |
| 26-2/3 | | 7.8 | 9.5 | 10 | | | | | | | | | | | | | | | | |
| 33 | | 5.5 | 6.5 | 6.5 | | | | | | | | | | | | | | | | |
| 40 | ✓ | 5.7 | 19.0 | 19.8 | | | | | | | | | | | | | | | ✓ | |

VALVE #206-380-3RF TYPE AC 1102/60 LWO 2907
 INLET PRESSURE 150psi IX# 4 DATE 10-19-77

9/11

29140

| CHANGE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|---|--------------|-----|------|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| H ₂ O | 0 | .35 | .70 | 7" | 6.7 | 6.3 | 0 | .35 | .70 | 7 | 6.7 | 6.3 | 0 | .35 | .70 | 7 | 6.7 | 6.3 |
| Hz | 8 | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | ↓ | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | 3.2 | 3.5 | OK | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | 3.0 | 3.3 | 5.0 | | | | | | | | | | | | | | |
| 8 | 5.2 | 3.5 | 4.5 | 4.8 | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | 4.0 | 4.7 | 5.3 | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | 4.2 | 5.5 | 5.9 | | | | | | | | | | | | | | |
| 16 | 10 | 4.3 | 4.5 | 5.3 | | | | | | | | | | | | | | |
| 21-1/3 | | 4.5 | 5.5 | 6.2 | | | | | | | | | | | | | | |
| 26-2/3 | | 3.0 | 3.7 | 4.7 | | | | | | | | | | | | | | |
| 33 | | 2.5 | 3.2 | 5.0 | | | | | | | | | | | | | | |
| 40 | ↓ | 4.7 | 17.2 | 10 | | | | | | | | | | | | | | |

VALVE #206-380-38F TYPE AL 102/60
 INLET PRESSURE 7" H₂O

IX#4 LWO 2909
 DATE 10-19-77

9/12

19725

| INLET PRESSURE WITH RESPECT TO INLET PRESSURE | Hz | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|--|------|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | | 3 | 11 | 110 | 142 | 135 | | 8 | 15 | 150 | 142 | 135 | | 8 | 15 | 150 | 142 | 135 | |
| | | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |

VALVE #8320A184E TYPE AC 102/60 (150 psi) IX# 5 DATE 10-27-77

Y AXIS

9/13

Z AXIS

X AXIS

18825

| FREQ IN CYCLES PER SECOND WITH RESPECT TO INLET PRESSURE | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
|--|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | |
| 40 | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ |

VALVE #830A184E TYPE AC INLET PRESSURE

102/60 7" H₂O

IX#5

DATE 10-27-77

G/14

334

| INCREASE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | |
| PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | 8 | | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | | OK | | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | | ✓ | | | ✓ | | | ✓ | | | ✓ | | | ✓ | | | ✓ | |

VALVE # 8316 GTE TYPE DC 1.074 A.M.P.S.
INLET PRESSURE 10 PSI

IX#6

DATE 10-27-77

Y AXIS

G/15

Z AXIS

X AXIS

38340

| INCREASE IN CYLINDER PORT PRESSURE WITH RESPECT TO INLET PRESSURE | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| 1 Hz | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | |
| 40 | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ |

VALVE #8316 65F TYPE DC INLET PRESSURE

1.074 Amps (175)

IX#6

DATE-10-27-77

9/16

34 J.C.E.

| RANGE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | |
|--|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | 8 | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | OK | | | OK | | | OK | | | OK | |
| 1-1/3 | .54 | OK | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | ✓ | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | 2.7 | 3.4 | 4.3 | | | | | | | | | | | | | | |
| 8 | 5.2 | 2.7 | 4.7 | 5.0 | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | 2.7 | 4.0 | 4.0 | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | 2.5 | 3.0 | 3.0 | | | | | | | | | | | | | | |
| 16 | 10 | 2.5 | 4.0 | 4.0 | | | | | | | | | | | | | | |
| 21-1/3 | | 1.5 | 2.5 | 3.5 | | | | | | | | | | | | | | |
| 26-2/3 | | 2.2 | 5.0 | 6.5 | | | | | | | | | | | | | | |
| 33 | | 4.5 | 10 | OK | | | | | | | | | | | | | | |
| 40 | ✓ | 9.5 | 10 | OK | | | | | | ✓ | | | ✓ | | | ✓ | | |

VALVE #202300-DRF TYPE DC
INLET PRESSURE 200 PSI

1.177 Ag's

LWO 2907

IX# 7

DATE 10-18-77

Y AXIS

9/17

Z AXIS

X AXIS

(33)

| INCREASE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | |
|---|--------------|-------|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--|
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | |
| 1/2" H ₂ O | 0 | .35 | .90 | 7 | 6.7 | 6.3 | 0 | .35 | .90 | 7 | 6.7 | 6.3 | 0 | .35 | .90 | 7 | 6.7 | 6.3 | |
| Hz | 8 | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | ✓ | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | 1.2 | 1.3 | 1.4 | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | 1.5 | 1.6 | 1.6 | | | | | | | | | | | | | | | |
| 4 | 2.6 | 1.5 | 1.6 | 1.6 | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | 1.6 | 1.8 | 1.8 | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | 1.7 | 1.8 | 1.9 | | | | | | | | | | | | | | | |
| 8 | 5.2 | 1.8 | 2.0 | 2.0 | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | 2.0 | 2.3 | 2.3 | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | 2.0 | 2.0 | 2.0 | | | | | | | | | | | | | | | |
| 16 | 10 | 2.0 | 2.0 | 2.0 | | | | | | | | | | | | | | | |
| 21-1/3 | | 2.0 | 2.3 | 2.4 | | | | | | | | | | | | | | | |
| 26-2/3 | | 2.7 | 3.9 | 4.0 | | | | | | | | | | | | | | | |
| 33 | | 3.2 | 3.7 | 3.7 | | | | | | | | | | | | | | | |
| 40 | | ✓ 3.7 | 9 | 9 ✓ | | | | | | | | | | | | | | | |

VALVE #202-300-2RF TYPE DC INLET PRESSURE 7" H₂O

.177H₂O

LW0 2907

IX #7

DATE 10-18-77

9/18

| CHANGE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | | | | Z AXIS | | | | | | | | | X AXIS | | | | | | | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--|--|--|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | | |
| | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | 0 | 10 | 20 | 200 | 190 | 180 | | | |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | | | |
| Hz | 8 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | | OK | | | | OK | | | | | | OK | | | | | | | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | | | |

VALVE #8321A1E
INLET PRESSURE

TYPE DC 1.074 Amps
200 PSI

IX#8

LWO 2703

DATE 10-25-77

Y AXIS

9/19

Z AXIS

X AXIS

12817

| CHANGE IN CYLINDER PORT PRESSURE WITH RESPECT TO INLET PRESSURE | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% |
| | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI |
| Hz | 8 | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | OK | | | OK | | | OK | | | OK | | | OK | | |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | | | | | | | | | | | | | | | | | |
| 16 | 10 | | | | | | | | | | | | | | | | | |
| 21-1/3 | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |

VALVE #832/A1E TYPE DC 1.074 Amps LW 0 2703
 INLET PRESSURE (10 PSI) IX#8 DATE 10-25-77

G/20

1982

| CHANGE IN CYL. PORT PRESSURE WITH RESPECT TO INLET PRESSURE | Y AXIS | | | | | | Z AXIS | | | | | | X AXIS | | | | | | | | |
|---|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|--------------|-----|-----|-----------|-----|-----|-----|-----|----|
| | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | DE-ENERGIZED | | | ENERGIZED | | | | | |
| | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | 0 | 5% | 10% | | | |
| PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | PSI | |
| Hz | 8 | | | | | | | | | | | | | | | | | | | | |
| 1 | .31 | OK | | | OK | | | | OK | | | | | | OK | | | | | | OK |
| 1-1/3 | .54 | | | | | | | | | | | | | | | | | | | | |
| 1-2/3 | .85 | | | | | | | | | | | | | | | | | | | | |
| 2 | 1.23 | | | | | | | | | | | | | | | | | | | | |
| 2-2/3 | 1.7 | | | | | | | | | | | | | | | | | | | | |
| 3-1/3 | 2.2 | | | | | | | | | | | | | | | | | | | | |
| 4 | 2.6 | | | | | | | | | | | | | | | | | | | | |
| 5-1/3 | 3.5 | | | | | | | | | | | | | | | | | | | | |
| 6-2/3 | 4.3 | | | | | | | | | | | | | | | | | | | | |
| 8 | 5.2 | | | | | | | | | | | | | | | | | | | | |
| 10-2/3 | 6.9 | | | | | | | | | | | | | | | | | | | | |
| 13-1/3 | 8.7 | ✓ | | | | | | | | | | | | | | | | | | | |
| 16 | 10 | 7.5 | 7.5 | 8.8 | | | | | | | | | | | | | | | | | |
| 21-1/3 | | OK | | | | | | | | | | | | | | | | | | | |
| 26-2/3 | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | |
| 40 | | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |


VALVE #823 A39E TYPE AC/DC
INLET PRESSURE

10x6 / 1074 Amps
40PSI IX#9

DATE 10-27-77
W.02834

LW02907 202-300-2RF


9/22




IX#7 ← — ~~IX~~ 10-18-77

LW02907 206-381-6F


LW02907 206-381-6F 62F



IX#1 ← — ~~IX~~ 10-18-77 IX#1 ← — ~~IX~~ 10-24-77




LW02907 206-380-3RF



IX#4 ← — ~~IX~~ 10-19-77

9/23

NO 234A71E




IX#2




10-19.1

LWO 2703 8321 A1 E


G/24



IX#8 ← → Z 10-20-77
 LWO 2703 8321 A1 E




IX#8 ← → Z 10-25-77
 LWO 2703 8321 A1 E



IX#8 ← → X 10-25-77

LWO 2687

8320A184E




IX#5

← — — → 10-20-77

LWO 2687

8320A184E




IX#5

← — — → 10-20-77


LWO 2776

8316 65E


G/26



IX#6 ← X 10-18-77
 LWO 2776 8316 65E



IX#6 ← Z
 LWO 2776 8316 54V



IX#3 ← X 10-18-77