

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	S	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE							14	LICENSE NUMBER										25	LICENSE TYPE					30	CAT					58

CON'T

REPORT SOURCE: 01 L 6 0 5 0 0 0 2 7 2 7 0 9 0 7 7 8 8 0 3 2 9 7 9 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operations, after performing a containment pressure relief, a design
0 3 | defect in the protection system was noted which could allow airborne activity to be
0 4 | released from containment to the outside atmosphere. Strict operator control was
0 5 | imposed until a design change could be implemented. This is the first occurrence of
0 6 | this type.
0 7 |
0 8 |

SYSTEM CODE [0] [9] 7 8		CAUSE CODE [S] [D] (11) 9 10		CAUSE SUBCODE [B] (12) 11		COMPONENT CODE [Z] [Z] [Z] [Z] [Z] [Z] (14) 12 13 17 18						COMP. SUBCODE [A] (13) 12		VALVE SUBCODE [Z] (16) 19 20			
(17) LER RO REPORT NUMBER [7] [8] 21 22		EVENT YEAR [7] [8] 21 22		SEQUENTIAL REPORT NO. [0] [6] [1] 24 25 26		OCCURRENCE CODE [0] [1] 28 29		REPORT TYPE [X] 30		REVISION NO. [2] 32							
ACTION TAKEN [F] (18) 33		FUTURE ACTION [Z] (19) 34		EFFECT ON PLANT [Z] (20) 35		SHUTDOWN METHOD [Z] (21) 36		HOURS (22) [0] [0] [0] [0] 37 38 39 40		ATTACHMENT SUBMITTED [Y] (23) 41		NPRD-4 FORM SUB. [N] (24) 42		PRIME COMP. SUPPLIER [N] (25) 43		COMPONENT MANUFACTURER [W] [1] [2] [0] (26) 44 45 46 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this occurrence was a design deficiency. A design change has been

1 1 | installed in the protection system which will prevent reoccurrence. A system

1 2 | analysis shows that similar problems do not exist in other SEC circuits.

1 3 |

1 4 |

FACILITY STATUS (1) 5 (E) (28) % POWER (0) 9 (9) (29) OTHER STATUS (30) N/A METHOD OF DISCOVERY (a) (31) DISCOVERY DESCRIPTION (32) Admin. Circuit Review

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 9 33 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35)
N/A

45 46 47 48 49 50

LOCATION OF RELEASE (36)
N/A

51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z	(38) N/A	(39)		

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	3	000	(40) N/A

1		9		Z		42		N/A	
1		9		Z		42		N/A	

7 8 9 10 30

PUBLICITY

ISSUED DESCRIPTION (45)

2 0 7 8 9 10 30

2 0 7 8 9 10 30

N/A 79040302 43

NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER A. W. Kapple

PHONE: (609) 365-7000 Salem Ext.