NRC FORM 366 (7-77) Update Report - Previous Report Date 10/3/78

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NJSGS1 (2) | 00-0000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (9–14) LICENSE NUMBER (15–25) LICENSE TYPE (26–30) CAT (57–58)

CON'T 01 | REPORT SOURCE L (6) | 05000272 (7) | 091078 (8) | 032979 (9)
DOCKET NUMBER (61–68) EVENT DATE (69–74) REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, S.W. flow alarm sounded in control for #13 CFCU. The
03 unit was declared inoperable due to low flow and Action Statement for T/S 3.6.2.3
04 was implemented. The unit was repaired in 17 hours 17 minutes and the Action
05 Statement was terminated. All other CFCU's were operational throughout this
06 occurrence. This is the fourth occurrence of this type (77-65, 78-50, 78-59).
07
08

09 SYSTEM CODE SB (11) | CAUSE CODE E (12) | CAUSE SUBCODE X (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 78 | — | SEQUENTIAL REPORT NO. 063 | / | OCCURRENCE CODE 03 | REPORT TYPE X | — | REVISION NO. 1

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W120 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The flow control transmitter failed to operate properly due to silt buildup in the
11 low pressure sensing line. The transmitter was cleaned and the sensing line was
12 blown out. Inspection Orders 400620, 621, 625, 626 and 627 call out CFCU sensing
13 line blow down every 14 days. No further corrective action is considered
14 necessary.

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY a (31) | DISCOVERY DESCRIPTION (32) Alarm

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Z (44) | DESCRIPTION (45) N/A

7904030312

NRC USE ONLY

NAME OF PREPARER A. W. Kapple PHONE: (609) 365-7000 Salem Ext. 628