



PSEG

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

November 8, 1979

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Olan D. Parr, Chief
Light Water Reactors Branch 3
Division of Project Management

Gentlemen:

CONTAINMENT PURGE AND PRESSURE-VACUUM RELIEF VALVES
NO. 2 UNIT
SALEM NUCLEAR GENERATING STATION
DOCKET NO. 50-311

Public Service Electric and Gas Company hereby submits the following information in response to your telephone request concerning the subject valves.

The design of the containment purge and pressure-vacuum relief valves considered the potential for debris that could become entrained in a post-accident environment lodging in the valves, thereby preventing the valves from performing their isolation function. In order to preclude this situation, the containment purge inlet valve and the pressure-vacuum relief valve, which are not connected directly to a filtered ventilation system inside the containment, are installed with the valve openings inside containment faced downward and protected by a 1-inch expanded metal mesh basket as illustrated in Attachment 1. It is our belief that this design provides assurance that debris will not become lodged in these valves and thereby prevent the valves from performing their isolation function.

The 10-inch pressure-vacuum relief valves were designed for a 5000 scfm flow rate with the valve in its full-open position (90 degrees). The maximum opening angle has been set at 60 degrees to ensure that the system design flow requirement of 2400 scfm as stated in the FSAR is met. Attachment 2 is an

BOO!
SE
1/1
ADD:
D SHUM
E Reeves

The Energy People

7911150 212

P

Mr. Olan D. Parr, Chief


-2-

11/8/79

operations analysis, consisting of calculations which verify that the critical valve parts will sustain DBA-LOCA loads without damage and that the valve will close when the fluid dynamic forces are introduced. In addition, failure mode calculations were performed for both the 10-inch pressure-vacuum relief and the 36-inch purge valves which are also provided in Attachment 2.

Should you have any questions, please do not hesitate to contact us.

Very truly yours,



R. L. Mittl
General Manager -
Licensing and Environment
Engineering and Construction

Attach.

FH2 1/2



PSEG

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

November 8, 1979

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Olan D. Parr, Chief
Light Water Reactors Branch 3
Division of Project Management

Gentlemen:

CONTAINMENT PURGE AND PRESSURE-VACUUM RELIEF VALVES
NO. 2 UNIT
SALEM NUCLEAR GENERATING STATION
DOCKET NO. 50-311

Public Service Electric and Gas Company hereby submits the following information in response to your telephone request concerning the subject valves.

The design of the containment purge and pressure-vacuum relief valves considered the potential for debris that could become entrained in a post-accident environment lodging in the valves, thereby preventing the valves from performing their isolation function. In order to preclude this situation, the containment purge inlet valve and the pressure-vacuum relief valve, which are not connected directly to a filtered ventilation system inside the containment, are installed with the valve openings inside containment faced downward and protected by a 1-inch expanded metal mesh basket as illustrated in Attachment 1. It is our belief that this design provides assurance that debris will not become lodged in these valves and thereby prevent the valves from performing their isolation function.

The 10-inch pressure-vacuum relief valves were designed for a 5000 scfm flow rate with the valve in its full-open position (90 degrees). The maximum opening angle has been set at 60 degrees to ensure that the system design flow requirement of 2400 scfm as stated in the FSAR is met. Attachment 2 is an

The Energy People

Mr. Olan D. Parr, Chief

-2-

11/8/79

operations analysis, consisting of calculations which verify that the critical valve parts will sustain DBA-LOCA loads without damage and that the valve will close when the fluid dynamic forces are introduced. In addition, failure mode calculations were performed for both the 10-inch pressure-vacuum relief and the 36-inch purge valves which are also provided in Attachment 2.

Should you have any questions, please do not hesitate to contact us.


Very truly yours,




R. L. Mittl
General Manager -
Licensing and Environment
Engineering and Construction

Attach.

FH2 1/2



PURGE SUPPLY



PRESSURE-VACUUM RELIEF

SALEM NUCLEAR GENERATING STATION
 NO. 2 UNIT-REACTOR CONTAINMENT
 MISCELLANEOUS PIPING AT PENETRATION SLEEVES
 ARRANGEMENT MECHANICAL

ATTACHMENT 2

MASONEILAN INTERNATIONAL, INC.

PUBLIC SERVICE ELECTRIC & GAS COMPANY

10" 32200 BUTTERFLY VALVES

BETTIS ACTUATOR MDL. 522C-SR-100

OPERATION ANALYSIS

The Bettis Robotarm is a spring opposed, pneumatic cylinder operator. During actuator loading, two 5" I.D. cylinders are pressurized to provide the necessary force to overcome the spring, valve friction, and dynamic loads. Although the spring force alone is sufficient to insure valve closure, an additional assist force is utilized to increase valve stroking speed. The assist force is caused by air loading one cylinder in the direction to close the valve. The assist force and loading force will not act at the same time.

Air for the assist force is obtained from the normal supply air. If the plant supply air fails, a backup accumulator tank will come on-line to air load the assist force.

A postulated LOCA would raise the containment pressure to 47 psig. Actuator loading will change. Calculations to determine the actuator forces during the various air loading configuration are shown on the attached sheets.

CUSTOMER/PROJECT P.S. E & G

MNI REF. NO.

 SUBJECT 10" 32200 BUTTERFLY VALVES
 OPERATION ANALYSIS

 DATE 9/25/79 BY MB
 CHECKED BY

ACTUATOR LOADING MOOES*

NORMAL SUPPLY PRESSURE = 80-100 PSIG

SPRING TORQUE

VALVE CLOSED = 3600 in-#

VALVE OPEN 60° = 9100 in-#

AIR ASSIST - ACTS WITH SPRING

80 PSI VALVE CLOSED = 3090 in-#

VALVE OPEN = 5340 in-#

100 PSI VALVE CLOSED = 3860 in-#

VALVE OPEN = 6675 in-#

LOADING FORCE - OPPOSES SPRING

80 PSI VALVE CLOSED = 6180 in-#

VALVE OPEN = 10680 in-#

100 PSI VALVE CLOSED = 7725 in-#

VALVE OPEN = 13350 in-#

NOTE: LOADING FORCE AND AIR ASSIST WILL NOT BE APPLIED TO THE ACTUATOR AT THE SAME TIME.

SUPPLY FAILURE - VALVE CLOSES WITH ACCUMULATOR

SPRING TORQUE - UNCHANGED

AIR ASSIST

(1) ACCUMULATOR PRESSURE = 80 PSIG MIN.

 (2) ACCUMULATOR VOLUME = 739 in³

 (3) ASSIST VOLUME CLOSED = 85 in³

 (4) ASSIST VOLUME OPEN = 28 in³

$$\text{ASSIST PRESSURE OPEN} = \frac{P_i V_i}{V_t}$$

$$= \frac{(80)(739)}{739 + 28} = 77 \text{ PSIG}$$

P_i: INITIAL ACCUMULATOR LOADING PRESSURE

V_i: ACCUMULATOR VOLUME

V_t: TOTAL VOLUME

CUSTOMER/PROJECT P. S. E. & G.

MNI REF. NO. _____

SUBJECT 10" 32200 BUTTERFLY VALVE
OPERATION ANALYSISDATE 9/25/79 BY MB
CHECKED BY

$$\text{ASSIST PRESSURE CLOSED} = \frac{80(739)}{739+85} = 71 \text{ PSI}$$

VALVE OPEN

$$\text{AIR ASSIST TORQUE} = 5190 \text{ in} \cdot \# @ 77 \text{ PSIG}$$

VALVE CLOSED

$$\text{AIR ASSIST TORQUE} = 2740 \text{ in} \cdot \#$$

LOCA

→ DURING A LOCA, LOADING PRESSURE IN THE ACTUATOR WILL NOT DROP TO 0 PSIG. THEREFORE, THE ACTUAL PRESSURE DIFFERENTIAL ACROSS THE PISTON FACE WILL DECREASE.

ASSUMING SPRING VOLUME IS OPEN TO CONTAINMENT, THE NEW FORCE BALANCE IS:

$$\text{ASSIST PRESSURE OPEN} = 77 - 47 = 30 \text{ PSI}$$

$$\text{ASSIST PRESSURE CLOSED} = 71 - 47 = 24 \text{ PSI}$$

VALVE OPEN

$$\text{AIR ASSIST TORQUE} = 2000 \text{ in} \cdot \#$$

VALVE CLOSED

$$\text{AIR ASSIST TORQUE} = 925 \text{ in} \cdot \#$$

SPRING AND ASSIST FORCE WILL STILL CLOSE VALVE. ESTIMATED VALVE STROKE TIME WILL INCREASE.

* NOTE: ACTUATOR LOADS SUPPLIED BY BETTIS CORPORATION, HOUSTON, TEXAS.

CUSTOMER/PROJECT

P. S. E. & G.

MNI REF. NO.

SUBJECT

10" 32200 BUTTERFLY VALVE

DATE

9/25/79

BY MB

CHECKED

BY

OPERATION ANALYSIS

VALVE OPERATION

NORMAL SERVICE - $\Delta P = 2" \text{ of } H_2O$; $\text{USE } 2 \text{ PSI}$ OPEN POSITION - 60°

$$T_{REQ'D} = T_{OFF-BALANCE} + T_{SPRING} = 1 \text{ PSI} \times 76.2 \frac{\text{in} \cdot \#}{\text{PSI}} + 9100 \text{ in} \cdot \#$$

$$T_{REQ'D} = 9176 \text{ in} \cdot \#$$

ACTUATOR LOADING TORQUE @ 80 PSI = 10680 in·#

WHEN CLOSED, THE PRESSURE ON THE UPPER AND LOWER PORTIONS OF THE VANE IS BALANCED, THEREFORE THE REQUIRED TORQUE IS THE SEATING LOAD OF THE VANE AGAINST THE LINER.

$$T_{SEATING} = 1390 \text{ in} \cdot \#$$

THIS TORQUE IS SUPPLIED BY THE SPRING INITIAL

$$\text{MIN. } T_{SPRING} = 3600 \text{ in} \cdot \#$$

LOCA - $\Delta P = 47 \text{ PSI}$

FLOW ACROSS THE VANE WILL TEND TO CLOSE THE VALVE AND ASSIST THE SPRING IN FAILING THE VALVE CLOSED.

CUSTOMER/PROJECT P.S.E. & G.

MNI REF. NO. _____

 SUBJECT ALLOWABLE VALVE STRESSES AND LOADS
FAILURE ANALYSIS

 DATE 9/23/79 BY MB
 CHECKED _____ BY _____

VALVE LOADS

(1) OPEN POSITION - 60°

LOADS CAUSED BY DYNAMIC TORQUE ON VANE FROM THE PRESSURE DROP ACROSS THE VALVE:

$$\Delta P = P_1 - P_2$$

$P_1 = 47 \text{ PSIG} - \text{CONTAINMENT PRESSURE DURING LOCA}$
 $P_2 = \text{ATM} = 0 \text{ PSIG}$

$$\Delta P = 47 \text{ PSI}$$

$$T_c = 76.2 \frac{\text{in} \cdot \#}{\text{PSI}} \times 47 = 3581 \text{ in} \cdot \#$$

T_c : dynamic torque

(2) CLOSE POSITION

TWO LOADING MODES

(a) ACTUATOR TORQUE*
(TORQUE ON SHAFT AND SHEAR PINS)

$$T_A = T_S + T_B$$

T_A : TOTAL ACTUATOR TORQUE

T_S : SPRING TORQUE

T_B : ACTUATOR ASSIST. TORQUE

$$T_A = 3600 \text{ in} \cdot \# + 3860 \text{ in} \cdot \#$$

$$T_A = 7460 \text{ in} \cdot \#$$

* SUPPLIED BY BETTIS CORPORATION
HOUSTON, TEXAS

(b) OFF-BALANCE PRESSURE
(SHEAR ON SHAFT & BEARING LOAD)

$$F = \Delta P (A)$$

$$A: \text{VANE AREA} = \frac{\pi}{4} d^2$$

$$d: \text{Vane diameter} = 10.1''$$

$$F = \Delta P \left(\frac{\pi}{4} d^2 \right) = 47 \left(\frac{\pi}{4} \right) 10.1^2 = 3765 \text{ lbs}$$

CUSTOMER/PROJECT P.S.E. & G.

MNI REF. NO. _____

 SUBJECT 10" 32200 BUTTERFLY VALVES
FAILURE ANALYSIS

 DATE 9/25/79 BY MB

CHECKED _____ BY _____

FAILURE MODES

A. OPEN POSITION - 60°

(1) SHEAR PINS 2 - #5 17-4 MATERIAL

$$T_{ALLOW.} = \left(\frac{d}{1.13}\right)^2 \times D \times S \times N$$

$T_{ALLOW.} = \left(\frac{.266}{1.13}\right)^2 \times 1 \times \frac{2}{3} \times 125000 \times 2$

$$T_{ALLOW.} = 9235 \text{ in} - \#$$

$T_{ALLOW.}$ allowable torque
 d : pin diameter = .266"
 S : shear stress (2/3 of tensile) = 2/3 x 125000 PSI
 D : shaft diameter = 1"
 N : number of pins = 2

(2) SHAFT 1" dia. 17-4 shaft

$$T_{ALLOW.} = \frac{D^3 S}{5.1} = \frac{1^3 (2/3 \times 125000)}{5.1}$$

$$T_{ALLOW.} = 16340 \text{ in} - \#$$

CRITICAL ELEMENT IN OPEN POSITION IS THE SHEAR PINS.

MIN. $T_{ALLOW.} = 9235 \text{ in} - \#$

MAX. VALUE LOAD IN OPEN POSITION $T_c = 3581 \text{ in} - \#$

$$MS = \frac{9235}{3581} - 1 = 1.58$$

B. CLOSE POSITION

(1) SHAFT - TEAR OUT BY UPSTREAM PRESSURE

$$F_{ALLOW.} = S A_s \times 2$$

$F_{ALLOW.}$ allowable shear on shaft
 A_s : shaft cross sectional area

$$F_{ALLOW.} = \frac{2}{3} (125000) \times \frac{\pi}{4} (1)^2 \times 2 = 130900 \text{ lbs}$$

CUSTOMER/PROJECT P.S.E. #G. MNI REF. NO. _____
 SUBJECT 18" 32200 BUTTERFLY VALVES DATE 9/25/79 BY MB
FAILURE ANALYSIS CHECKED _____ BY _____

$$F_{ACTUAL} = 3765 \text{ lbs @ } 47 \text{ PSI}$$

$$MS = \frac{130900}{3765} - 1 = \text{large}$$


(2) BEARING LOAD - @ $\Delta P = 47 \text{ PSI}$

$$\sigma_{Y_{ACT.}} = \frac{F_{ACTUAL}}{A_{BEAR}}$$

$\sigma_{Y_{ACT.}}$: ACTUAL YIELD STRESS
 F_{ACTUAL} : FORCE ON BEARING
 A_{BEAR} : BEARING AREA

$$\sigma_{Y_{ACT.}} = \frac{3765}{1.662 \times 2} = 1134 \text{ PSI}$$

$$MS = \frac{65006}{3765} - 1 = \text{large}$$



440C MATL.
 $\sigma_{Y_{ALLOW}} = 65000 \text{ PSI}$
 3.002 D12
 1.001 D12
 1.002 D12
 63/32

(3) SHAFT TORQUE

NON CRITICAL - USE SHEAR PINS

(4) SHEAR PINS

$$T_{ALLOW.} = 9235 \text{ in-#}$$

$$T_{ACTUAL} = 7460 \text{ in-#}; \text{ TOTAL ACTUATOR LOAD ON SEAT}$$

$$MS = \frac{9235}{7460} - 1 = .24$$

CUSTOMER/PROJECT

P. S. E. & G.

MNI REF. NO.

 DATE 9/28/79 BY MB

SUBJECT

36" 32200 BUTTERFLY VALVE

CHECKED

BY

FAILURE MODES

CLOSE POSITION ONLY

(1) SHAFT - TEAR OUT BY UPSTREAM PRESSURE
2" DIA. 17-4 MATL.

$$F_{ALLOW} = S A_s \times 2$$

F_{ALLOW} : ALLOWABLE SHEAR LOAD ON SHAFT
 S : SHEAR STRESS ($\frac{2}{3}$ OF TENSILE)

$$F_{ALLOW} = (\frac{2}{3} \times 125000) \times 3.14 \times 2$$

A_s : SHAFT CROSS-SECTIONAL AREA

$$= \frac{\pi}{4} (2)^2 = 3.14 \text{ in}^2$$

$$F_{ALLOW} = 523000 \text{ lbs}$$

F_{ACTUAL} : ACTUAL FORCE ON VANE

$$F_{ACTUAL} = \Delta P (A_v)$$

A_v : VANE AREA (O.D. = 34.5")

$$F_{ACTUAL} = 47 \times 935 = 44000 \text{ lbs}$$

$$= \frac{\pi}{4} (34.5)^2 = 935 \text{ in}^2$$

ΔP : PRESSURE DIFFERENTIAL = 47 PSI

$$MS = \frac{523000}{44000} - 1 = \text{large}$$

(2) BEARING LOAD 440C MATL.

$$\sigma_{ACTUAL} = \frac{F_{ACTUAL}}{A_{BEAR} \times 2}$$

σ_{ACTUAL} : ACTUAL YIELD STRESS

A_{BEAR} : BEARING AREA (LENGTH X I.D.)

$$= 3.35 \times 2 = 6.7 \text{ in}^2$$

$$\sigma_{ACTUAL} = \frac{44000}{6.7} = 3283 \text{ PSI}$$

σ_{ALLOW} : ALLOWABLE YIELD STRESS

$$= 65000 \text{ PSI}$$

$$MS = \frac{\sigma_{ALLOW}}{\sigma_{ACTUAL}} - 1 = \frac{65000}{3283} - 1 = \text{large}$$

(3) SHAFT TORQUE

$$T_{ALLOW} = \frac{D^3 S}{5.1}$$

T_{ALLOW} : ALLOWABLE TORQUE

D : SHAFT DIAMETER = 2"

$$T_{ALLOW} = \frac{2^3 (\frac{2}{3} \times 125000)}{5.1}$$

$$T_{ALLOW} = 130700 \text{ in-lb}$$

CUSTOMER/PROJECT P.S.E. & G

MNI REF. NO. _____

SUBJECT 36" 32200 BUTTERFLY VALVE

DATE 9/25/79 BY MB

CHECKED _____ BY _____

$T_{ACTUAL} = 77850 \text{ in-}\# @ 100 \text{ PSIG ASSIST}$
 BETTIS ROBOTARM ACTUATOR
 MOL. 746A-2SR-41

$$MS = \frac{130700}{77850} - 1 = .68$$

(4) SHEAR PINS - 3 - #9 PINS; 17-4 MATERIAL

$$T_{ALLOW} = \left(\frac{d}{1.13} \right)^2 \times D \times S \times N$$

T_{ALLOW} : allowable torque
 d : pin diameter = .539"
 S : SHEAR STRESS (2/3 OF TENSILE)
 $= \frac{2}{3} \times 125000 \text{ PSI}$
 D : SHAFT DIAMETER = 2"
 N : NUMBER OF PINS = 3

$$T_{ALLOW} = \left(\frac{.539}{1.13} \right)^2 \times 2 \times \frac{2}{3} \times 125000 \times 3$$

$$T_{ALLOW} = 113760 \text{ in-}\#$$

$$MS = \frac{113760}{77850} - 1 = .46$$

CUSTOMER/PROJECT

MNI REF. NO.

SUBJECT

10" 32200 BUTTERFLY VALVES
FAILURE ANALYSIS - $\Delta P = 60 \text{ PSI}$

DATE

9/26/79 BY MYB

CHECKED

BY

VALVE LOADS

(1) OPEN POSITION - 60° LOAD CAUSED BY DYNAMIC TORQUE ON VANE FROM
PRESSURE DROP ACROSS THE VALVE.

$$\Delta P = 60 \text{ PSI}$$

 ΔP : PRESSURE DIFFERENTIAL

$$T_c = 76.2 \frac{\text{in} \cdot \#}{\text{PSI}} \cdot 60$$

 T_c : dynamic torque

$$T_c = 4572 \text{ in} \cdot \#$$

(2) CLOSE POSITION

TWO LOADING MODES

(a) ACTUATOR TORQUE *
(TORQUE ON SHAFT AND SHEAR PIN)

$$T_A = 7460 \text{ in} \cdot \#$$

 T_A : TOTAL ACTUATOR TORQUE

* SUPPLIED BY BETTIS CORPORATION, HOUSTON, TEXAS

(b) OFF-BALANCE PRESSURE
(SHEAR ON SHAFT & BEARING LOAD)

$$F = \Delta P (A_v)$$

F: ACTUAL TEAR OUT FORCE
 A_v : VANE AREA (O.D. = 10.1")
 $= \frac{\pi}{4} (10.1)^2 = 80.12 \text{ in}^2$

$$F = 60 (80.12) = 4810 \text{ lbs}$$

CUSTOMER/PROJECT P.S.E & C. MNI REF. NO. _____
DATE 9/26/79 BY MB
SUBJECT 10" 32200 BUTTERFLY VALVES CHECKED _____ BY _____

FAILURE MODES

A. OPEN POSITION - 60°

(1) SHEAR PINS 2 - #5 PINS 17-4 MATERIAL

$$T_{allow} = 9235 \text{ in-}\# \text{ - SEE PAGE 2.2}$$

(2) SHAFT

$$T_{allow} = 16340 \text{ in-}\# \text{ - SEE P. 2.2}$$

CRITICAL ELEMENT IN OPEN POSITION IS THE SHEAR PINS.

$$T_{allow} = 9235 \text{ in-}\#$$

MAXIMUM VALVE LOAD IN OPEN POSITION IS THE ACTUATOR TORQUE

$$T_{ACT} = T_L = T_S$$

T_{ACT} : ACTUAL TORQUE

$$T_{ACT} = 13350 - 9100 = 4250 \text{ in-}\#$$

T_L : LOADING TORQUE
= 13350 in-}\#; MAX.

T_S : SPRING TORQUE
= 9100 in-}\#

$$MS = \frac{T_{allow}}{T_{ACT}} - 1 = \frac{9235}{4250} - 1 = 1.17$$

B. CLOSE POSITION

(1) SHAFT - TEAR OUT BY UPSTREAM PRESSURE

$$F_{allow} = 130900 \text{ lbs}$$

$$F_{ACTUAL} = 4810 \text{ lbs} @ \Delta P = 60 \text{ PSI}$$

$$MS = \frac{130900}{4810} - 1 = \text{large}$$

CUSTOMER/PROJECT P. S. E. EG

MNI REF. NO. _____

SUBJECT 10" 32200 BUTTERFLY VALVES

DATE 9/26/79 BY MB

CHECKED _____ BY _____

(2) BEARING LOAD - @ $\Delta P = 60 \text{ PSI}$

$$S_{YACT} = \frac{F_{ACTUAL}}{A_{BEAR.}}$$

S_{YACT} : ACTUAL YIELD STRESS

F_{ACTUAL} : FORCE ON BEARING

$$S_{YACT} = \frac{4810}{1.6621 \times 2} = 1450 \text{ PSI}$$

$A_{BEAR.}$: BEARING AREA
= SEE page 2-3

S_{YALLOW} : ALLOWABLE YIELD STRESS
= 65000 PSI @ 440C

$$MS = \frac{65000}{4810} - 1 = \text{large}$$

(3) SHAFT TORQUE

NON CRITICAL; USE SHEAR PINS

(4) SHEAR PINS

$$T_{ALLOW} = 9235 \text{ in} \cdot \#$$

T_s : SPRING TORQUE ON SEAT
= 3600 in · #

$$T_{ACTUAL} = T_s + T_A$$

T_A : ASSIST. TORQUE ON SEAT
= 3860 in · # @ 100 PSI

$$T_{ACTUAL} = 7460 \text{ in} \cdot \#$$

$$MS = \frac{9235}{7460} - 1 = .24$$

CUSTOMER/PROJECT

MNI REF. NO.

SUBJECT

36" 32200 BUTTERFLY VALVE
DP = 60 PSI

DATE 9/28/79 BY MJB

CHECKED BY

FAILURE MODES

(1) SHAFT - TEAR OUT BY UPSTREAM PRESSURE
2" OIA. 17-4 MATL.

$$F_{ALLOW} = 523000 \text{ lbs} - \text{SEE PAGE 3.1}$$

$$F_{ACTUAL} = 60 \times 935 = 56100 \text{ lbs}$$

$$MS = \frac{523000}{56100} - 1 = \text{large}$$

(2) BEARING LOAD 440C MATL.

$$\sigma_{ACTUAL} = \frac{F_{ACTUAL}}{A_{BEAR} \times 2} - \text{SEE PAGE 3.1}$$

$$\sigma_{ACTUAL} = 4280 \text{ PSI}$$

$$MS = \frac{65000}{4280} - 1 = \text{large}$$

(3) SHAFT TORQUE

$$T_{ALLOW} = 130700 \text{ in} \cdot \text{lb} - \text{SEE PAGE 3.1}$$

$$T_{ACTUAL} = 77850 \text{ in} \cdot \text{lb} - \text{SEE PAGE 3.2}$$

$$MS = \frac{130700}{77850} - 1 = .68$$

(4) SHEAR PINS

UNCHANGED FROM $\Delta P = 47 \text{ PSI}$

SEE PAGE 3.2