

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and Gas Company

Docket No. 50-272

Based on the results of an NRC inspection conducted on July 1 - August 4, 1979, it appears that one of your activities was not conducted in full compliance with the conditions of your NRC Facility License No. DPR-70 as indicated below. This item is an Infraction.

- A. Title 10 CFR Part 20.203(b) states that each radiation area shall be conspicuously posted with a sign or signs bearing the radiation caution symbol and the words: CAUTION RADIATION AREA.

Contrary to the above, the following failures to post areas were identified:

- (1) On July 10, 1979, the passageway in front of the Spent Fuel Demineralizer, in which radiation levels exceeded 5 mr/hour by survey, was not posted as a radiation area.
- (2) On July 10, 1979, Auxiliary Building Elevation 64' near the west stairwell, an area in which radiation levels by survey exceeded 5 mr/hour, was not adequately posted as a radiation area.
- (3) On August 1, 1979, Auxiliary Building elevation 84' near the charging/safety injection pump suction from the RWST, in which radiation levels by survey exceeded 5 mr/hour, was not adequately posted as a radiation area.

7911210377