

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N J S G S I | 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | \_\_\_\_\_ | 5  
 7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
 0 1 | REPORT SOURCE | L | 6 | 0 5 | 0 0 0 2 7 2 | 7 | 0 7 1 0 7 9 | 8 | 1 1 | 1 0 7 9 | 9  
 7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the refueling outage, Westinghouse notified PSE&G that a potential safety  
 0 3 | problem exists with heatup of the S/G level measurement reference legs during  
 0 4 | accident conditions which would cause indicated level greater than actual level.  
 0 5 | This erroneous indication could result in delayed protection system actuation and  
 0 6 | could affect operator response for post accident recovery. This is the first  
 0 7 | occurrence of this type.  
 0 8 | \_\_\_\_\_

0 9 | SYSTEM CODE | I B | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | I N S T R U | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | Z | 16  
 7 8 9 10 11 12 13 18 19 20

17 | LER/RO REPORT NUMBER | 7 9 | EVENT YEAR | 7 9 | SEQUENTIAL REPORT NO. | 0 5 0 | OCCURRENCE CODE | 0 1 | REPORT TYPE | X | REVISION NO. | 1 |  
 7 8 21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | G | 18 | FUTURE ACTION | H | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 0 0 0 | 22 | ATTACHMENT SUBMITTED | Y | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | W 1 2 0 | 26  
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The apparent cause is design deficiency. The low-low S/G water level setpoint have  
 1 1 | been changed from 5% to 11%. Operators will be trained to the changed procedures  
 1 2 | and directed to utilize other indication to assist in verification of primary to  
 1 3 | secondary heat transfer.  
 1 4 | \_\_\_\_\_

1 5 | FACILITY STATUS | G | 28 | % POWER | 0 0 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | D | 31 | DISCOVERY DESCRIPTION | Westinghouse Notification | 32  
 7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36  
 7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES NUMBER | 0 0 0 | 37 | Z | 38 | DESCRIPTION | N/A | 39  
 7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES NUMBER | 0 0 0 | 40 | DESCRIPTION | N/A | 41  
 7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43  
 7 8 9 10 80

2 0 | PUBLICITY ISSUED DESCRIPTION | Z | 44 | DESCRIPTION | N/A | 45  
 7 8 9 10 80

7912040343