

Distribution w/encl:

Docket File	O. Parr
NRC PDR	A. Dromerick
Local PDR	M. Rushbrook
LWR #3 File	OELD
S. Varga	IE (3)
F. Williams	

Docket No. 50-311

BCC: NSIC
TIC
ACRS (16)

Mr. R. L. Mittl, General Manager
Licensing and Environment
Engineering and Construction Department
Public Service Electric and Gas Company
80 Park Place
Newark, New Jersey 07101

JAN 31 1980

Dear Mr. Mittl:

SUBJECT: SECONDARY WATER CHEMISTRY MONITORING PROGRAM -
SALEM NUCLEAR GENERATING STATION, UNIT 2

In a letter dated December, 1979 you provided information regarding the secondary water chemistry program for Salem Unit 2. We have reviewed the information and have determined that in addition to the program you propose we require that you monitor the steam condensate at the effluent of the condensate pump. The basis for this requirement is presented in our evaluation of your program which is attached as an enclosure.

Please inform us after receipt of this letter of your schedule of providing your intent with regard to our requirement stated above.

Sincerely,

Original Signed by
O. D. Parr
Olan D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management

Enclosure:
As Stated

cc w/enclosure:
See next page

*App
3
60*

OFFICE	LWR #3:LPM	LWR #3:BC				
SURNAME	<i>ADP</i> A. Dromerick/LM	<i>ODP</i> ODParr				
DATE	1/27/80	1/31/80				

8002190 155

Mr. R. L. Mittl, General Manager - 2 -

JAN 31 1980

cc: Richard Fryling, Jr., Esq.
Assistant General Counsel
Public Service Electric & Gas Company
80 Park Place
Newark, New Jersey 07100

Mark Wetterhahn, Esq.
Conner, Moore & Cober
1747 Pennsylvania Avenue, N.W.
Suite 1050
Washington, D.C. 20006

Mr. Leif J. Norrholm
U. S. Nuclear Regulatory Commission
Region I
Drawer I
Hancocks Bridge, New Jersey 08038