

CENTRAL FILES

50-272

Frederick W. Schneider
Vice President
Production

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 201/430-7373

June 4, 1980

Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

NRC IE BULLETIN NO. 79-01B
ENVIRONMENTAL QUALIFICATION OF
CLASS 1E EQUIPMENT
NO. 1 UNIT
SALEM GENERATING STATION

In response to your letter of January 14, 1980, transmitting NRC IE Bulletin 79-01B, which was received on January 17, 1980, the attached partial response is hereby submitted for your review. This submittal is being made pursuant to our letters of February 29, March 7, March 21, and April 14, 1980 and discussions with Mr. R. W. McGaughy and Mr. A. E. Finkel of your office.

Please note that the enclosed submittal does not complete the effort required for this Bulletin. Our work effort was discussed with Mr. A. Finkel of your office. Mr. Finkel indicated that PSE&G should determine the percentage complete and provide a schedule for when the remaining information would be submitted.

The master list information is approximately 95% complete in identifying components. The qualification data sheets are approximately 40% completed. It should be noted that many components in the master list will not have qualification data sheets since they are not located in areas subject to a high energy line breakthrough which the equipment must operate. Our immediate effort is in verifying which items need to operate in adverse environments. In order to complete the submittal requirements of this Bulletin fully, we expect that the final submittal will not be made until September 1980. Periodic submittals will be made when appropriate.

Q

8006300 233

D

Mr. Boyce H. Grier

-2-

6/4/80

We wish to add that a similar review of qualification data must be made on Unit 2, but against different guidelines of NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Equipment." In addition, a qualification review with respect to radiation is being done as part of TMI Lessons Learned requirements (NUREG-0578). Some information applicable to the Bulletin will come from these reviews.

If you require additional information on the enclosed submittal or on our revised schedule for completion, we will be please to discuss it with you.

Sincerely,



CC: Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C.

Mr. A. E. Finkel, Reactor Inspector
Office of Inspection and Enforcement
King of Prussia, Pa.

Mr. L. J. Norrholm
Hancocks Bridge, N.J.

STATE OF NEW JERSEY)


) SS: COUNTY OF ESSEX

)

FREDERICK W. SCHNEIDER, being duly sworn according to law
deposes and says:

I am a Vice President of Public Service Electric and
Gas Company, and as such, I signed the letter dated June 4,
1980, to Mr. Boyce H. Grier, Director, NRC Office of In-
spection and Enforcement, Region 1, in partial response to
NRC Bulletin No. 79-01B "Environmental Qualification of
Class IE Equipment."

The matters set forth in said response letter are true to
the best of my knowledge, information, and belief.


FREDERICK W. SCHNEIDER

Subscribed and sworn to before me

this 9 day of JUNE, 1980



Notary Public of New Jersey

My commission expires on Oct. 1, 1983

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-0518 Component: SOLENOID VALVE Manufacturer: ASCO Model: 206-381-3F Service: CONTROL FOR VALVE ISS110 Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: PANEL E1. CONTAINMENT 78 Flood Level E1: 83'-1" Above Flood Level: No	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1, 2	7, 8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.		
	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3, 4 (NOTE A)	7, 8	TEST (NOTE B)	NONE	
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7, 8		NONE	
	Relative Humidity	100%	100%	—	7		NONE	
	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR PH OF 5 TO 10	6	7			
	Radiation		2 x 10 ⁸ R		7			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	THERMAL - SIMULATED 4 YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10 ⁸ R	NONE	
	Submergence	NOT REQUIRED	N/A	9	N/A	N/A	NONE	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q 6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-0519	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1,2	7,8		
Component: SOLENOID VALVE	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3,4 (NOTE A)	7,8	NONE	
Manufacturer: ASCO	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7,8	NONE	
Model: 206-381-3F	Relative Humidity	100%	100%	—	7	NONE	
Service: CONTROL FOR VALVE ISS107	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR PH OF ± 10	6	7		
Accuracy: N/A Spec. Demon.	Radiation		2 x 10 ⁸ R		7		
Location: PANEL E1. CONTAINMENT 7B	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	NONE	
Flood Level E1: 83'-1" Above Flood Level: No	Submergence	NOT REQUIRED	N/A	9	N/A	N/A	NONE

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROBE (WYLE REPORT No. 44439-2 REVA)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-0520</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>206-381-3F</i> Service: <i>CONTROL FOR VALVE ISS104</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>PANEL E1. CONTAINMENT 78</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>No</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.</i>			
	Temperature	<i>LOCA/MSLB 271/296°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3,4 (NOTE A)</i>	<i>7,8</i>		<i>TEST (NOTE B)</i>	<i>NONE</i>	
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>			<i>NONE</i>	
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>-</i>	<i>7</i>			<i>NONE</i>	
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≤ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>				
	Aging	<i>-</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>-</i>	<i>7</i>		<i>THERMAL - SIMULATED 4YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10⁸R</i>	<i>NONE</i>	
	Submergence	<i>NOT REQUIRED</i>	<i>N/A</i>	<i>9</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	<i>-</i>

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV.A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-0521</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>206-381-3F</i> Service: <i>CONTROL FOR VALVE ISS103</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>PANEL E1. CONTAINMENT 78</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>No</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1, 2</i>	<i>7, 8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE B)</i>	<i>NONE</i>	 	
	Temperature	<i>LOCA/MSLB 271/296°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3, 4 (NOTE A)</i>	<i>7, 8</i>				
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7, 8</i>				
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>				
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF 5-10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>				
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>				<i>THERMAL - SIMULATED 4 YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10⁸R</i>
	Submergence	<i>NOT REQUIRED</i>	<i>N/A</i>	<i>9</i>	<i>N/A</i>				<i>N/A</i>

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SHORTER THAN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-802 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP8344A74E Service: <i>CONTROL FOR VALVE INOC2</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: E1. CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR. ≈</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.</i>		
	Temperature	<i>LOCA/MSLB 271/350°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>	<i>TEST (NOTE A)</i>	<i>NONE</i>	<i>—</i>
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>	<i>—</i>
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	<i>—</i>
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>			
	Radiation		<i>2 x 10⁸ R</i>		<i>7</i>			
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>	<i>THERMAL - SIMULATED 4 YRS. @ 140°F 40,000 CYCLES OF OPERATION AND RADIATION 5x10⁸R</i>	<i>NONE</i>	<i>—</i>
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>NONE</i>	<i>—</i>

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-1021</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 days in</i> <i>ADVERSE ENV.</i> \approx	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENV.</i>		
Component: <i>SOLENOID VALVE</i>	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND</i> <i>350°F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>	<i>TEST (NOTE A)</i>	<i>NONE</i>	
Manufacturer: <i>ASCO</i>	Pressure	<i>LOCA/MSLB</i> <i>49.2/42.8</i> <i>PSIG</i>	<i>110 PSIG AND</i> <i>54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>	
Model: <i>NP8344A76E</i>	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	
Service: <i>CONTROL FOR VALVE 1VC2</i>	Chemical Spray	<i>0.2 WT. %</i> <i>NaOH</i> <i>1.2 WT. %</i> <i>Boric Acid</i>	<i>3000 PPM</i> <i>BORON WITH</i> <i>NACH FOR PH OF</i> ≈ 10	<i>6</i>	<i>7</i>			
Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i>	Radiation		<i>$2 \times 10^8 R$</i>		<i>7</i>			
Accuracy: <i>N/A</i> Spec. Demon.	Aging	<i>—</i>	<i>4 YEAR</i> <i>QUALIFIED LIFE</i> <i>FOR ELASTOMERS</i> <i>AND COILS</i>	<i>—</i>	<i>7</i>	<i>THERMAL - SIMULATED 4 YRS. @ 140°F</i> <i>40,000 CYCLES OF OPERATION AND RADIATION $5 \times 10^8 R$</i>	<i>NONE</i>	
Location: <i>E1.</i> <i>CONTAINMENT</i>	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>NONE</i>	
Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>YES</i>								

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-0803 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP8344A74E Service: <i>CONTROL</i> FOR VALVE IN C3 Function: <i>CLOSES</i> VALVE UPON ISOLATION SIGNAL Accuracy: <i>N/A</i> Spec. Demon. Location: E1. <i>CONTAINMENT</i> Flood Level E1: 83'-1" Above Flood Level: YES	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENV. ≈	1,2	7,8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENV. TEST (NOTE A)			
	Temperature	LOCA/MSLB 271/350°F	346°F AND 350°F (FIGURE 1 #2)	3,4	7,8		NONE	—	
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 #2)	5	7,8		NONE	—	
	Relative Humidity	100%	100%	—	7		NONE	—	
	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR A1 OF ≈ 10	6	7				
	Radiation		2x10 ⁸ R		7		—		
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7		THERMAL - SIMULATED 4 YRS. @ 140°F 40,000 CYCLES OF OPERATION AND RADIATION 5x10 ⁸ R	NONE	—
	Submergence	N/A	N/A	N/A	N/A		N/A	NONE	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQ521678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-1022 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP834476E Service: <i>CONTROL</i> FOR VALVE 1VC3 Function: <i>CLOSES</i> VALVE UPON ISOLATION SIGNAL Accuracy: <i>N/A</i> Spec. Demon. Location: E1. CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 DAYS IN</i> <i>ADVERSE ENVR.</i> ≈	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL</i> <i>TEST WITH A</i> <i>SUPPLEMENTAL</i> <i>ADVERSE ENVR.</i>		
	Temperature	<i>LOCA/MSLB</i> 271/350°F	<i>346 °F AND</i> <i>350 °F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>	<i>TEST</i> <i>(NOTE A)</i>	<i>NONE</i>	—
	Pressure	<i>LOCA/MSLB</i> 43.2/42.8 PSIG	<i>110 PSIG AND</i> <i>54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>	—
	Relative Humidity	<i>100%</i>	<i>100%</i>	—	<i>7</i>		<i>NONE</i>	—
	Chemical Spray	<i>0.2 WT. %</i> <i>NA OH</i> <i>1.2 WT. %</i> <i>BORIC ACID</i>	<i>3000 PPM</i> <i>BORON WITH</i> <i>NAOH FOR PH OF</i> <i>≈ 10</i>	<i>6</i>	<i>7</i>			
	Radiation		<i>2 x 10⁸ R</i>		<i>7</i>			
	Aging	—	<i>4 YEAR</i> <i>QUALIFIED LIFE</i> <i>FOR ELASTOMERS</i> <i>AND COILS</i>	—	<i>7</i>	<i>THERMAL - SIMULATED</i> <i>4 YRS. @ 140 °F</i> <i>40,000 CYCLES OF</i> <i>OPERATION AND</i> <i>RADIATION 5x10⁸ R</i>	<i>NONE</i>	—
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>NONE</i>	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQ521678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-399</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>206-381-3F</i> Service: <i>CONTROL FOR VALVE 1WL12</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>PANEL E1. CONTAINMENT 78</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>NO</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE B)</i>			
	Temperature	<i>LOCA/MSLB 271/296°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3,4 (NOTE A)</i>	<i>7,8</i>		<i>NONE</i>		
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>		
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>		
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BOWIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≤ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>				
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>		<i>THERMAL - SIMULATED 4YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5x10⁸R</i>	<i>NONE</i>	
	Submergence	<i>NOT REQUIRED</i>	<i>N/A</i>	<i>9</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS		
	Parameter	Spec.	Qualif.	Spec.				Qualif.	
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-0397 Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: 206-381-3F Service: <i>CONTROL FOR VALVE 1W12</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>PANEL E1.</i> <i>CONTAINMENT 78</i> Flood Level E1: 83'-1" Above Flood Level: <i>No</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1, 2</i>	<i>7, 8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.</i>			
	Temperature	<i>LOCA/MSLB</i> 271/296°F	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3, 4 (NOTE A)</i>	<i>7, 8</i>	<i>TEST (NOTE B)</i>	<i>NONE</i>	<i>—</i>	
	Pressure	<i>LOCA/MSLB</i> 43.2/42.8 PSIG	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7, 8</i>		<i>NONE</i>	<i>—</i>	
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	<i>—</i>	
	Chemical Spray	<i>0.2 WT. % NaOH</i> <i>1.2 WT. % Boric Acid</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF 8 TO 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>				
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>	<i>THERMAL - SIMULATED 4 YRS @ 140°F</i> <i>40000 CYCLES OF OPERATION AND RADIATION 5 x 10⁸R</i>	<i>NONE</i>	<i>—</i>	
	Submergence	<i>NOT REQUIRED</i>	<i>N/A</i>	<i>9</i>	<i>N/A</i>	<i>N/A</i>	<i>NONE</i>	<i>—</i>	

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.2B

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS														
	Parameter	Spec.	Qualif.	Spec.				Qualif.													
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-394 Component: SOLENOID VALVE Manufacturer: ASCO Model: 206-381-3F Service: CONTROL FOR VALVE 1WL16 Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: PANEL E1. CONTAINMENT 78 Flood Level E1: 83'-1" Above Flood Level: NO	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1,2	7,8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE B)	NONE	—													
	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3,4 (NOTE A)	7,8				NONE	—											
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7,8						NONE	—									
	Relative Humidity	100%	100%	—	7								NONE	—							
	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR PH OF 5 TO 10	6	7										NONE	—					
	Radiation		2 x 10 ⁸ R		7												NONE	—			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7														THERMAL- SIMULATED 4YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5x10 ⁸ R	NONE	—
	Submergence	NOT REQUIRED	N/A	9	N/A																

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROBE (WYLE REPORT No. 44439-2 - REL.A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-401 Component: SOLENOID VALVE Manufacturer: ASCO Model: 206-381-3F Service: CONTROL FOR VALVE IWL96 Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: PANEL E1. CONTAINMENT 78 Flood Level E1: 83'-1" Above Flood Level: NO	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1, 2	7, 8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.		
	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3, 4 (NOTE A)	7, 8	TEST (NOTE B)	NONE	—
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7, 8		NONE	—
	Relative Humidity	100%	100%	—	7		NONE	—
	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR PH OF 8 TO 10	6	7			
	Radiation		2 x 10 ⁸ R		7			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	THERMAL- SIMULATED 4 YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10 ⁸ R	NONE	—
	Submergence	NOT REQUIRED	N/A	9	N/A	N/A	NONE	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRD MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLSB PROFILE (WYLE REPORT No. 44439-2 REV.A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.				Qualif.
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SU-0927</i>	Operating Time	<i>ISOLATION</i> ≤ 20 <i>SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR.</i> \approx	<i>1,2</i>	<i>7,8</i>	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE A)		
Component: <i>SOLENOID VALVE</i>	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND 350°F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>		<i>NONE</i>	—
Manufacturer: <i>ASCO</i>	Pressure	<i>LOCA/MSLB</i> <i>45.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>	—
Model: <i>NP8344A74E</i>	Relative Humidity	<i>100%</i>	<i>100%</i>	—	<i>7</i>		<i>NONE</i>	—
Service: <i>CONTROL FOR VALVE INVC</i>	Chemical Spray	<i>0.2 WT. % NaOH</i> <i>1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>			
Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i>	Radiation		<i>$2 \times 10^8 R$</i>		<i>7</i>		↓	
Accuracy: <i>N/A</i> Spec. Demon.	Aging	—	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	—	<i>7</i>		<i>NONE</i>	—
Location: <i>E1.</i> <i>CONTAINMENT</i>	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>		<i>NONE</i>	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQ521678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-1026 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP8344A76E Service: CONTROL FOR VALVE 1UC6 Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: E1. CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: YES	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR. ≈	1,2	7,8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE A)	NONE	—
	Temperature	LOCA/NSLB 271/350°F	346 °F AND 350 °F (FIGURE 1 & 2)	3,4	7,8		NONE	—
	Pressure	LOCA/NSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7,8		NONE	—
	Relative Humidity	100%	100%	—	7		NONE	—
	Chemical Spray	0.2 WT. % NA OH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NACH FOR PH OF ≈ 10	6	7			
	Radiation		2 × 10 ⁸ R		7			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	THERMAL - SIMULATED 4 YRS. @ 140 °F 40,000 CYCLES OF OPERATION AND RADIATION 5x10 ⁸	NONE	—
	Submergence	N/A	N/A	N/A	N/A	N/A	NONE	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQ521678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SU-0427 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP831654E Service: CONTROL FOR VALVE 15J123 Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: PANEL E1. CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: NO	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1,2	7,8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.		
	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3,4 (NOTE A)	7,8	TEST (NOTE B)	NONE	—
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7,8		NONE	—
	Relative Humidity	100%	100%	—	7		NONE	—
	Chemical Spray	0.2 WT. % NaOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NaOH FOR PH OF 8 TO 10	6	7			
	Radiation		2 x 10 ⁸ R		7			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	THERMAL- SIMULATED 4 YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10 ⁸ R	NONE	—
	Submergence	NOT REQUIRED	N/A	9	N/A	N/A	NONE	—

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROBE (WYLE REPORT No. 44439-2 REV.A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.			
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-0491</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>NP831654E</i> Service: <i>CONTROL FOR VALVE ICU3</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>PANEL E1. CONTAINMENT</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>NO</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.</i>	
	Temperature	<i>LOCA/MSLB 271/296°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3,4 (NOTE A)</i>	<i>7,8</i>	<i>TEST (NOTE B)</i>	<i>NONE</i>
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORDON WITH NaOH FOR PH OF 6 TO 10</i>	<i>6</i>	<i>7</i>		
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>	<i>—</i>	
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>	<i>THERMAL-SIMULATED 4YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5x10⁸R</i>	<i>NONE</i>
	Submergence	<i>NOT REQUIRED</i>			<i>9</i>		

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
<p>System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-492</i></p> <p>Component: <i>SOLENOID VALVE</i></p> <p>Manufacturer: <i>ASCO</i></p> <p>Model: <i>NP831654E</i></p> <p>Service: <i>CONTROL FOR VALVE ICV4</i></p> <p>Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i></p> <p>Accuracy: <i>N/A</i> Spec. Demon.</p> <p>Location: <i>PANEL E1. CONTAINMENT</i></p> <p>Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>NO</i></p>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVIR</i>	<i>1, 2</i>	<i>7, 8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.</i>		
	Temperature	<i>LOCA/MSLB 271/296°F</i>	<i>346°F AND 350°F (FIGURE 1 & 2)</i>	<i>3, 4 (NOTE A)</i>	<i>7, 8</i>	<i>TEST (NOTE B)</i>	<i>NONE</i>	
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 & 2)</i>	<i>5</i>	<i>7, 8</i>		<i>NONE</i>	
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	
	Chemical Spray	<i>0.2 WT. % NAOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NAOH FOR PH OF ≤ 10</i>	<i>6</i>	<i>7</i>			
	Radiation		<i>2 x 10⁸R</i>		<i>7</i>			
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>	<i>THERMAL- SIMULATED 4YAS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5x10⁸R</i>	<i>NONE</i>	
	Submergence	<i>NOT REQUIRED</i>			<i>9</i>			

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REV. A)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
 UNIT NO. 1
 DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-0493 Component: SOLENOID VALVE Manufacturer: ASCO Model: NP831654E Service: CONTROL FOR VALVE ICUS Function: CLOSES VALVE UPON ISOLATION SIGNAL Accuracy: N/A Spec. Demon. Location: PANEL E1. CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: No	Operating Time	ISOLATION ≤ 20 SECONDS	30 DAYS IN ADVERSE ENVIR	1,2	7,8	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR.		
	Temperature	LOCA/MSLB 271/296°F	346°F AND 350°F (FIGURE 1 & 2)	3,4 (NOTE A)	7,8	TEST (NOTE B)	NONE	—
	Pressure	LOCA/MSLB 43.2/42.8 PSIG	110 PSIG AND 54 PSIG (FIGURE 1 & 2)	5	7,8		NONE	—
	Relative Humidity	100%	100%	—	7		NONE	—
	Chemical Spray	0.2 WT. % NAOH 1.2 WT. % BORIC ACID	3000 PPM BORON WITH NAOH FOR PH OF ± 10	6	7			
	Radiation		2 x 10 ⁸ R		7			
	Aging	—	4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS	—	7	THERMAL - SIMULATED 4YRS @ 140°F 40000 CYCLES OF OPERATION AND RADIATION 5 x 10 ⁸ R	NONE	—
	Submergence	Not REQUIRED			9			

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-13,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR: PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS 21678/TR (3/79)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)
9. FSAR: RESPONSE TO Q6.28

Notes:

- A. DUE TO LOCATION WITHIN INSTRUMENT PANEL ENCLOSURE, PEAK AMBIENT TEMPERATURE SEEN BY DEVICE IS LESS THAN MSLB PROFILE (WYLE REPORT No. 44439-2 REVA)
- B. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS
	Parameter	Spec.	Qualif.	Spec.	Qualif.			
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SV-0506</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 DAYS IN ADVERSE ENVIR.</i> \approx	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE A)</i>		
Component: <i>SOLENOID VALVE</i>	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND 350°F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>		<i>NONE</i>	
Manufacturer: <i>ASCO</i>	Pressure	<i>LOCA/MSLB</i> <i>43.2/42.8</i> <i>PSIG</i>	<i>110 PSIG AND 54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>	<i>NONE</i>		
Model: <i>206-381-3F</i>	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	
Service: <i>CONTROL FOR VALVE IPR17</i>	Chemical Spray	<i>0.2 WT. % NaOH</i> <i>1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>			
Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i>	Radiation		<i>$2 \times 10^8 R$</i>		<i>7</i>			
Accuracy: <i>N/A</i> Spec. Demon.	Aging		<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>		<i>7</i>	<i>THERMAL - SIMULATED 4 YRS. @ 140°F</i> <i>40,000 CYCLES OF OPERATION AND RADIATION $5 \times 10^8 R$</i>	<i>NONE</i>	
Location: <i>E1.</i> <i>CONTAINMENT</i>	Submergence	<i>NOT REQUIRED</i>	<i>N/A</i>	<i>9</i>	<i>N/A</i>	<i>N/A</i>	<i>NONE</i>	
Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>No</i>								

References:

- TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,*
- FSAR: SECTION 5.4*
- FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82*
- NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE*
- FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82*
- FSAR; PAGE 6.4-10*
- AUTOMATIC SWITCH Co. TEST REPORT AQ521678/TR (3/78)*
- WYLE LABS TEST REPORT No. 44439-1 (3/23/79)*
- FSAR: RESPONSE TO Q6.28*

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.*

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SU-1077</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>206-381-6F</i> Service: <i>CONTROL FOR VALVE INCV7</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>E1.</i> <i>CONTAINMENT</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 DAYS IN ADVERSE ENV.</i> \approx	<i>1,2</i>	<i>7,8</i>	SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENV. TEST (NOTE A)			
	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND 350°F</i> (FIGURE 1 #2)	<i>3,4</i>	<i>7,8</i>		<i>NONE</i>	<i>—</i>	
	Pressure	<i>LOCA/MSLB</i> <i>43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG</i> (FIGURE 1 #2)	<i>5</i>	<i>7,8</i>		<i>NONE</i>	<i>—</i>	
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>	<i>—</i>	
	Chemical Spray	<i>0.2 WT. % NaOH</i> <i>1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2x10⁸ R</i>		<i>7</i>		<i>—</i>		
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>		<i>THERMAL - SIMULATED 4YRS. @ 140°F</i> <i>40,000 CYCLES OF OPERATION AND RADIATION 5x10⁸</i>	<i>NONE</i>	<i>—</i>
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	<i>—</i>

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQ521678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: SU-1079 Component: SOLENOID VALVE Manufacturer: ASCO Model: 206-381-6F Service: <i>CONTROL FOR VALVE IVC9</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>E1.</i> CONTAINMENT Flood Level E1: 83'-1" Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION ≤ 20 SECONDS</i>	<i>30 DAYS IN ADVERSE ENVR. ≈</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVR. TEST (NOTE A)</i>			
	Temperature	<i>LOCA/MSLB 271/350°F</i>	<i>346°F AND 350°F (FIGURE 1 #2)</i>	<i>3,4</i>	<i>7,8</i>		<i>NONE</i>		
	Pressure	<i>LOCA/MSLB 43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG (FIGURE 1 #2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>		
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>		
	Chemical Spray	<i>0.2 WT. % NaOH 1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2x10⁸ R</i>		<i>7</i>		<i>—</i>		
	Aging	<i>—</i>	<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>		<i>THERMAL - SIMULATED 4 YRS. @ 140°F 40,000 CYCLES OF OPERATION AND RADIATION 5x10⁸ R</i>	<i>NONE</i>	
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH Co. TEST REA. AQS21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: SV-1081 Component: SOLENOID VALVE Manufacturer: ASCO Model: 206-381-6F Service: <i>CONTROL FOR VALVE INCH</i> Function: <i>CLOSES VALVE UPON ISOLATION SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>E1.</i> <i>CONTAINMENT</i> Flood Level E1: 83'-1" Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION</i> ≤ 20 SECONDS	<i>30 DAYS IN ADVERSE ENVIR.</i> \approx	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL TEST WITH A SUPPLEMENTAL ADVERSE ENVIR. TEST (NOTE A)</i>			
	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND 350°F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>			<i>NONE</i>	
	Pressure	<i>LOCA/MSLB</i> <i>43.2/42.8 PSIG</i>	<i>110 PSIG AND 54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>			<i>NONE</i>	
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>			<i>NONE</i>	
	Chemical Spray	<i>0.2 WT. % NaOH</i> <i>1.2 WT. % BORIC ACID</i>	<i>3000 PPM BORON WITH NaOH FOR PH OF ≈ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>$2 \times 10^8 R$</i>		<i>7</i>				
	Aging		<i>4 YEAR QUALIFIED LIFE FOR ELASTOMERS AND COILS</i>	<i>—</i>	<i>7</i>		<i>THERMAL - SIMULATED 4 YRS. @ 140°F</i> <i>40,000 CYCLES OF OPERATION AND RADIATION 5X10⁸R</i>	<i>NONE</i>	
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	

References:

- 1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,*
- 2. FSAR: SECTION 5.4*
- 3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82*
- 4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE*
- 5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82*
- 6. FSAR; PAGE 6.4-10*
- 7. AUTOMATIC SWITCH CO. TEST REPORT AQ521678/TR (3/78)*
- 8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)*

Notes:

A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.

SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

SYSTEM COMPONENT EVALUATION SHEET

TABLE II

Page _____

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIFICATION METHOD	OUTSTANDING ITEMS	REMARKS	
	Parameter	Spec.	Qualif.	Spec.	Qualif.				
System: <i>CONTAINMENT ISOLATION</i> Identification: <i>SU-1083</i> Component: <i>SOLENOID VALVE</i> Manufacturer: <i>ASCO</i> Model: <i>206-381-6F</i> Service: <i>CONTROL</i> <i>FOR VALVE IN C13</i> Function: <i>CLOSES</i> <i>VALVE UPON ISOLATION</i> <i>SIGNAL</i> Accuracy: <i>N/A</i> Spec. Demon. Location: <i>E1.</i> <i>CONTAINMENT</i> Flood Level E1: <i>83'-1"</i> Above Flood Level: <i>YES</i>	Operating Time	<i>ISOLATION</i> <i>≤ 20</i> <i>SECONDS</i>	<i>30 DAYS IN</i> <i>ADVERSE ENVR.</i> <i>≈</i>	<i>1,2</i>	<i>7,8</i>	<i>SEQUENTIAL</i> <i>TEST WITH A</i> <i>SUPPLEMENTAL</i> <i>ADVERSE ENVR.</i> <i>TEST</i> <i>(NOTE A)</i>			
	Temperature	<i>LOCA/MSLB</i> <i>271/350°F</i>	<i>346°F AND</i> <i>350°F</i> <i>(FIGURE 1 & 2)</i>	<i>3,4</i>	<i>7,8</i>		<i>NONE</i>		
	Pressure	<i>LOCA/MSLB</i> <i>45.2/42.8</i> <i>PSIG</i>	<i>110 PSIG AND</i> <i>54 PSIG</i> <i>(FIGURE 1 & 2)</i>	<i>5</i>	<i>7,8</i>		<i>NONE</i>		
	Relative Humidity	<i>100%</i>	<i>100%</i>	<i>—</i>	<i>7</i>		<i>NONE</i>		
	Chemical Spray	<i>0.2 WT. %</i> <i>Na OH</i> <i>1.2 WT. %</i> <i>BORIC ACID</i>	<i>3000 PPM</i> <i>BORON WITH</i> <i>NACH FOR PH OF</i> <i>≈ 10</i>	<i>6</i>	<i>7</i>				
	Radiation		<i>2x10⁸ R</i>		<i>7</i>		<i>—</i>		
	Aging	<i>—</i>	<i>4 YEAR</i> <i>QUALIFIED LIFE</i> <i>FOR ELASTONERS</i> <i>AND COILS</i>	<i>—</i>	<i>7</i>		<i>THERMAL - SIMULATED</i> <i>4 YRS. @ 140°F</i> <i>40,000 CYCLES OF</i> <i>OPERATION AND</i> <i>RADIATION 5x10⁸</i>	<i>NONE</i>	
	Submergence	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>		<i>N/A</i>	<i>NONE</i>	

References:

1. TECH SPECS: PAGE 3/4 3-28 AND 3/4 6-12, 3/4 6-12,
2. FSAR: SECTION 5.4
3. FSAR: FIGURE 7.5-5 AND RESPONSE TO Q5.82
4. NRC MEMORANDUM 12/20/78, SALEM EQUIPMENT QUALIFICATION TEMPERATURE ENVELOPE
5. FSAR: FIGURE 14.3-25, PAGE 14.3-56 AND RESPONSE TO Q5.82
6. FSAR; PAGE 6.4-10
7. AUTOMATIC SWITCH CO. TEST REPORT AQS21678/TR (3/78)
8. WYLE LABS TEST REPORT No. 44439-1 (3/23/79)

Notes:

- A. SEQUENTIAL TEST INCLUDED RADIATION EXPOSURE, SEISMIC THEN SIMULATED ACCIDENT ENVIRONMENT. IN ADDITION THE SAME TEST SPECIMENS WENT THROUGH AN ADDITIONAL ACCIDENT TEST SEQUENCE.