NRC FORM 366 (7-77) UPDATE REPORT - LAST REPORT SUBMITTED 1/31/79

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NJSGS1 (2) | 00-0000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (7-14) LICENSE NUMBER (15-25) LICENSE TYPE (26-30) CAT (57-58)

CON'T 01 | REPORT SOURCE L (6) | 05002727 (7) | 010279 (8) | 062380 (9)
DOCKET NUMBER (60-68) EVENT DATE (69-74) REPORT DATE (75-80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During preparation of the annual non-radioactive environmental operating report, the
03 average annual (1978) suspended solids concentration in the discharge from the non-
04 radioactive waste basin was calculated to be 34.7 mg/l. This exceeds the
05 Environmental Technical Specification limit of 25 mg/l.
06
07
08

09 SYSTEM CODE WC (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 013 | / | OCCURRENCE CODE 04 | REPORT TYPE X | — | REVISION NO. 1

ACTION TAKEN F (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The high average suspended solids was the result of an abnormally high number of
11 demineralizer regenerations necessary to support the initial flushes required for
12 Unit 2. Since the 1979 Refueling Outage, a 3 foot weir wall across the NRW retention
13 basins and a well water clarifier were put in operation.
14

15 FACILITY STATUS Z (28) | % POWER 050 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Annual Report Preparation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Z (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER A. W. Kapple PHONE: 609-365-7000, Salem Ext. 628

8 0063 00424

GPO 917-926