· · · · · · · · · · · · · · · · · · ·		7 .	
U. S. NUCLEAR RE	GULATORY	сомм	15510
E ALL REQUIRED II	NEODMATIC		

	LICENSEE EVENT REPORT
·	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N J S G S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 HICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T	REPORT L 6 0 5 0 0 0 2 7 2 7 0 6 0 1 8 0 9 EVENT DATE 74 75 - REPORT DATE 80
0 2	During routine surveillance testing of Fire Detection Instruments, the fuseable
0 3	plug for the battery room detectors of both Unit 1 and Unit 2 were melted
0 4	rendering them inoperable. Action Statement 3.3.3.6 was entered at 0700 hours
0 5	(79-43).
0 6	L
0 7	
08	9
0 9 7 8	SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
	LER'RO REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT FORM SUB. PRIME COMP. COMPONENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER A 18 G 19 Z 20 Z 21 O O O O O U Y 23 Y 24 L 25 X 9 9 9 9 26 33 34 34 35 36 37 40 41 41 43 42 47
10	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) A hot air blower was used to raise the temperature of the detector to an alarm
11	condition, and the heat source was not removed quickly enough and the detector
1. 2	was damaged. The detectors were replaced and tested satisfactory, terminating the
1 3	Action Statement at 2100 hours on June 3, 1980. The procedure has been changed
14	requiring the use of other equipment for the test.
	STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 B 31 Routine Surveillance 9 10 12 13 44 45 46 80
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 Z 33 Z 34 N/A LOCATION OF RELEASE 36
1 7 7 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) O O O O (37) Z (38) N/A 9 REPSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) N/A
1 8	PERSONNEL INJURIES NUMBER DESCRIPTION 41 0 0 0 40 N/A
	9 11 12 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION N/A
2 0	9 PUBLICITY SSUED DESCRIPTION (45) 9 10 NRC USE ONLY N/A N/A NRC USE ONLY 80 N/A N/A
, 5	9 10 68 69 80 5 NAME OF PREPARER M. J. Murphy PHONE: 609-935-0998