

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 7 8 9 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T REPORT SOURCE 0 1 L 6 0 5 0 0 0 3 1 1 7 0 6 1 0 8 0 8 0 7 1 0 8 0 9
 7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During preparation for a routine surveillance, both Safety Injection Pumps were
 0 3 made operable when less than 312°F in the Reactor Coolant System.
 0 4
 0 5
 0 6
 0 7
 0 8

0 9 SYSTEM CODE S F (11) CAUSE CODE D (12) CAUSE SUBCODE Z (13) COMPONENT CODE Z Z Z Z Z Z Z (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)
 7 8 9 10 11 12 13 18 19 20
 (17) LER RO REPORT NUMBER 8 0 0 0 4 0 3 L 0
 21 22 23 24 26 27 28 29 30 31 32
 ACTION TAKEN G (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED Y (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER L (25) COMPONENT MANUFACTURER P 0 2 5 (26)
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The procedure did not state a precaution limiting the maximum number of Safety
 1 1 Injection Pumps allowed to be operable to one. A procedural change has been made
 1 2 stating the limit.
 1 3
 1 4

1 5 FACILITY STATUS B (28) % POWER 0 0 0 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY D (31) DISCOVERY DESCRIPTION Resident NRC Inspector (32)
 7 8 9 10 12 13 44 45 46 80
 1 6 ACTIVITY CONTENT Z (33) Z (34) NA (35) LOCATION OF RELEASE NA (36)
 7 8 9 10 11 44 45 80
 1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)
 7 8 9 11 12 13 80
 1 8 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)
 7 8 9 11 12 80
 1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)
 7 8 9 10 80

ISSUED PUBLICITY N (44) DESCRIPTION NA (45) 8 0 0 7 1 7 0 4 4 8
 7 8 9 10 68 69 80
 NRC USE ONLY