



PSEG

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

Ref. LCR 80-01

July 16, 1980

Director Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Gentlemen:

REQUEST FOR AMENDMENT
ADDITIONAL INFORMATION
FACILITY OPERATING LICENSES DPR-70
AND DPR-75
SALEM GENERATING STATION
UNIT NOS. 1 AND 2
DOCKET NOS. 50-272 AND 50-311

On March 17, 1980, we submitted a request to amend our Facility Operating License DPR-70 to permit a lowering of the individual cell minimum voltages on the 125 Volt and 28 Volt batteries to 2.13 Volts. Attached is a letter from CD, Batteries Divison, which gives the manufacturer's concurrence with this voltage. This information has been requested by Mr. William J. Ross, Project Manager - Salem 1, to support the amendment request.


Subsequent to our original March request, Salem Unit No. 2 has been issued Facility Operating License DPR-75. This Request for Amendment is applicable to Unit No. 2 in exactly the same manner as Unit No. 1. In accordance with the Atomic Energy Act of 1954, as amended and the regulations thereunder, we hereby request that this Request for Amendment be applied to Facility Operating License DPR-75 for Salem Generating Station, Unit No. 2. In accordance with 10CFR 170.22, a check for the amount of \$400 is enclosed.

Very truly yours,

Frank P. Librizzi
General Manager -
Electric Production

*B021
S
3/3
w/CHECK
\$400.00*

Attachment



8007280 442

P