

# LICENSEE EVENT REPORT

CONTROL BLOCK:             ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

⑦ ⑧ 0 1 | N J S G S 2 | ② | 0 0 - 0 0 0 0 0 0 - 0 0 | ③ | 4 1 1 1 1 1 | ④ |   | ⑤  
7 8 9 14 15 25 26 30 57 58

CON'T  
⑦ ⑧ 0 1 | REPORT SOURCE | L | ⑥ | 0 5 0 0 0 3 1 1 1 | ⑦ | 0 7 0 9 8 0 | ⑧ | 0 8 0 8 8 0 | ⑨  
60 61 68 69 74 75 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

⑦ ⑧ 0 2 | During a Reactor Coolant System heatup, it was determined that various

⑦ ⑧ 0 3 | Steam Generator Flow and Pressure Channels were not responding properly

⑦ ⑧ 0 4 | Action Statement 3.3.2.1 was entered at 1220, and the bistables were

⑦ ⑧ 0 5 | placed in a tripped condition within 1 hour. This is the first

⑦ ⑧ 0 6 | occurrence of this type.

⑦ ⑧ 0 7 |

⑦ ⑧ 0 8 |

⑦ ⑧ 0 9 | SYSTEM CODE | I B | ⑪ | CAUSE CODE | D | ⑫ | CAUSE SUBCODE | Z | ⑬ | COMPONENT CODE | I N S T R U | ⑭ | COMP. SUBCODE | E | ⑮ | VALVE SUBCODE | Z | ⑯

⑪ ⑫ ⑬ ⑭ ⑮ ⑯

⑰ LER/RO REPORT NUMBER | 8 0 | 21 22 | SHUTDOWN METHOD | Z | 20 | 21 | SEQUENTIAL REPORT NO. | 0 0 9 | 24 26 | OCCURRENCE CODE |  | 27 | 0 3 | 28 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32

⑰ 21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | E | ⑱ | 33 | FUTURE ACTION | G | ⑳ | 34 | EFFECT ON PLANT | Z | 20 | 35 | SHUTDOWN METHOD | Z | 21 | 36 | HOURS | 0 0 0 0 | 37 40 | ATTACHMENT SUBMITTED | Y | ⑲ | 41 | NPRD-4 FORM SUB. | N | ⑳ | 42 | PRIME COMP. SUPPLIER | L | ⑳ | 43 | COMPONENT MANUFACTURER | F 1 2 0 | ⑳ | 44 47

⑱ ⑲ ⑳ ⑲ ⑳ ⑲ ⑳ ⑲ ⑳ ⑲ ⑳ ⑲ ⑳

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

⑦ ⑧ 1 0 | The isolation valve from the main steam piping was shut which prevented

⑦ ⑧ 1 1 | the channels from operating properly. The valve was opened. The heat-

⑦ ⑧ 1 2 | up procedure has been changed to require the valve lineup to be completed

⑦ ⑧ 1 3 | prior to commencing a plant heatup.

⑦ ⑧ 1 4 |

⑦ ⑧ 1 5 | FACILITY STATUS | B | ⑳ | 7 8 | % POWER | 0 0 0 0 | ⑳ | 9 10 | OTHER STATUS | N/A | ⑳ | 11 12 | METHOD OF DISCOVERY | A | ㉑ | 13 14 | DISCOVERY DESCRIPTION | Improper Indication | ㉒ | 15 16

⑳ ⑲ ㉑ ㉒

⑦ ⑧ 1 6 | ACTIVITY RELEASED | Z | ㉑ | 7 8 | CONTENT OF RELEASE | Z | ㉒ | 9 10 | AMOUNT OF ACTIVITY | NA | ㉑ | 11 12 | LOCATION OF RELEASE | NA | ㉒ | 13 14

㉑ ㉒ ㉑ ㉒

⑦ ⑧ 1 7 | PERSONNEL EXPOSURES | NUMBER | 0 0 0 | ㉑ | 9 10 | TYPE | Z | ㉒ | 11 12 | DESCRIPTION | NA | ㉑ | 13 14

㉑ ㉒ ㉑ ㉒

⑦ ⑧ 1 8 | PERSONNEL INJURIES | NUMBER | 0 0 0 | ㉑ | 9 10 | DESCRIPTION | NA | ㉑ | 11 12

㉑ ㉒ ㉑ ㉒

⑦ ⑧ 1 9 | LOSS OF OR DAMAGE TO FACILITY | TYPE | Z | ㉑ | 9 10 | DESCRIPTION | NA | ㉑ | 11 12

㉑ ㉒ ㉑ ㉒

⑦ ⑧ 2 0 | ISSUED | N | ㉑ | 9 10 | DESCRIPTION | NA | ㉑ | 11 12 | PUBLICITY |  | ㉑ | 13 14 | NRC USE ONLY |   | ㉑ | 15 16

㉑ ㉒ ㉑ ㉒ ㉑ ㉒

8008140331  
NAME OF PREPARER M.J. Murphy

PHONE: 609-935-0998