(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: N J S G S 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT: (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 7 2 (7)	EVENT DATE: 1 0 2 0 8 0 (8)	REPORT DATE: 1 0 2 8 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 0837 hours, a routine reactor coolant boron sample indicated a concentration
0 3 of 1898 ppm which is less than the 2000 ppm minimum required by Technical
0 4 Specification 3.9.1 for Mode 6 operation. Boration was commenced in accordance with
0 5 the Action Statement and the RCS boron concentration was returned to 2132 ppm by
0 6 1050 hours.
0 7
0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	C A (11)	A (12)	C (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 5 3	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	G (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The RCS was drained to half loop level and a hydrolazer was being used to
1 1 decontaminate the steam generator channel heads. Personnel failed to anticipate and
1 2 plan for the effects of the water that entered the RCS causing the dilution. The
1 3 job was terminated and a procedure will be developed for hydrolazing the Primary
1 4 Coolant System

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	H (28)	0 0 0 (29)	N/A	B (31)	Boron Sample

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	N/A

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	N/A	

NAME OF PREPARER J. M. Randolph PHONE: 609-935-0998

GPO 917-926

8011030575