



PSEG

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

December 11, 1980

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. Steven Varga, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Gentlemen:

REQUEST FOR AMENDMENT
FACILITY OPERATING LICENSE DPR-70
UNIT NO. 1
SALEM GENERATING STATION
DOCKET NO. 50-272

In accordance with the Atomic Energy Act of 1954, as amended and the regulations thereunder, we hereby transmit copies of our request for amendment and our analysis of the change to our Facility Operating License DPR-70 for Salem Generating Station, Unit No. 1.

This request consists of a proposed change to the Safety Technical Specifications (Appendix A) involving modification to limits on a Surveillance flow test of Sodium Hydroxide (NaOH) from the Containment Spray Additive Tank.


This change is deemed to not involve a significant hazards consideration. Therefore, it is determined to be a Class III amendment as defined by 10CFR 170.22, and a check for the amount of \$4,000 is enclosed.

We would appreciate a prompt review and response to this request as this change is required in order to change modes, presently scheduled for December 11, 1980. Technical Specification Surveillance Requirement 4.6.2.1 concerning the eductor flow rate was satisfactorily demonstrated on December 7, 1980. Eductor performance curves will be obtained from Westinghouse Electric Corporation and forwarded at a future date.

This submittal includes three (3) originals and forty (40) copies.

Very truly yours,

Richard A. Uderitz
Richard A. Uderitz
General Manager -
Nuclear Production



1879 1979

US NRC
DISTRIBUTION SERVICES
BRANCH

US NRC
DISTRIBUTION SERVICES
BRANCH

1980 DEC 18 AM 11 51 AM 11 51

RECEIVED DISTRIBUTION SERVICES UNIT
DISTRIBUTION SERVICES UNIT

A001
S
3/3
W/Check: \$4000.00

80121902/6

P