

CONTAINMENT SYSTEMS

SPRAY ADDITIVE SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.2 The spray additive system shall be OPERABLE with:

- a. A spray additive tank containing a volume of at least 2000 gallons of not less than 30 percent by weight NaOH solution, and
- b. Two spray additive eductors each capable of adding NaOH solution from the chemical additive tank to a containment spray system pump flow.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the spray additive system inoperable, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the spray additive system to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.2.2 The spray additive system shall be demonstrated OPERABLE:

- a. At least once per 31 days also by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 6 months by:
 - 1. Verifying the solution level in the tank, and
 - 2. Verifying the concentration of the NaOH solution by chemical analysis.
- c. At least once per 18 months during shutdown, by verifying that each automatic valve in the flow path actuates to its correct position on a Containment High-High pressure test signal.
- d. At least once per 5 years by verifying a NaOH solution flow rate of ~~7.3 ± 0.7~~ **12.0 ± 3.0** gpm from the spray additive tank through sample valve 1CS61 with the spray additive tank at 2.5 ± 0.5 psig.