

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

1	6	0	5	0	0	0	2	7	2	7	0	2	0	6	8	1	8	0	2	2	6	8	1	9
60	61							68	69							74	75							80
DOCKET NUMBER										EVENT DATE								REPORT DATE						

0 2 | During normal operation on 2/6/81, the Rod Position Indicator for Rod 2D1 indicated

0 3 | that the rod had dropped. The RPI was declared inoperable and Action Statement

0 4 | 3.1.3.2.a was entered at 2320 hours. Similar occurrences were: 77-87, 79-5 and

0 5 | 80-24.

7 8 9 10 11 12 13 14 15 16 17 18 19 20

0 9 R B X Z E L E C O N Z Z

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

(17)	LER NO REPORT NUMBER	EVENT YEAR [8 1] 21 22	[—] 23	SEQUENTIAL REPORT NO. [0 1 5] 24 25 26	[/] 27	OCCURRENCE CODE [0 3] 28 29	REPORT TYPE [L] 30	[—] 31	REVISION NO. [0] 32
ACTION TAKE'	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	(22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
[X] 33	(18) [Z] 34	(19)	[Z] 35	(20)	[0 0 0 0] 37 38 39 40	[Y] (23) 41	[N] (24) 42	[N] (25) 43	[W 1 2 0] (26) 44 45 46 47

1 0 | The Amphenol screw connector on the rod's position indicator cable was loosely
1 1 | connected at the reactor head. The connection was made secure and a satisfactory
1 2 | surveillance test performed. The Action Statement was terminated at 0730 hours on
1 3 | 2/7/81.

FACILITY STATUS				% POWER				OTHER STATUS (30)				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION (32)			
1	5	E	28	0	3	0	29	N/A				A	31	Operator Observation					
7	8	9		10		12		13				44	45		46		80		

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 7 8 9 10 11

Z 33 Z 34

AMOUNT OF ACTIVITY 35

N/A

LOCATION OF RELEASE 36

N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	7		0	0	0	37	Z	38	N/A

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	2	3	4	5	6
0	0	0	40	N/A	

11 12
LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 9
7 8 9 10
Z (42) N/A

PUBLICATION		ISSUED		DESCRIPTION		NRC USE ONLY	
2	0	N	44	N/A			

NRC USE ONLY

8103030682

NAME OF PREPARER W. J. Steele

PHONE: 609-935-0998