NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	N J S G S 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT

CON'T 0 1	REPORT SOURCE L (6)	0 5 0 0 0 3 1 1 (7)	0 4 1 3 8 1 (8)	0 5 1 1 8 1 (9)
		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 1823 hours on April 13, 1981, Action Statement 3.4.1.1.b.2.b was entered
0 3 because all Reactor Coolant and Residual Heat Removal Pumps were de-energized
0 4 to facilitate the replacement of relief valve 2RH3 in the Residual Heat Removal
0 5 System. Technical Specifications allow for all these pumps to be de-energized for
0 6 up to one hour. The task of replacing 2RH3 and returning the Residual Heat
0 7 Removal System to operation required 5 hours and 22 minutes. The Action Statement
0 8 was terminated at 2345 hours.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	C F (11)	X (12)	X (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 0 5	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
Z (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	L (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The time allowed by Technical Specifications for all the pumps to be de-energized
1 1 was not sufficient for the completion of the task of replacing 2RH3 and returning
1 2 the system to operation. PSE&G feels that this particular event warrants no
1 3 specific corrective action.
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	G (28)	0 0 0 (29)	NA	Z (31)	N/A

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

8105190437

NAME OF PREPARER W. J. Steele PHONE: 609-935-0998

GPO 917-928