
'JUL 0 1 1981

Docket Nos.5503272 and 50-311

> Mr. F. W. Schneider, Vice President Production Public Service Electric and Gas Company 80 Park Plaza 15A Newark, New Jersey 07101

Docket NRC PDR L PDR TERA NSIC ORB#1 Rdg DEisenhut 0ELD IE-3 ACRS-10 SVarga WRoss **CParrish**

Gray File



Dear Mr. Schneider:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER

FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSS DESIGNED

BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

> Sincerely, Original signed by S. A. Varga

Steven A. Varga, Chief Operating Reactors Branch #1 Division of Licensing

cc: See next page

8107100012 810701 PDR ADOCK 05000272

OFFICE	م طار: 0RB#1	QRB#1:DL		LA#A	 	
SURNAME	WRoss de	Svarga	GMeyer	CM//raglia	 	
DATE 🎝	6/ 2 6/8]	6/2081	6/५२ /८१	6 1/2 7/81	 	

NULL 10 : 1981

Docket Nos. 50-250 and 50-251

> Dr. Robert E. Uhrig, Vice President Advanced Systems and Technology Florida Power and Light Company Post Office Box 529100 Miami, Florida 33152

DISTRIBUTION Dockets GLainas NRC PDR **PCheck** L PDR TERA NSIC ORB#1 Rdg DEisen-ut 0ELD IE-3 NUCLEAR REGULATORY ACRS-10 SVarga MGrotenhuis **CParrish** Bray File

ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH MSSSS DESIGNED

BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators sucheas those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by: S. A. Varga

Steven A. Varga, Chief Operating Reactors Branch #1 Division of Licensing

See next page

NRC FORM 318 (10-80) NRCM 0240

NRC FORM 318 (10-80) NRCM 0240 OFFICIAL RECORD COPY							
DATE	.7//81:ds	7//.81			***************************************	••••••	
SURNAME	MGrotenhuis	SVarga				•••••	
OFFICE	ORB#1:DL	ORB#1:DL		•••••	•••••		

porter

U.S. NUCLEAR REGULATO



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

July 1, 1981

Docket Nos. 50-272 and 50-311

> Mr. F. W. Schneider, Vice President Production Public Service Electric and Gas Company 80 Park Plaza 15A Newark, New Jersey 07101

Dear Mr. Schneider:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER

FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED

BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Steven A. Varga, Chief

Operating Reactors Branch #1

Division of Licensing

cc: See next page

Mr. F. W. Schneider

Public Service Electric and Gas Company

cc: Mark J. Wetterhahn, Esquire Conner, Moore and Corber Suite 1050 1747 Pennsylvania Avenue, NW Washington, D. C. 20006

> Richard Fryling, Jr., Esquire Assistant General Solicitor Public Service Electric and Gas Company 80 Park Place Newark, New Jersey 07101

Gene Fisher, Bureau of Chief Bureau of Radiation Protection 380 Scotch Road Trenton, New Jersey 08628

Mr. R. L. Mittl, General Manager Licensing and Environment Public Service Electric and Gas Company 80 Park Plaza 17C Newark, New Jersey 07101

Mr. Henry J. Midura, Manager Salem Nuclear Generating Station Public Service Electric and Gas Company P. O. Box 168 Hancocks Bridge, New Jersey 08038

Salem Free Library 112 West Broadway Salem, New Jersey 08079

Leif J. Norrholm, Resident Inspector Salem Nuclear Generating Station U. S. Nuclear Regulatory Commission Drawer I Hancocks Bridge, New Jersey 08038

Peter A. Moeller Nuclear Licensing Engineer Public Service Electric and Gas Company 80 Park Plaza - 15A Newark, New Jersey 07101 Mr. R. A. Uderitz
General Manager, Nuclear
Production
Public Service Electric and
Gas Company
80 Park Plaza 15A
Newark, New Jersey 07101

Mr. J. T. Boettger
General Manager, Quality
Assurance
Public Service Electric and
Gas Company
80 Park Plaza 16-E
Newark, New Jersey 07101

Mr. Edwin A. Liden, Manager
Nuclear Licensing
Licensing and Environment Dept.
Public Service Electric and Gas
Company
80 Park Plaza 16D
Newark, New Jersey 07101