The circulating and service water systems of Unit 1 and 2 were chlorinated from April until December (Table 2.2.1-1) During the chlorination periods, the analyses of free chlorine residual indicated values between <0.1-0.5 mg/liter at the condenser outlets. Consequently, because of the additional dilution from the unchlorinated condenser shell and the additional chlorine demand from that water, the concentration at the discharge to the river was less than 0.1 mg/liter.

## TABLE 2.2.1-1

## SODIUM HYPOCHLORITE SYSTEM 1980 OPERATING SUMMARY

		Sodium Hypo- chlorite System			Free Chlorine
Water System	Unit No.	In Service	Out of Service	Days of Chlorination	Residual (mg/liter)
Circulating	1*				
	2	Nov. 9	Dec. 10	22	0.2-0.5
Service	1	Apr. 22	Aug. 15	18	<0.1-0.5
	2	Apr. 24	Nov. 4	19	<0.1-0.4

\*No chlorination was conducted in 1980

Suspended Solids (ETS Section 2.2.2) 2.2.2

The non-radioactive liquid waste basin processes make-up demineralizer and condensate polishing demineralizer regenerant wastes and steam generator blowdown, permitting solids settling before discharging to the river.

In 1980, 24-hr composite samples for suspended solids (TSS) were taken from the basin discharge pipe monthly and analyses were performed using the filtration/gravimetric method which is recognized by EPA.

M P80 50 01

8107240530 810713 PDR ADOCK 05000272

PDR







