

MAR 26 1982

Docket Nos. 50-272  
50-311



MEMORANDUM FOR: Steven A. Varga, Chief  
Operating Reactors Branch #1, DL

FROM: William J. Ross, Project Manager  
Operating Reactors Branch #1, DL

SUBJECT: MEETING WITH PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
RELATED TO FIRE PROTECTION AT SALEM UNITS 1 AND 2

On March 8, 1982 representatives of Public Service Electric and Gas Company (the licensee) met with the staff to discuss the need for automatic fire suppression systems in certain areas of Salem Units 1 and 2. A list of participants is enclosed.

In several previous meetings, the licensee had described proposed methods for meeting the requirements of Section G of Appendix R to 10 CFR Part 50, "Fire Protection of Safe Shutdown Capability." In several areas of both Salem Units 1 and 2 cables and equipment and associated non-safety circuits of redundant trains are neither separated by a three-hour barrier nor protected by an automatic fire suppression system as required by III.G.2. The licensee has been attempting to provide an acceptable level of protection without converting the existing manual fire suppression systems to automatic.

During this meeting the licensee and consultant described a model for analyzing fire loading and demonstrated how this model could be used to predict the expected fire severity of rooms with the plant. This presentation is summarized in Enclosure 2.

The staff agreed that the model indicated that the fire severity in most of the areas under consideration could be maintained at an acceptable level for 30 minutes, without the use of an automatic suppression system, until the fire brigade can begin to fight the fire. However, the staff was not convinced that the model suffices for all rooms, configurations, or ventilation systems. The 4kv switchgear rooms and the electrical penetration rooms were identified as two areas where the model's results were suspect.

8204140537 820326  
PDR ADDCK 05000272  
F PDR

OFFICE ▶	.....	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....	.....

The staff requested the licensee to provide, within three weeks, further justification that all rooms could be protected without an automatic suppression system (as demonstrated by their model) or alternative means of meeting the requirements of Section G. The staff also advised the licensee that we have reservations related to the use of carbon dioxide suppression systems, especially manual systems but we would be willing to discuss all options.

William J. Ross, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosures:  
As stated

OFFICE ▶	DL:ORB#1						
SURNAME ▶	WJROSS/MS						
DATE ▶	3/26/82						

MEETING SUMMARY  
OPERATING REACTORS BRANCH NO. 1  
DIVISION OF LICENSING

MAR 26 1982

Docket File  
NRC PDR  
Local PDR  
ORB 1 File  
J. Heltemes, AEOD  
B. Grimes  
S. Varga  
Project Manager  
OELD  
OI&E (1)  
ACRS (10)  
NRC Participants  
NSIC

cc: Licensee with  
Service List

Mr. R. A. Uderitz  
Public Service Electric and Gas Company

cc: Mark J. Wetterhahn, Esquire  
Conner and Wetterhahn  
1747 Pennsylvania Avenue, NW  
Suite 1050  
Washington, D.C. 20006

Ronald C. Haynes  
Regional Administrator - Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Richard Fryling, Jr., Esquire  
Assistant General Solicitor  
Public Service Electric and Gas Company  
Mail Code T5E - P.O. Box 570  
Newark, New Jersey 07101

Gene Fisher, Bureau of Chief  
Bureau of Radiation Protection  
380 Scotch Road  
Trenton, New Jersey 08628

Mr. R. L. Mittl, General Manager -  
Corporate Quality Assurance  
Public Service Electric and Gas Company  
Mail Code T16D - P.O. Box 570  
Newark, New Jersey 07101

Mr. Henry J. Midura, General Manager -  
Salem Operations  
Public Service Electric and Gas Company  
P.O. Box 168  
Hancocks Bridge, New Jersey 08038

Salem Free Library  
112 West Broadway  
Salem, New Jersey 08079

Leif J. Norrholm, Resident Inspector  
Salem Nuclear Generating Station  
U. S. Nuclear Regulatory Commission  
Drawer I  
Hancocks Bridge, New Jersey 08038

Mr. Edwin A. Liden, Manager -  
Nuclear Licensing  
Public Service Electric and Gas Company  
Mail Code T16D - P.O. Box 570  
Newark, New Jersey 07101

Participants

NRC

R. Benedict  
J. Stang  
W. Ross  
R. Eberle

Licensee

W. Pavincich  
G. Supplee  
M. Swann (Protopower)

## SALEM GENERATING STATION FIRE HAZARD ANALYSIS

OBJECTIVE: Develop a practical tool for predicting the expected fire severity of rooms within the Salem Generating Station consistent with recognized fire hazard analyses and test data.

This tool will serve as the basis for area by area exemption requests for employing one hour rated fire barriers without automatically initiated suppression systems.

METHODOLOGY: Employing the recently developed computer program, establish if a satisfactory correlation between equivalent ASTM E-119 fire severity and combustible fire load density exists. Compare values with NFPA Fire Protection Handbook Table 6-8A.

TABLE 6-8A. Estimated Fire Severity for Offices  
and Light Commercial Occupancies

Data applying to fire-resistive buildings with  
combustible furniture and shelving

Combustible Content Total, including finish, floor, and trim psf	F <sub>f</sub> Heat Potential Assumed* Btu per sq.ft. (x10 <sup>3</sup> )	Equivalent Fire Severity Approximately equivalent to that of test under standard curve for the following periods:
5	40	30 min.
10	80	1 hr.
15	120	1½
20	160	2
30	240	3
40	320	4½
50	380	7
60	432	8
70	500	9

\* Heat of combustion and weights of combustibles  
correspond to ordinary combustible materials  
such as wood, paper, or textiles.

COMPUTER PROGRAM DESCRIPTION:

SUMMARY: The program conducts a transient energy and mass balance for given combustibles and room configurations to produce an approximate room air temperature - time profile. This profile is used to establish a fire rating by determining its equivalency to the ASTM E-119 fire test curve.

NEW

CHANGES: o Revised heat of combustion values ( $H_A$ ) to be consistent with available test data and other analyses.

- Heptane,  $H_A = 44.56 \text{ KJ/g}^{(1)}$  for complete combustion.

$H'_A = 30.75 \text{ KJ/g}^{(1)}$  net, actual.  $\approx 73,000 \text{ BTU/gallon}$

(Cable) - EPR/Hypalon,  $H_A = 17.4-29.6 \text{ KJ/g}^{(1)}$  for complete combustion.

$$H'_A = \eta_c H_A$$

$$\eta_c = 0.5^{(2)}$$

$H'_A = 14.8 \text{ KJ/g}$  net, actual  $6400 \text{ BTU/lb.}$



- o Revised actual heat release rates ( $\dot{Q}_A$ ) to be consistent with available test data.

- Heptane, *heat release rate* =  $\dot{Q}_A = 2700 \text{ KW/m}^2(1) = 239 \text{ Btu/sec-ft}^2$

linear regression rate = 4 mm/min<sup>(3)</sup>  $\Rightarrow \dot{Q}_A = \underline{120} \text{ Btu/sec-ft}^2$

convective fraction = 67%<sup>(1)</sup>

radiative fraction = 33%<sup>(1)</sup>

- EPR/Hypalon,  $\dot{Q}_A = 180-350 \text{ KW/m}^2(1) = 15.9-30.8 \text{ Btu/sec-ft}^2$

convective fraction = 38-65%<sup>(1)</sup>  $X_C = \underline{67\%}$

radiative fraction = 62-35%<sup>(1)</sup>  $X_R = \underline{33\%}$

$\dot{Q}_A = H_A / 30 \text{ min.} = \underline{3.54} \text{ Btu/sec-lbm.} =$

SALIENT POINTS:

- o Ignition of all in situ combustibles is made to occur almost spontaneously within a few seconds of transient combustible ignition.
- o Cable heat release rate,  $\dot{Q}_A = 3.54$  Btu/sec-lbm, is highly conservative if all the cabling is assumed to be burning simultaneously.
- o Radiative fraction of 1/3 is consistent with generally recognized fire characteristics.
- o Convective heat transfer coefficient assumes laminar flow past boundary surfaces; actual mode is generally turbulent.

## RESULTS:

- o Typical time-temperature profile, Figure 1.
- o Selected burn rate provides conservative results. Effect of different burn rates is depicted in Figure 2.
- o Unsuccessful correlation of floor fire load density with equivalent E-119 fire severity, Figure 3.
- o Successful correlation using the total boundary area fire load density,  $t_E = 0.168 F_b^{0.605}$ .
  - The maximum acceptable fire load density,  $F_b \approx 5000$  Btu/ft<sup>2</sup> boundary area.
  - > - Rooms for which an exemption is requested meet this criteria.
  - The ASTM E-119 fire test curve converted to the 250°F base is described by the equation,  $t_E = 0.055 U^{0.621}$  for  $5 \leq t_E \leq 60$  min, Figure 5. The near equality of the exponents for this equation and that for the correlation curve, verifies a direct relationship between the fire load density and the integral of the fire test curve.
  - The correlation is not without precedence. Theoretical studies in Sweden<sup>(4)</sup> have led to the same conclusion.

APPLICABILITY OF CORRELATION:

- o Non-ventilation controlled fires.
- o Similar boundary material thermal properties and thicknesses.
- o Approximately similar room geometries,  $3 \leq R \leq 8$ .

SUMMARY:

- o Utilizing the developed computer program, a successful correlation between fire load density based on total boundary surface area and equivalent E-119 fire severity has been obtained.
- o The rooms of the Salem Generating Station for which an exemption is requested meet the fire load density criteria.

## NOMENCLATURE

- $A_b$  = Total room boundary surface area ( $l^2$ ).
- $A_f$  = Room floor area ( $l^2$ ).
- $F_b$  = Fire load density based on total boundary area,  $Q_T/A_b$ , ( $E/l^2$ ).
- $F_f$  = Fire load density based on floor area,  $Q_T/A_f$ , ( $E/l^2$ ).
- $H_A$  = Actual heat of combustion for complete combustion ( $E/M$ ).
- $H_A'$  = Net, actual heat of combustion (incomplete combustion) ( $E/M$ ).
- $R$  = Room geometry coefficient,  $A_b/A_f$  (-).
- $Q_T$  = Total combustible fire load ( $E$ ).
- $\dot{Q}_A$  = Net heat release rate ( $E/t$ ).
- $t_E$  = Equivalent ASTM E-119 fire severity ( $t$ ).
- $U$  = Integral of ASTM E-119 fire test curve ( $t-T$ ).
- $X_c$  = Convective fraction (-).
- $X_r$  = Radiative fraction (-).
- $\eta_c$  = Combustion efficiency (-).

#### REFERENCES

- (1) Tewarson, A., "Damageability and Combustibility of Electrical Cables", Factory Mutual Research Corp.
- (2) "NRC Twenty Foot Separation Fire Test Plan", Edison Electric Institute.
- (3) Burgess, D. and Hertzberg, M., "Radiation from Pool Flames", U.S. Dept. of Interior, Bureau of Mines.
- (4) Odeen, K., "Theoretical Study of Fire Characteristics in Enclosed Spaces", Bulletin 10, Division of Building Construction, Royal Institute of Technology, Stockholm.

<b>PROTO POWER MANAGEMENT CORPORATION GROTON, CONNECTICUT</b>	CALC NO	PAGE	OF
	ORIGINATOR	DATE	
	REVIEWED	JOB NO.	
CLIENT	PROJECT		
SUBJECT			




FIG. 1 PZF-1 TEMP-TIME PROFILE

<b>PROTO POWER MANAGEMENT CORPORATION GROTON, CONNECTICUT</b>	CALC NO	PAGE	OF
	ORIGINATOR	DATE	
	REVIEWED	JOB NO	
	CLIENT	PROJECT	
SUBJECT			





FIG. 2. EFFECT OF CABLE BURN RATE



FIG 3.  $F_c$  vs.  $t_E$



FLOOR FIRE LOAD DENSITY  $F_c = Q_c/A_c$   
 (BTU/ft<sup>2</sup> floor)

(Btu/ft<sup>2</sup>)

BOUNDARY SURFACE FIRE LOAD DENSITY,  $F_b = Q_T/A_b$

$F_{b,max} @ t_E = 30$




FIG. 4.  $F_b$  vs.  $t_E$

$$U_{250} = \int_0^{t_f} T_{250} dt_f \quad (^\circ\text{F} \cdot \text{min.})$$

ASTM E-119 FIRE SEVERITY - BASE 250°F




FIG. 5.  $U_{250}$  vs.  $t_E$