

DPR 70
DPR 75

REPORT NO. RERR-13


TE HQ FILE COPY

UNIT NOS. 1 & 2
RADIOACTIVE EFFLUENT RELEASE REPORT
JULY - DECEMBER 1982

SALEM NUCLEAR GENERATING STATION
Public Service Electric and Gas Company

M P79 43/33 1-gs

8309160006 830824
PDR ADDCK 05000272
R PDR



PSEG

The Energy People

1982

SEMIANNUAL RADIOACTIVE
EFFLUENT RELEASE REPORT
RERR-13

SALEM NUCLEAR GENERATING STATION
SALEM UNIT NOS. 1 & 2

UNIT 1 DOCKET NO. 50-272
UNIT 2 DOCKET NO. 50-311
OPERATING LICENSE NO. DPR-70
OPERATING LICENSE NO. DPR-75

FINAL

JULY 1983

SALEM NUCLEAR GENERATING STATION
UNIT NOS. 1 AND 2
RADIOACTIVE EFFLUENT RELEASE REPORT
July 1, 1982 to December 31, 1982

Introduction

This report, RERR-13, summarizes the releases of radioactive materials in liquid, gaseous and solid form from the Salem Nuclear Generating Station Units 1 and 2 for the period July 1, 1982 to December 31, 1982. As requested by the United States Nuclear Regulatory Commission (USNRC) this report was prepared in the format specified for all nuclear power plants as defined in USNRC Regulatory Guide 1.21.

The report is prepared in the format of Regulatory Guide 1.21, Appendix B, as required by Specification 5.6.1.2 of the Salem Environmental Technical Specifications. Preceding the tables summarizing the gaseous and liquid discharges and solid waste shipments is our response to parts A-F of the "Supplemental Information" section of the Regulatory Guide 1.21, Appendix B.

As required by Regulatory Guide 1.21, our Technical Specification limits are described in detail within this report along with a summary description of how measurements and approximations of the total activity discharged were developed.

To facilitate determination of compliance with 40CFR190 requirements, the following information on electrical output is provided.

Unit 1 generated 1,843,381 megawatt-hours of electrical energy (net) during the reporting period.

Unit 2 generated 3,448,270 megawatt-hours of electrical energy (net) during the reporting period.

Due to a major modification in our Company's computer processing equipment, tabulations of releases were not available for inclusion in our earlier report. This report provides the information which was not available for inclusion in our earlier report.

Part A. PRELIMINARY SUPPLEMENTAL INFORMATION

1.0 Regulatory Limits

We are required to summarize our regulatory limits in each report. Symbols utilized in the equations listed below under Sections 1.1 and 1.2 are the same as those used in the Salem Environmental Technical Specifications (ETS). The symbol Q as explained in Section 2.3.3 of the ETS is the release rate of the gaseous activity in units of curies per second. The K, L, M and N terms are actually site dependent dose conversion factors. The equations listed below in Sections 1.1 and 1.2 take into consideration the release point location, building wake effects and physical characteristics of the radionuclides released.

In addition 40CFR190 regulations require that the annual dose equivalent does not exceed 25 mrem to the whole body or any organ (except the thyroid which is limited to 75 mrem).

1.1 Fission and Activation Gases Release Limits

- a) Gaseous releases from the nuclear units are limited such that at no time will releases of gaseous radioactive materials cause a member of the general public to be exposed to an annual dose rate in excess of 500 mrem to the entire body or 3 rem to the skin in conformance with the requirements of 10CFR20.
- b) Gaseous releases from the units are further restricted such that when releases are averaged over a calendar quarter no member of the general public will be exposed to an annual dose rate in excess of 20 millirads of gamma radiation or 40 millirads of beta radiation.
- c) In addition, it is required that air doses averaged over a twelve month period be less than 40 and 80 millirads for gamma and beta radiation respectively.

We use the following equations to demonstrate compliance with these limits:

$$2.0 Q_{tv} * K_v \leq 1$$

$$0.33 Q_{tv} * (L_v + 1.1 N_v) \leq 1$$

When averaged over a calendar quarter the release rate for radioactive gases must satisfy the following equation. The basis for these equations is 10CFR50 Appendix I.

$$13 Q_{tv} * \bar{N}_v \leq 1$$

$$6.3 Q_{tv} * \bar{M}_v \leq 1$$

The limiting Unit 1 release limit Q is calculated to be 5.78E+04 and 5.87E04 microcuries/sec for both the 3rd and 4th quarters respectively.

The limiting Unit 2 release limit Q is calculated to be 5.87E+04 and 5.62E+04 microcuries/sec. for the 3rd and 4th quarters respectively.

When averaged over any twelve consecutive month period, the release rate for radioactive gases must satisfy the following equation. The basis for this equation is 10CFR50 Appendix I.

$$25 Q_{tv} * \bar{N}_v \leq 1$$

$$13 Q_{tv} * \bar{M}_v \leq 1$$

The release limits of radioactive gases for the Salem Nuclear Generating Station are not fixed numbers, but depend upon the radioactive isotopes present in the effluent.

1.2 Iodine and Particulates, Half Life > 8 days

The regulatory limits for iodines and particulates are listed below.

The release rates of iodine and particulates are restricted such that no member of the general public will receive a dose at a rate in excess of 1.5 rem/yr. to the thyroid.

Releases of iodines and particulates are further restricted to prevent any member of the general public from receiving a dose rate in excess of 30 mrem in a calendar quarter or 60 mrem in any twelve month period. The equations which govern these conditions are listed below:

At any instant of time the release rate for radioactive iodines and particulates material with a half life greater than 8 days is limited by the equation below. The basis for this equation is 10CFR20.

$$(1.5 \times 10^5) Q_v \leq 1$$

During any calendar quarter the release limit is governed by the equations listed below. The basis for these equations is 10CFR50 Appendix I.

$$\begin{array}{c} 2 \text{ curies of I-131} \\ \text{and} \\ Q_v \times 13 \times (1.5 \times 10^5) \leq 1 \end{array}$$

During any twelve month period radioactive releases should conform to the following constraints of 10CFR50 Appendix I.

$$\begin{array}{c} 25 \times (1.5 \times 10^5) \times Q_v \leq 1 \\ \text{and} \\ 4 \text{ curies of I-131} \end{array}$$

1.3 Liquid Effluents Release Limits

We are not permitted to discharge radioactive liquids such that we exceed the values in 10CFR20, Appendix B, Table II, Column 2.

In addition, the following limits apply:

The cumulative release of radioactive effluents, excluding tritium and dissolved gases, shall be less than 10 Ci in a calendar quarter for each unit.

The cumulative release of radioactive effluents, excluding tritium and dissolved gases, shall be less than 20 Ci in any twelve consecutive months for each unit.

2.0 Maximum Permissible Concentrations (MPC)

Regulatory Guide 1.21 requires that the licensee provide the MPC's used in determining allowable release rates for radioactive releases.

- a) MPC values were not used to determine the maximum release rates for fission gases, iodines, or particulates.
- b) MPC values as stated in 10CFR20, Appendix B, Table II, Column 2 were used for liquids.

3.0 Average Energy

Regulatory Guide 1.21 requires that the licensee provide the average energy of the radionuclide mixture in releases of fission and activation gases, if applicable.

Release limits for the SNGS are not based upon average energy, hence, this section does not apply.

4.0 Measurements and Approximation of Total Radioactivity

4.1 Liquid effluents are monitored in accordance with Table 2.3-3 of the Environmental Technical Specifications. During the period of record, all wastes from the chemical drain tank and the laundry and hot shower tanks were routed to the hold-up tanks for monitoring prior to release. Technical Specifications require these tanks to be recirculated the equivalent of two tank volumes to produce uniform mixing before sampling and analysis before any releases are made. Batch releases are defined as releases from the waste monitor tanks, waste monitor hold-up tank, and the chemical and volume control tanks. Continuous releases are defined as releases from intermittent blowdown of the steam generators. The predominant gamma emitting isotopes detected in sampling were Co58, Co60, Cr51, and Mn54. Specific activity from analyses were multiplied by the volume of effluent discharged to the environment in order to estimate the total liquid activity discharged.

4.2 Gaseous effluent streams are monitored and sampled in accordance with Table 2.3-4 of the Environmental Technical Specifications. The plant vent is the final release point of all planned gaseous effluents and is continuously monitored by four very sensitive Geiger Mueller (GM) tubes. The GM tubes are intended as a surveillance device. The vent is also continuously sampled for iodine and particulates with a charcoal cartridge and filter paper connected in series to a low volume air sampler. The filter and charcoal are changed weekly, and analyzed on a multichannel analyzer in the laboratory. Sampling is also performed on all gas decay tanks and containment purges, prior to their release to the environment. The plant vent is sampled for noble gases monthly. All tritium samples were taken by bubbling gas through water and then counting the tritiated water on a liquid scintillation counter.

The detection requirements of Table 2.3-2 of the ETS are achieved or exceeded. Isotopes existing at concentrations below the achieved detection limit are not treated as being present.

Continuous Mode gaseous releases are quantified by routine (monthly or weekly) sampling and isotopic analyses of the plant vent. Specific activities for each isotope detected are multiplied by the total vent flow volume for the entire sampling period in order to estimate the normal continuous release of radioactivity through the plant vent if any exists.

Batch Mode releases are quantified by the sample of each gas decay tank or containment purge prior to discharge. Specific activities for each isotope are multiplied by the total volume of gas discharged.

Elevated RMS readings while the channel is in an alarm state are treated as batch mode releases. If specific activity data from grab samples taken while the release was in progress is not available, then the abnormal release will be quantified by the use of the plant vent radiation monitors. The monitors response is converted in a "specific activity" using historical efficiency factors. The "specific activity" is multiplied by the volume of effluent discharged while the channel was in an alarm state in order to estimate the total activity discharged.

4.3 The estimated total error of the reported continuous gaseous releases is within 50% when concentrations exceed detectable levels. This error is due primarily to variability of waste stream flow rates and changes in isotopic distributions of waste streams between sampling periods. The estimated total error of the reported batch gaseous releases is within 10%.

Error estimates for continuous releases where sample activity is below the detectable concentration levels are not included since error estimates at the LLD are not defined.

The estimated total error of reported liquid releases is within 25%.

5.0 Batch Releases

Batch releases of gaseous and liquid effluent are provided in Tables 4A-1 and 4B-1 for Unit 1 and 4A-2 and 4B-2 for Unit 2.

6.0 Unplanned Releases

During this reporting period two unplanned releases were identified and quantified as batch gaseous releases.

Part B. Gaseous Effluents

See Summary Tables 1A-1 thru 1C-1 representative of Salem Unit 1 operations.

See Summary Tables 1A-2 thru 1C-2 representative of Salem Unit 2 operations.

Part C. Liquid Effluents

See Summary Tables 2A-1 and 2B-1 representative of Salem Unit 1 operations.

See Summary Tables 2A-2 and 2B-2 representative of Salem Unit 2 operations.

Part D. Solid Waste

See Summary Table 3 Units 1 and 2

Part E. Radiological Impact on Man

The calculated individual doses in this section are based on actual locations of nearby residents and farms. The population dose impact is based on historical site specific data i.e., food production, milk production, feed for milch animals and seafood production.

The doses were calculated using methods described in Regulatory Guide 1.109 and represent calculations for the six month reporting interval. Doses from batch and continuous releases were calculated using the meteorological dispersion coefficient X/Q for the six month reporting interval.

Liquid Pathways

Doses to individuals in the population from liquid releases are primarily from the seafood ingestion pathway. The total body dose to an individual was calculated to be $7.26E-03$ mrem. The calculated population total body dose was $1.56E-1$ person-rem. The highest organ dose from liquid releases was $5.73E-02$ mrem to the gastrointestinal tract.

Air Pathways

The resulting whole body and skin doses to an individual were calculated to be $4.27E-03$ mrem and $5.32E-03$ mrem respectively. The calculated population total body dose was $8.85E-01$ person-rem. The average total body dose to the population within fifty miles of the site was $1.65E-04$ mrem/person.

Direct Radiation

Direct radiation may be estimated by TLD measurements. One method for comparing TLD measurements is by comparison with preoperational data. TLD measurements on site near the Service Water pumps (location 11S1) and near the Circulating Water pumps (location 10S1) averaged 9.05 and 6.48 mrad/months, respectively, apparently due to trace activity in the Refueling Water Storage Tank.

TLD's at onsite locations 2S2 and 5S1 which are 0.3 miles and 0.9 miles from the reactor containment, averaged 4.23 and 4.59 mrad/month respectively. The values for stations 2S1 and 5S1 are within the statistical variation associated with the preoperation program results.

All offsite monitoring locations remained within preoperational ranges. It should be noted that the nearest resident is 3.5 miles away. It can thus be concluded that there was no measurable dose to any offsite locations from direct radiation.

Part F. Meteorological Data

Cumulative joint wind frequency distribution by atmospheric stability class at the 300 foot elevation is provided for the third and fourth quarters of 1982 as Table 5 and 6.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES
 UNIT 1

	Units	3rd Quarter	4th Quarter	Est.Total(1) Error %
A. Fission & Activation Gases				
1. Total release	Ci	6.91E+01	1.64E+02	2.50E+01
2. Average release rate for period	uCi/sec.	8.69E+00	2.01E+01	
3. Percent of technical specification limit (See ETS Spec. 2.3.3.b)	%	1.44E-02	3.64E-02	
B. Iodines				
1. Total iodine-131	Ci	4.25E-03	1.87E-03	2.50E+01
2. Average release rate for period	uCi/sec.	5.35E-04	2.35E-04	
3. Percent of technical specification (2Ci) limit	%	2.13E-01	4.35E-02	
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	1.87E-04	2.23E-06	2.50E+01
2. Average release rate for period	uCi/sec.	2.36E-05	2.81E-07	
3. Percent of technical specification limit	%	4.60E-03	5.48E-05	
4. Gross alpha radioactivity (2)	Ci	0.00E+00	0.00E+00	
D. Tritium				
1. Total release	Ci	2.96E-01	3.27E+02	2.50E+01
2. Average release rate for period	uCi/sec.	3.72E-02	4.11E+01	
3. Percent of technical specification limit	%	N/A	N/A	

(1) For batch releases the estimated overall error is within 10%.

(2) Analyses indicate no measurable alpha emitting transuranics.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES
 UNIT

	Units	3rd Quarter	4th Quarter	Est.Total(1) Error %
A. Fission & Activation Gases				
1. Total release	Ci	1.00E+03	6.85E-01	2.50E+01
2. Average release rate for period	uCi/sec.	1.26E+02	7.61E-02	
3. Percent of technical specification limit (See ETS Spec. 2.3.3.b)	%	2.15E-02	1.35E-04	
B. Iodines				
1. Total iodine-131	Ci	1.74E-03	7.00E-04	2.50E+01
2. Average release rate for period	uCi/sec.	2.19E-04	8.81E-05	
3. Percent of technical specification limit	%			
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	<LLD	<LLD	2.50E+01
2. Average release rate for period	uCi/sec.	-	-	
3. Percent of technical specification limit	%	-	-	
4. Gross alpha radioactivity	Ci	0.00E+00	0.00E+00	
D. Tritium				
1. Total release	Ci			
2. Average release rate for period	uCi/sec.			
3. Percent of technical specification limit	%			

(1) For batch releases the estimated overall error is within 10%.

TABLE 1B-1
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-ELEVATED RELEASES
 UNIT 1
 CONTINUOUS MODE

BATCH MODE

Nuclides Released	Units	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
1. Fission gases					
Krypton-85	Ci	1.62E-03		1.04E-01	3.07E-01
Krypton-85m	Ci				4.15E-01
Krypton-87	Ci	7.64E-06			
Krypton-88	Ci	6.12E-03		6.03E-04	2.34E-01
Xenon-133	Ci	2.41E-01	1.83E-04	6.73E+01	1.55E+02
Xenon-135	Ci	1.17E-01		1.11E+00	
Xenon-135m	Ci	1.46E-02			7.64E+00
Xenon-138	Ci				
Xenon-133m	Ci	2.28E-04		5.53E-01	1.64E+00
Argon-41	Ci				2.58E-02
Fluorine-18	Ci	4.20E-06		4.70E-05	
Xe-131m	Ci				
Total for period	Ci	3.81E-01	1.83E-04	6.91E+01	1.64E+02
2. Iodines					
Iodine-131	Ci	1.41E-03	1.30E-03		
Iodine-133	Ci	2.84E-03	5.70E-04		
Iodine-135	Ci				
Total for period	Ci	4.25E-03	1.87E-03		

TABLE 1B-1
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-ELIMINATED RELEASES
 (Continued)
 UNIT 1

CONTINUOUS MODE

BATCH MODE

Nuclides Released	Units	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
3. Particulates (Half life > 8 days)					
Chromium-51	Ci				
Manganese-54	Ci				
Cobalt-58	Ci				
Cobalt-60	Ci				
Iron-59	Ci				2.23E-06
Yttrium-88	Ci			1.84E-04	
Strontium-89	Ci				
Strontium-90	Ci				
Niobium-95	Ci				
Zirconium-95	Ci				
Tin-117m	Ci				
Cesium-137	Ci	2.70E-06			
Cerium-139	Ci				
Gross Alpha	Ci				
Total For Period	Ci	2.70E-06	<LLD	1.84E-04	2.23E-06
4. Tritium					
Tritium	Ci	<LLD	<LLD	2.96E-01	3.27E+02

TABLE 1B-2
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-ELEVATED RELEASES
 UNIT 2

Nuclides Released	Units	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
1. Fission gases					
Krypton-85	Ci			2.18E-01	3.96E-02
Krypton-85m	Ci				
Krypton-87	Ci				
Krypton-88	Ci				
Xenon-133	Ci	1.00E+03	1.85E-04	2.54E+00	5.64E-01
Xenon-135	Ci	3.97E-02	8.87E-04	1.70E-03	
Xenon-135m	Ci				
Xenon-138	Ci				
Xenon-133m	Ci	6.24E-05		1.13E-02	
Argon-41	Ci				
Fluorine-18	Ci				
Xenon - 131m	Ci				
Total for period	Ci	1.00E+03	1.07E-03	2.77E+00	6.04E-01
2. Iodines					
Iodine-131	Ci	1.35E-03	5.97E-04		
Iodine-133	Ci	3.94E-04	1.03E-04		
Iodine-135	Ci				
Total for period	Ci	1.74E-03	7.00E-04		

TABLE 1B-2
 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1982)
 GASEOUS EFFLUENTS-ELAPSED RELEASES
 (Continued)
 UNIT 2

Nuclides Released	Units	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
3. Particulates (Half life > 8 days)					
Chromium-51	Ci				
Manganese-54	Ci				
Cobalt-58	Ci				
Cobalt-60	Ci				
Iron-59	Ci				
Yttrium-88	Ci				
Strontium-89	Ci				
Strontium-90	Ci				
Niobium-95	Ci				
Zirconium-95	Ci				
Sr-85	Ci				
Cesium-134	Ci				
Cesium-137	Ci				
Cerium-139	Ci				
Gross Alpha	Ci				
Total For Period	Ci	<LLD	<LLD		
4. Tritium					
Tritium	Ci	<LLD	1.92E+00		

TABLE 1C

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1982

UNITS 1 AND 2

GASEOUS EFFLUENTS-GROUND-LEVEL RELEASES

Nuclides Released	Unit	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
-------------------	------	-------------	-------------	-------------	-------------

There were no ground level releases for the period of record.

TABLE 2A-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)

UNIT 1

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

		3rd Units Quarter	4th Quarter	Est. Total Error, %
A. Fission and activation products				
1. Total release (not including tritium, gases, alpha)	Ci	3.54E-01	1.18E+00	2.50E+01
2. Average diluted concentration during period	uCi/ml	1.01E-07	3.13E-07	
3. Percent of applicable limits of Technical Specifications	%	3.54E+00	1.18E+01	
B. Tritium				
1. Total release	Ci	3.70E+02	1.43E+02	2.50E+01
2. Average diluted concentration during period	uCi/ml	1.05E-04	3.79E-05	
3. Percent of applicable limit	%	N/A	N/A	
C. Dissolved and entrained gases				
1. Total release	Ci	1.29E+00	1.92E-01	2.50E+01
2. Average diluted concentration during period	uCi/ml	3.68E-07	5.09E-08	
3. Percent of applicable limit	%	N/A	N/A	
D. Gross alpha radioactivity				
1. Total release	Ci	0.00E+00	0.00E+00	2.50E+01
E. Volume of waste release (prior to dilution - Batch Release)				
	liters	5.09E+06	5.03E+06	
F. Volume of dilution water used during period - Batch Release				
	liters	3.51E+09	3.77E+09	2.50E+01

A - Not Applicable

TABLE 2A-2

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)

UNIT 2

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	Units	3rd Quarter	4th Quarter	Est. Total Error, %
A. Fission and activation products				
1. Total release (not including tritium, gases, alpha)	Ci	3.34E-01	1.13E+00	2.50E+01
2. Average diluted concentration during period	uCi/ml	2.98E-08	8.07E-08	
3. Percent of applicable limits of Technical Specifications	%	3.34E+00	1.13E+01	
B. Tritium				
1. Total release	Ci	2.33E+02	5.97E+01	2.50E+01
2. Average diluted concentration during period	uCi/ml	2.08E-05	4.26E-06	
3. Percent of applicable limit	%	N/A	N/A	
C. Dissolved and entrained gases				
1. Total release	Ci	1.38E+00	1.36E+00	2.50E+01
2. Average diluted concentration during period	uCi/ml	1.23E-07	9.71E-08	
3. Percent of applicable limit	%	N/A	N/A	
D. Gross alpha radioactivity				
1. Total release	Ci	0.00	0.00	2.50E+01
E. Volume of waste release (prior to dilution - Batch Release)				
	liters	4.31E+06	5.54E+06	
F. Volume of dilution water used during period - Batch Release				
	liters	1.12E+10	1.40E+10	2.50E+01

N/A - Not Applicable

TABLE 2B-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)

LIQUID EFFLUENTS UNIT 1

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci			1.83E-02	7.66E-03
Cesium-137	Ci			2.78E-02	9.64E-03
Iodine-131	Ci			2.45E-02	2.41E-03
Iodine-132	Ci				4.25E-04
Iodine-133	Ci			5.10E-03	6.13E-05
Iodine-134	Ci				
Cobalt-57	Ci			7.01E-05	2.18E-04
Cobalt-58	Ci			8.02E-02	6.55E-01
Cobalt-60	Ci			1.61E-01	3.32E-01
Ruthenium-103	Ci				7.11E-04
Manganese-54	Ci			3.41E-02	4.55E-02
Radium-226	Ci				7.76E-02
Plutonium-239	Ci				2.20E-04
Zirconium-95	Ci				3.04E-03
Molybdenum-99	Ci			4.03E-05	9.98E-04
Barium-140	Ci				
Lanthanum-140	Ci			3.66E-04	6.88E-03
Cerium-139	Ci				
Tellurium-132	Ci				6.52E-04
Niobium-97	Ci				9.51E-03
Niobium-95	Ci			7.40E-04	1.03E-02
Antimony-124	Ci				5.12E-04
Antimony-125	Ci			4.48E-04	3.19E-03
Tritium	Ci			3.70E+02	1.43E+02
Iron-59	Ci				6.13E-03
Sodium-24	Ci			7.85E-04	
Silver-110m	Ci			4.15E-04	3.46E-03
Total for period (above)					
excluding H3	Ci			3.54E-01	1.18E+00
Xenon-133m	Ci			7.86E-03	
Xenon-133	Ci			1.25E+00	1.89E-01
Xenon-135	Ci			3.16E-02	2.88E-03
Krypton-85m	Ci			6.55E-05	
Argon-41	Ci				

TABLE 2B-2

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1982)

LIQUID EFFLUENTS UNIT 2

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci			2.19E-02	1.22E-02
Cesium-137	Ci			3.10E-02	1.71E-02
Iodine-131	Ci			1.88E-02	6.70E-03
Iodine-132	Ci				
Iodine-133	Ci			4.74E-03	8.52E-04
Cobalt-58	Ci			8.76E-02	6.24E-01
Cobalt-60	Ci			1.34E-01	3.31E-01
Cadmium-109	Ci				
Manganese-54	Ci			3.15E-02	4.30E-02
Chromium-51	Ci			4.95E-04	5.72E-02
Molybdenum-99	Ci			4.32E-05	1.30E-04
Zirconium-95	Ci			1.85E-04	3.62E-03
-113	Ci				8.18E-05
ium-140	Ci				
Lanthanum-140	Ci			7.79E-04	5.95E-03
Cesium-136	Ci			5.76E-04	
Niobium-97	Ci				1.08E-02
Niobium-95	Ci			6.72E-04	7.95E-03
Antimony-124	Ci				7.13E-04
Antimony-125	Ci			9.62E-04	2.56E-03
Tritium	Ci			2.33E+02	5.97E+01
Iron-59	Ci				4.52E-03
Sodium-24	Ci			3.37E-04	
Silver 110m	Ci				3.92E-03
Tellurium-132	Ci				
Total for period (above)					
excluding H3	Ci			3.34E-01	1.13E+00
Xenon-133m	Ci			7.35E-03	1.13E+00
Xenon-133	Ci			1.35E+00	2.25E-01
Xenon-135	Ci			2.60E-02	4.45E-03
Krypton-85m	Ci				8.05E-05
Argon-41	Ci				

TABLE 3

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1982
 JULY - DECEMBER 1982
 UNITS 1 AND 2
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1. Type of waste	Units	6-month Period	Est. Total Error, %
a. Spent resins, filters sludges, evaporator bottoms	m3 Ci	1.75E+02 1.05E+02	1.50E+01
b. Dry compressible waste, contaminated equip.	m3 Ci	7.63E+02 3.58E+00	1.50E+01
c. Irradiated components, control rods,	m3 Ci	0.00E+00 0.00E+00	
d. Others (describe)	m3 Ci	0.00E+00 0.00E+00	

Estimate of major nuclide composition (by type of waste)

a.	Cobalt - 58	79.9%	8.4E+01
	Cobalt - 60	12.4%	1.3E+01
	Manganese - 54	3.0%	3.2E+00
	Cesium - 134	2.5%	2.6E+00
	Cesium - 137	2.2%	2.3E+00
b.	Cobalt - 58	79.9%	2.90E+00
	Cobalt - 60	12.4%	0.44E+00
	Manganese - 54	3.0%	0.11E+00
	Cesium - 134	2.5%	0.09E+00
	Cesium - 137	2.2%	0.08E+00

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
37	Truck	Barnwell, South Carolina
13	Truck	Hanford, Wash.

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

TABLE 4A-1

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - September 30, 1982
2. Type of release (Gas)
3. Number of releases during the 3rd Quarter 1.5E+01
4. Total time duration for all releases of type listed above
5.74E+03
minutes
5. Maximum duration for releases of type listed above 1.56E+03
minutes
6. Average duration for all releases of type listed above
3.82E+02
minutes
7. Minimum duration for release of type listed above 6.00E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4A-2

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - September 30, 1982
2. Type of release (Gas)
3. Number of releases during the 3rd Quarter 9.00E+0
4. Total time duration for all releases of type listed above
1.42E+03
minutes
5. Maximum duration for releases of type listed above 3.10E+02
minutes
6. Average duration for all releases of type listed above
1.58E+02
minutes
7. Minimum duration for release of type listed above 1.12E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4A-1 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - December 31, 1982
2. Type of release (Gas)
3. Number of releases during the 4th Quarter 1.5E+01
4. Total time duration for all releases of type listed above
3.92E+03
minutes
5. Maximum duration for releases of type listed above 1.13E+03
minutes
6. Average duration for all releases of type listed above
2.61E+02
minutes
7. Minimum duration for release of type listed above 6.50E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4A-2 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - December 31, 1982
2. Type of release (Gas)
3. Number of releases during the 4th Quarter 5.0E+00
4. Total time duration for all releases of type listed above
5.30E+02
minutes
5. Maximum duration for releases of type listed above 1.10E+02
minutes
6. Average duration for all releases of type listed above
1.06E+02
minutes
7. Minimum duration for release of type listed above 1.02E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4B-1

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - September 30, 1982
2. Type of release (Liquid)
3. Number of releases during the 3rd Quarter 7.90+01
4. Total time duration for all releases of type listed above
1.63E+04
minutes
5. Maximum duration for releases of type listed above 4.33E+02
minutes
6. Average duration for all releases of type listed above
2.07E+02
minutes
7. Minimum duration for release of type listed above 1.65E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. 2.15E+05
gpm

TABLE 4B-2

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - September 30, 1982
2. Type of release (Liquid)
3. Number of releases during the 3rd Quarter 6.80+01
4. Total time duration for all releases of type listed above
1.37E+04
minutes
5. Maximum duration for releases of type listed above 3.44E+02
minutes
6. Average duration for all releases of type listed above
2.02E+02
minutes
7. Minimum duration for release of type listed above 1.65E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. 2.15E+05
gpm

TABLE 4B-1 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 1 -

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - December 31, 1982
2. Type of release (Liquid)
3. Number of releases during the 4th Quarter 7.90E+01
4. Total time duration for all releases of type listed above
1.63E+04
minutes
5. Maximum duration for releases of type listed above 8.18E+02
minutes
6. Average duration for all releases of type listed above
2.06E+02
minutes
7. Minimum duration for release of type listed above 1.36E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release 2.22E+05
gpm

TABLE 4B-2 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1982)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - December 31, 1982
2. Type of release (Liquid)
3. Number of releases during the 4th Quarter 8.6E+01
4. Total time duration for all releases of type listed above
1.78E+04
minutes
5. Maximum duration for releases of type listed above 4.23E+02
minutes
6. Average duration for all releases of type listed above
2.07E+02
minutes
7. Minimum duration for release of type listed above 1.65E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release 2.09E+05
gpm

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
LE-1.9 CLASS A

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-16		19-24		25 PLUS		SUM PERCENT	
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT
N	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
W	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
MEAN WIND SPEED	0.0													
CALM HOURS	0													
PERCENT CALM	0.0													
MISSING	0													

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.6/ -1.7 CLASS B

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	0	0.0	0	0.0	1	.0	0	0.0	1	.0
SSE	0	0.0	0	0.0	2	.1	0	0.0	0	0.0	0	0.0	2	.1
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	1	.0	0	0.0	0	0.0	0	0.0	1	.0
SW	0	0.0	2	.1	1	.0	0	0.0	0	0.0	0	0.0	3	.1
WSW	0	0.0	0	0.0	1	.0	0	0.0	0	0.0	0	0.0	1	.0
W	0	0.0	0	0.0	0	0.0	3	.1	0	0.0	0	0.0	3	.1
WNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
	0	0.0	2	.1	5	.2	3	.1	1	.0	0	0.0	11	.5

MEAN WIND SPEED 12.1
CALM HOURS 0
PERCENT CALM 0.0
MISSING 0

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.6/ -1.5 CLASS C

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM PERCENT	
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT
N	0	0.0	0	0.0	0	0.0	1	.0	0	0.0	0	0.0	1	.0
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	3	.1	1	.0	4	.2	0	0.0	8	.4
SSE	0	0.0	0	0.0	4	.2	2	.1	0	0.0	0	0.0	6	.3
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	2	.1	1	.0	0	0.0	0	0.0	0	0.0	3	.1
SW	0	0.0	2	.1	0	0.0	0	0.0	1	.0	0	0.0	3	.1
WSW	0	0.0	1	.0	3	.1	1	.0	0	0.0	0	0.0	5	.2
W	0	0.0	0	0.0	0	0.0	1	.0	2	.1	0	0.0	3	.1
WNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNW	0	0.0	0	0.0	0	0.0	1	.0	0	0.0	0	0.0	1	.0
	0	0.0	5	.2	11	.5	7	.3	7	.3	0	0.0	30	1.5

MEAN WIND SPEED 12.9
CALM HOURS 0
PERCENT CALM 0.0
MISSING 0

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.4/ -0.5 CLASS D

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	1	.0	11	.5	28	1.4	20	1.0	5	.2	0	0.0	65	3.2
NNE	0	0.0	9	.4	21	1.0	19	.9	1	.0	0	0.0	50	2.5
NE	2	.1	4	.2	13	.6	18	.9	0	0.0	0	0.0	37	1.8
ENE	2	.1	6	.3	7	.3	5	.2	0	0.0	0	0.0	20	1.0
E	0	0.0	7	.3	3	.1	0	0.0	0	0.0	0	0.0	10	.5
ESE	0	0.0	0	0.0	0	0.0	2	.1	0	0.0	0	0.0	2	.1
SE	0	0.0	6	.3	4	.2	37	1.8	18	.9	2	.1	67	3.3
SSE	5	.2	21	1.0	16	.8	47	2.3	12	.6	0	0.0	101	5.0
S	3	.1	21	1.0	13	.6	26	1.3	9	.4	2	.1	74	3.7
SSW	1	.0	17	.8	21	1.0	22	1.1	8	.4	0	0.0	69	3.4
SW	0	0.0	30	1.5	30	1.5	25	1.2	5	.2	0	0.0	90	4.5
WSW	0	0.0	15	.7	22	1.1	10	.5	5	.2	0	0.0	52	2.6
W	2	.1	6	.3	22	1.1	22	1.1	9	.4	2	.1	63	3.1
WNW	0	0.0	3	.1	20	1.0	10	.5	0	0.0	2	.1	35	1.7
NW	1	.0	13	.6	13	.6	16	.8	0	0.0	1	.0	44	2.2
NNW	0	0.0	8	.4	31	1.5	12	.6	0	0.0	0	0.0	51	2.5
	17	.8	177	8.8	264	13.2	291	14.5	72	3.6	9	.4	830	41.4

MEAN WIND SPEED 11.8
CALM HOURS 0
PERCENT CALM 0.0
MISSING 63

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-300FT)

LAPSE RATE
=0.4/ 1.5 CLASS E

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	4	.2	11	.5	13	.6	20	1.0	20	1.0	8	.4	76	3.8
NNE	6	.3	5	.2	20	1.0	27	1.3	1	.0	0	0.0	59	2.9
NE	0	0.0	10	.5	23	1.1	27	1.3	9	.4	0	0.0	69	3.4
ENE	2	.1	5	.2	13	.6	6	.3	6	.3	0	0.0	32	1.6
E	2	.1	15	.7	16	.8	4	.2	0	0.0	2	.1	39	1.9
ESE	2	.1	4	.2	4	.2	4	.2	0	0.0	2	.1	16	.8
SE	1	.0	7	.3	21	1.0	9	.4	6	.3	2	.1	46	2.3
SSE	9	.4	10	.5	29	1.4	23	1.1	4	.2	2	.1	77	3.8
S	4	.2	11	.5	29	1.4	28	1.4	18	.9	1	.0	91	4.5
SSW	0	0.0	9	.4	23	1.1	63	3.1	27	1.3	0	0.0	122	6.1
SW	1	.0	14	.7	33	1.6	37	1.8	16	.8	0	0.0	101	5.0
WSW	2	.1	13	.6	8	.4	24	1.2	1	.0	0	0.0	48	2.4
W	2	.1	14	.7	23	1.1	18	.9	7	.3	0	0.0	64	3.2
WNW	1	.0	8	.4	20	1.0	10	.5	0	0.0	0	0.0	39	1.9
NW	2	.1	7	.3	24	1.2	23	1.1	9	.4	3	.1	68	3.4
NNW	1	.0	11	.5	15	.7	17	.8	3	.1	3	.1	50	2.5
	39	1.9	154	7.7	314	15.7	340	17.0	127	6.3	23	1.1	997	49.8

MEAN WIND SPEED 12.7
CALM HOURS 1
PERCENT CALM .0
MISSING 38

TABLE 5

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
1.6 / 4.0 CLASS F

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	1	.0	10	.5	9	.4	1	.0	0	0.0	21	1.0
NNE	0	0.0	0	0.0	2	.1	15	.7	3	.1	0	0.0	20	1.0
NE	0	0.0	1	.0	3	.1	4	.2	1	.0	0	0.0	9	.4
ENE	0	0.0	3	.1	2	.1	2	.1	1	.0	0	0.0	8	.4
E	0	0.0	2	.1	0	0.0	0	0.0	0	0.0	0	0.0	2	.1
ESE	2	.1	0	0.0	0	0.0	1	.0	0	0.0	0	0.0	3	.1
SE	0	0.0	1	.0	4	.2	0	0.0	0	0.0	0	0.0	5	.2
SSE	1	.0	4	.2	5	.2	3	.1	0	0.0	0	0.0	13	.6
S	0	0.0	1	.0	1	.0	1	.0	0	0.0	0	0.0	3	.1
SSW	1	.0	0	0.0	1	.0	0	0.0	2	.1	2	.1	6	.3
SW	0	0.0	1	.0	0	0.0	0	0.0	1	.0	0	0.0	2	.1
WSW	1	.0	0	0.0	0	0.0	3	.1	0	0.0	0	0.0	4	.2
W	2	.1	1	.0	2	.1	4	.2	1	.0	0	0.0	10	.5
WNW	0	0.0	0	0.0	5	.2	0	0.0	0	0.0	0	0.0	5	.2
NW	0	0.0	0	0.0	2	.1	0	0.0	2	.1	0	0.0	4	.2
NNW	0	0.0	2	.1	4	.2	8	.4	4	.2	1	.0	19	.9
	7	.3	17	.8	41	2.0	50	2.5	16	.8	3	.1	134	6.7

MEAN WIND SPEED 12.8
CALM HOURS 0
PERCENT CALM 0.0
MISSING 2

TABLE 5.

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
GT. 4.0 CLASS G

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
W	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

MEAN WIND SPEED 0.0
CALM HOURS 0
PERCENT CALM 0.0
MISSING 0

ARTIFICIAL ISLAND 7/82-9/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300=30FT)

LAPSE RATE
ALL STABILITIES

DIRECTION	SPEEDS(MI/HR)												SUM	PERCENT
	1-3	4-7		8-12		13-18		19-24		25 PLUS				
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	5	.2	23	1.1	51	2.5	50	2.5	26	1.3	8	.4	163	8.1
NNE	6	.3	14	.7	43	2.1	61	3.0	5	.2	0	0.0	129	6.4
NE	2	.1	15	.7	39	1.9	49	2.4	10	.5	0	0.0	115	5.7
ENE	4	.2	14	.7	22	1.1	13	.6	7	.3	0	0.0	60	3.0
E	2	.1	24	1.2	19	.9	4	.2	0	0.0	2	.1	51	2.5
ESE	4	.2	4	.2	4	.2	7	.3	0	0.0	2	.1	21	1.0
SE	1	.0	14	.7	32	1.6	47	2.3	29	1.4	4	.2	127	6.3
SSE	15	.7	35	1.7	56	2.8	75	3.7	16	.8	2	.1	199	9.9
S	7	.3	33	1.6	43	2.1	55	2.7	27	1.3	3	.1	168	8.4
SSW	2	.1	28	1.4	47	2.3	85	4.2	37	1.8	2	.1	201	10.0
SW	1	.0	49	2.4	64	3.2	62	3.1	23	1.1	0	0.0	199	9.9
WSW	3	.1	29	1.4	34	1.7	38	1.9	6	.3	0	0.0	110	5.5
W	6	.3	21	1.0	47	2.3	48	2.4	19	.9	2	.1	143	7.1
WNW	1	.0	11	.5	45	2.2	20	1.0	0	0.0	2	.1	79	3.9
NW	3	.1	20	1.0	39	1.9	39	1.9	11	.5	4	.2	116	5.8
NNW	1	.0	21	1.0	50	2.5	38	1.9	7	.3	4	.2	121	6.0
	63	3.1	355	17.7	635	31.7	691	34.5	223	11.1	35	1.7	2002	100.0

MISSING HOURS 205

MEAN WIND SPEED 12.3

TOTAL NUMBER OF CALM HOURS 1 PERCENT .0

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
LE=1.9 CLASS A

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
W	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WNW	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
NW	0	0.0	0	0.0	1	.1	2	.1	0	0.0	0	0.0	3	.2
NNW	0	0.0	0	0.0	0	0.0	0	0.0	2	.1	0	0.0	2	.1
	0	0.0	0	0.0	2	.1	2	.1	2	.1	0	0.0	6	.3

MEAN WIND SPEED 15.2
CALM HOURS 0
PERCENT CALM 0.0
MISSING 0

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.6/ -1.7 CLASS 8

DIRECTION	SPEEDS(MI/HR)												SUM	PERCENT
	1-3		4-7		8-12		13-18		19-24		25 PLUS			
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	0	0.0	0	0.0	2	.1	0	0.0	0	0.0	2	.1
NNE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	0	0.0	1	.1
SE	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
SSE	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WSW	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
W	0	0.0	2	.1	0	0.0	0	0.0	0	0.0	0	0.0	2	.1
WNW	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
NW	0	0.0	0	0.0	0	0.0	2	.1	1	.1	0	0.0	3	.2
NNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
	0	0.0	3	.2	4	.2	4	.2	1	.1	0	0.0	12	.7

MEAN WIND SPEED 11.8
CALM HOURS 0
PERCENT CALM 0.0
MISSING 0

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.6/ -1.5 CLASS C

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	0	0.0	1	.1	2	.1	0	0.0	0	0.0	3	.2
NNE	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	0	0.0	1	.1
NE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ENE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
E	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
ESE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SE	0	0.0	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	1	.1
SSE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
S	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SW	0	0.0	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	1	.1
WSW	0	0.0	0	0.0	1	.1	0	0.0	2	.1	1	.1	4	.2
W	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	0	0.0	1	.1
WNW	0	0.0	0	0.0	0	0.0	2	.1	0	0.0	0	0.0	2	.1
NW	0	0.0	0	0.0	0	0.0	1	.1	3	.2	0	0.0	4	.2
NNW	0	0.0	0	0.0	0	0.0	3	.2	0	0.0	0	0.0	3	.2
	0	0.0	2	.1	2	.1	10	.6	5	.3	1	.1	20	1.1

MEAN WIND SPEED 15.8
CALM HOURS 0
PERCENT CALM 0.0
MISSING 1

TABLE 6

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
-1.4/ -0.5 CLASS D

DIRECTION	SPEEDS(MI/HR)														SUM PERCENT
	1-3		4-7		8-12		13-18		19-24		25 PLUS		SUM	PERCENT	
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT			
N	0	0.0	3	.2	15	.8	22	1.2	9	.5	2	.1	51	2.9	
NNE	1	.1	4	.2	10	.6	6	.3	0	0.0	0	.0	23	1.2	
NE	1	.1	4	.2	12	.7	6	.3	0	0.0	0	0.0	23	1.3	
ENE	1	.1	1	.1	3	.2	1	.1	0	0.0	0	0.0	6	.3	
E	1	.1	4	.2	3	.2	0	0.0	0	0.0	0	0.0	8	.5	
ESE	1	.1	1	.1	0	0.0	0	0.0	0	0.0	0	0.0	2	.1	
SE	1	.1	3	.2	6	.3	7	.4	1	.1	0	0.0	18	1.0	
SSE	0	0.0	11	.6	9	.5	9	.5	4	.2	0	0.0	33	1.9	
S	4	.2	6	.3	12	.7	18	1.0	1	.1	0	0.0	41	2.3	
SSW	1	.1	7	.4	10	.6	3	.2	4	.2	0	0.0	25	1.4	
SW	0	0.0	4	.2	7	.4	4	.2	2	.1	0	0.0	17	1.0	
WSW	1	.1	4	.2	2	.1	5	.3	4	.2	0	0.0	16	.9	
W	0	0.0	4	.2	8	.5	8	.5	8	.5	0	0.0	28	1.6	
WNW	2	.1	6	.3	7	.4	9	.5	14	.8	8	.5	46	2.6	
NW	1	.1	4	.2	13	.7	5	.3	8	.5	10	.6	41	2.3	
NNW	1	.1	7	.4	5	.3	8	.5	14	.8	4	.2	39	2.2	
	16	.9	73	4.1	122	6.9	111	6.3	69	3.9	25	1.4	416	23.4	

MEAN WIND SPEED 13.5
CALM HOURS 0
PERCENT CALM 0.0
MISSING 77

TABLE 6

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
=0.4/ 1.5 CLASS E

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	3	.2	15	.8	14	.8	17	1.0	28	1.6	14	.8	91	5.1
NNE	1	.1	1	.1	8	.5	23	1.3	1	.1	11	.6	45	2.5
NE	4	.2	7	.4	10	.6	21	1.2	16	.9	4	.2	62	3.5
ENE	4	.2	15	.8	19	1.1	9	.5	1	.1	0	0.0	48	2.7
E	7	.4	12	.7	9	.5	4	.2	0	0.0	0	0.0	32	1.8
ESE	0	0.0	6	.3	3	.2	2	.1	0	0.0	0	0.0	11	.6
SE	1	.1	12	.7	6	.3	10	.6	1	.1	0	0.0	30	1.7
SSE	0	0.0	8	.5	18	1.0	18	1.0	9	.5	7	.4	60	3.4
S	1	.1	12	.7	22	1.2	37	2.1	21	1.2	11	.6	104	5.9
SSW	0	0.0	7	.4	28	1.6	43	2.4	20	1.1	8	.5	106	6.0
SW	1	.1	8	.5	27	1.5	46	2.6	5	.3	2	.1	89	5.0
WSW	1	.1	5	.3	15	.8	7	.4	3	.2	0	0.0	31	1.7
W	2	.1	2	.1	13	.7	36	2.0	4	.2	1	.1	58	3.3
WNW	4	.2	5	.3	7	.4	40	2.3	35	2.0	3	.2	94	5.3
NW	1	.1	5	.3	16	.9	28	1.6	21	1.2	15	.8	86	4.8
NNW	1	.1	3	.2	15	.8	25	1.4	1	.1	2	.1	47	2.6
	31	1.7	123	6.9	230	13.0	366	20.6	166	9.4	78	4.4	994	56.0

MEAN WIND SPEED 14.7
CALM HOURS 2
PERCENT CALM .1
MISSING 235

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
1.6 / 4.0 CLASS F

DIRECTION	SPEEDS(MI/HR)												SUM	PERCENT
	1-3		4-7		8-12		13-18		19-24		25 PLUS			
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	2	.1	4	.2	9	.5	2	.1	1	.1	18	1.0
NNE	0	0.0	0	0.0	5	.3	14	.8	2	.1	0	0.0	21	1.2
NE	2	.1	1	.1	0	0.0	2	.1	1	.1	0	0.0	6	.3
ENE	2	.1	7	.4	6	.3	2	.1	2	.1	0	0.0	19	1.1
E	0	0.0	1	.1	4	.2	0	0.0	0	0.0	0	0.0	5	.3
ESE	0	0.0	1	.1	1	.1	0	0.0	0	0.0	0	0.0	2	.1
SE	0	0.0	5	.3	2	.1	4	.2	0	0.0	0	0.0	11	.6
SSE	1	.1	6	.3	7	.4	5	.3	3	.2	1	.1	23	1.3
S	2	.1	5	.3	12	.7	21	1.2	6	.3	0	0.0	46	2.6
SSW	0	0.0	3	.2	9	.5	18	1.0	17	1.0	6	.3	53	3.0
SW	1	.1	0	0.0	1	.1	12	.7	8	.5	11	.6	33	1.9
WSW	0	0.0	1	.1	4	.2	1	.1	1	.1	0	0.0	7	.4
W	0	0.0	0	0.0	2	.1	3	.2	1	.1	0	0.0	6	.3
WNW	0	0.0	3	.2	0	0.0	4	.2	0	0.0	0	0.0	7	.4
NW	0	0.0	1	.1	1	.1	3	.2	0	0.0	0	0.0	5	.3
NNW	0	0.0	1	.1	1	.1	3	.2	1	.1	0	0.0	6	.3
	8	.5	37	2.1	59	3.3	101	5.7	44	2.5	19	1.1	268	15.1

MEAN WIND SPEED 14.5
CALM HOURS 0
PERCENT CALM 0.0
MISSING 36

TABLE 6

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED.
LOCATION 300FTDEG C/100M
(300-30FT)LAPSE RATE
GT. 4.0 CLASS G

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM	PERCENT
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	0	0.0	2	.1	2	.1	0	0.0	0	0.0	0	0.0	4	.2
NNE	0	0.0	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	1	.1
NE	0	0.0	0	0.0	3	.2	3	.2	0	0.0	0	0.0	6	.3
ENE	0	0.0	0	0.0	0	0.0	1	.1	1	.1	0	0.0	2	.1
E	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
ESE	0	0.0	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	1	.1
SE	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
SSE	0	0.0	0	0.0	1	.1	0	0.0	1	.1	0	0.0	2	.1
S	0	0.0	0	0.0	5	.3	4	.2	3	.2	4	.2	16	.9
SSW	0	0.0	0	0.0	1	.1	12	.7	6	.3	0	0.0	19	1.1
SW	0	0.0	0	0.0	1	.1	1	.1	0	0.0	0	0.0	2	.1
WSW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
W	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
WNW	0	0.0	1	.1	0	0.0	0	0.0	0	0.0	0	0.0	1	.1
NW	0	0.0	1	.1	0	0.0	0	0.0	1	.1	0	0.0	2	.1
NNW	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
	0	0.0	4	.2	15	.8	22	1.2	12	.7	4	.2	57	3.2

MEAN WIND SPEED 15.5
 CALM HOURS 0
 PERCENT CALM 0.0
 MISSING 19

ARTIFICIAL ISLAND 10/82-12/82

JOINT DISTRIBUTION OF WIND DIRECTION AND SPEED
LOCATION 300FT

DEG C/100M
(300-30FT)

LAPSE RATE
ALL STABILITIES

DIRECTION	1-3		4-7		SPEEDS(MI/HR) 8-12		13-18		19-24		25 PLUS		SUM PERCENT	
	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT	SUM	PERCENT		
N	3	.2	22	1.2	36	2.0	52	2.9	39	2.2	17	1.0	169	9.5
NNE	2	.1	6	.3	23	1.3	44	2.5	3	.2	12	.7	90	5.1
NE	7	.4	12	.7	25	1.4	32	1.8	17	1.0	4	.2	97	5.5
ENE	7	.4	23	1.3	28	1.6	13	.7	4	.2	0	0.0	75	4.2
E	8	.5	17	1.0	17	1.0	4	.2	0	0.0	0	0.0	46	2.6
ESE	1	.1	9	.5	5	.3	2	.1	0	0.0	0	0.0	17	1.0
SE	2	.1	20	1.1	15	.8	22	1.2	2	.1	0	0.0	61	3.4
SSE	1	.1	25	1.4	36	2.0	32	1.8	17	1.0	8	.5	119	6.7
S	7	.4	23	1.3	51	2.9	80	4.5	31	1.7	15	.8	207	11.7
SSW	1	.1	17	1.0	48	2.7	76	4.3	47	2.6	14	.8	203	11.4
SW	2	.1	12	.7	36	2.0	64	3.6	15	.8	13	.7	142	8.0
WSW	2	.1	10	.6	23	1.3	13	.7	10	.6	1	.1	59	3.3
W	2	.1	9	.5	23	1.3	47	2.6	13	.7	1	.1	95	5.4
WNW	6	.3	15	.8	16	.9	55	3.1	49	2.8	11	.6	152	8.6
NW	2	.1	11	.6	31	1.7	41	2.3	34	1.9	25	1.4	144	8.1
NNW	2	.1	11	.6	21	1.2	39	2.2	18	1.0	6	.3	97	5.5

55 3.1 242 13.6 434 24.5 616 34.7 299 16.8 127 7.2 1773 99.9

MISSING HOURS 433

MEAN WIND SPEED 14.4

TOTAL NUMBER OF CALM HOURS 2 PERCENT .1

TABLE 6