

---

---

## REVISED RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

### APR1400 Design Certification

Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.: 357-8344  
SRP Section: 06.02.04 – Containment Isolation System  
Application Section: 6.2.4  
Date of RAI Issue: 01/05/2016

---

### **Question No. 06.02.04-11**

Describe inspections, tests, analyses and acceptance criteria (ITAAC) for verification of containment isolation valve (CIV) placement

10 CFR 52.47(b)(1) requires that a DC application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification.

DCD Tier 1, Table 2.11.3-2 "Containment Isolation System ITAAC", provides the ITAAC for the CIVs. How will this ITAAC, as written, ensure that the supplied as-built piping distances from the outer CIV to the containment will be such that the valves are located as close to containment as practical? (i.e. describe any inspections, tests, or acceptance criteria which will confirm that the as built piping distances will not exceed those listed in DCD Tier 2, Table 6.2.4-1).

In addition, indicate the associated containment penetration numbers in DCD Tier 1, Table 2.11.3-1 "Containment Isolation System Component List."

### **Response – (Rev. 3)**

GDCs 55, 56, and 57 require that isolation valves outside containment should be located as close to containment as practical. The APR1400 design has incorporated this design concept into the location of the containment isolation valves and has reflected the locations in the piping analyses performed. However, in applying the graded approach for piping design and analysis, only specific piping lines that penetrate containment are in the scope of the program and are required to be analyzed. Acceptable containment isolation valve location is assured through the overall design and piping analysis program. The length of pipe between containment and the outboard isolation valve indicated in DCD Tier 2, Table 6.2.4-1 does not necessarily represent a bounding condition for each piping line listed. However, in order to document this item during the design/construction phase, an ITAAC has been added to DCD Tier 1, Table 2.11.3-2 as

shown in Attachment . Additionally, the pipe length from an operational plant has been provided in DCD Tier 2, Revision 2, Table 6.2.4-1 as a reference and is subject to change during the detailed design phase.

The changes to the DCD made in the response to the RAI 306-8240 Question 06.02.06-9 and RAI 357-8344 Question 06.02.04-9 have been addressed in DCD Tier 2, Revision 1, Table 6.2.4-1. However, incorrect information in item nos. 48, 49, 50, 55, 161, 162, 163 in DCD Tier 2, Table 6.2.4-1 have been identified and corrected in DCD Tier 2, Revision 2.

Containment penetration numbers have been added in DCD Tier 1, Revision 1, Table 2.11.3-1 according to the response to the RAI 357-8344 Question 06.02.04-11, Revision 0. However, some incorrect information regarding valves FW-V132, IA-V0020, PS-V0032, PS-V0258, and WI-V0015 have been identified and corrected in DCD Tier 1, Revision 2. Finally, the missing valves VQ-V2014, VQ-V2016, and VQ-V2024 have been added in DCD Tier 1, Revision 2, Table 2.11.3-1.

---

### **Impact on DCD**

DCD Tier 1, Table 2.11.3-2 will be revised as shown in the attachment to this response.

- DCD Tier 1, Table 2.11.3-2 (Attachment )

### **Impact on PRA**

There is no impact on the PRA.

### **Impact on Technical Specifications**

There is no impact on the Technical Specifications.

### **Impact on Technical/Topical/Environmental Reports**

There is no impact on any Technical, Topical, or Environmental Report.

**APR1400 DCD TIER 1**

11. MOVs, AOVs, SOVs, E/H valves located inside and outside the containment in series on the same penetration are powered from different Class 1E divisions.

2.11.3.2 Inspections, Tests, Analyses, and Acceptance Criteria

The inspection, tests, analyses, and associated acceptance criteria for the CIAS are specified in Table 2.11.3-2.

12. Containment isolation valves outside the containment as listed in Table 2.11.3-1 and as shown in Figure 2.11.3-1, are located as close to the containment as practical, consistent with General Design Criteria 55, 56, and 57.

## APR1400 DCD TIER 1

Table 2.11.3-2 (6 of 6)

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria																																												
11. MOVs, AOVs, SOVs, E/H valves located inside and outside the containment in series on the same penetration are powered from different Class 1E divisions.	11. Inspection of the MOVs, AOVs, SOVs, E/H valves located inside and outside the containment in series on the same penetration will be performed.	11. The following MOVs, AOVs, SOVs, E/H valves located inside and outside the containment in series on the same penetration are powered from different Class 1E divisions. <table border="1" data-bbox="1024 573 1390 1499"> <thead> <tr> <th data-bbox="1024 573 1203 636">Inside containment</th> <th data-bbox="1203 573 1390 636">Outside containment</th> </tr> </thead> <tbody> <tr><td data-bbox="1024 636 1203 674">CC-V0249(MOV)</td><td data-bbox="1203 636 1390 674">CC-V0250(MOV)</td></tr> <tr><td data-bbox="1024 674 1203 711">CC-V0297(MOV)</td><td data-bbox="1203 674 1390 711">CC-V0296(MOV)</td></tr> <tr><td data-bbox="1024 711 1203 749">CC-V0301(MOV)</td><td data-bbox="1203 711 1390 749">CC-V0302(MOV)</td></tr> <tr><td data-bbox="1024 749 1203 787">CV-V506(AOV)</td><td data-bbox="1203 749 1390 787">CV-V505(AOV)</td></tr> <tr><td data-bbox="1024 787 1203 825">CV-V522(AOV)</td><td data-bbox="1203 787 1390 825">CV-V523(AOV)</td></tr> <tr><td data-bbox="1024 825 1203 863">CV-V560(AOV)</td><td data-bbox="1203 825 1390 863">CV-V561(AOV)</td></tr> <tr><td data-bbox="1024 863 1203 900">DE-V0005(MOV)</td><td data-bbox="1203 863 1390 900">DE-V0006(AOV)</td></tr> <tr><td data-bbox="1024 900 1203 938">GW-V0001(MOV)</td><td data-bbox="1203 900 1390 938">GW-V0002(SOV)</td></tr> <tr><td data-bbox="1024 938 1203 976">PR-V431(MOV)</td><td data-bbox="1203 938 1390 976">PR-V432(MOV)</td></tr> <tr><td data-bbox="1024 976 1203 1014">PX-V0001(SOV)</td><td data-bbox="1203 976 1390 1014">PX-V0002(SOV)</td></tr> <tr><td data-bbox="1024 1014 1203 1052">PX-V0003(SOV)</td><td data-bbox="1203 1014 1390 1052">PX-V0004(SOV)</td></tr> <tr><td data-bbox="1024 1052 1203 1089">PX-V0005(SOV)</td><td data-bbox="1203 1052 1390 1089">PX-V0006(SOV)</td></tr> <tr><td data-bbox="1024 1089 1203 1127">PX-V0021(SOV)</td><td data-bbox="1203 1089 1390 1127">PX-V0020(SOV)</td></tr> <tr><td data-bbox="1024 1127 1203 1165">PX-V0041(MOV)</td><td data-bbox="1203 1127 1390 1165">PX-V0042(MOV)</td></tr> <tr><td data-bbox="1024 1165 1203 1203">SI-V653(MOV)</td><td data-bbox="1203 1165 1390 1203">SI-V655(MOV)</td></tr> <tr><td data-bbox="1024 1203 1203 1241">SI-V654(MOV)</td><td data-bbox="1203 1203 1390 1241">SI-V656(MOV)</td></tr> <tr><td data-bbox="1024 1241 1203 1278">VQ-V0012(MOV)</td><td data-bbox="1203 1241 1390 1278">VQ-V0011(E/H)</td></tr> <tr><td data-bbox="1024 1278 1203 1316">VQ-V0013(MOV)</td><td data-bbox="1203 1278 1390 1316">VQ-V0014(E/H)</td></tr> <tr><td data-bbox="1024 1316 1203 1354">VQ-V0032(AOV)</td><td data-bbox="1203 1316 1390 1354">VQ-V0031(AOV)</td></tr> <tr><td data-bbox="1024 1354 1203 1392">VQ-V0033(AOV)</td><td data-bbox="1203 1354 1390 1392">VQ-V0034(AOV)</td></tr> <tr><td data-bbox="1024 1392 1203 1430">WI-V0015(MOV)</td><td data-bbox="1203 1392 1390 1430">WI-V0012(AOV)</td></tr> </tbody> </table>	Inside containment	Outside containment	CC-V0249(MOV)	CC-V0250(MOV)	CC-V0297(MOV)	CC-V0296(MOV)	CC-V0301(MOV)	CC-V0302(MOV)	CV-V506(AOV)	CV-V505(AOV)	CV-V522(AOV)	CV-V523(AOV)	CV-V560(AOV)	CV-V561(AOV)	DE-V0005(MOV)	DE-V0006(AOV)	GW-V0001(MOV)	GW-V0002(SOV)	PR-V431(MOV)	PR-V432(MOV)	PX-V0001(SOV)	PX-V0002(SOV)	PX-V0003(SOV)	PX-V0004(SOV)	PX-V0005(SOV)	PX-V0006(SOV)	PX-V0021(SOV)	PX-V0020(SOV)	PX-V0041(MOV)	PX-V0042(MOV)	SI-V653(MOV)	SI-V655(MOV)	SI-V654(MOV)	SI-V656(MOV)	VQ-V0012(MOV)	VQ-V0011(E/H)	VQ-V0013(MOV)	VQ-V0014(E/H)	VQ-V0032(AOV)	VQ-V0031(AOV)	VQ-V0033(AOV)	VQ-V0034(AOV)	WI-V0015(MOV)	WI-V0012(AOV)
Inside containment	Outside containment																																													
CC-V0249(MOV)	CC-V0250(MOV)																																													
CC-V0297(MOV)	CC-V0296(MOV)																																													
CC-V0301(MOV)	CC-V0302(MOV)																																													
CV-V506(AOV)	CV-V505(AOV)																																													
CV-V522(AOV)	CV-V523(AOV)																																													
CV-V560(AOV)	CV-V561(AOV)																																													
DE-V0005(MOV)	DE-V0006(AOV)																																													
GW-V0001(MOV)	GW-V0002(SOV)																																													
PR-V431(MOV)	PR-V432(MOV)																																													
PX-V0001(SOV)	PX-V0002(SOV)																																													
PX-V0003(SOV)	PX-V0004(SOV)																																													
PX-V0005(SOV)	PX-V0006(SOV)																																													
PX-V0021(SOV)	PX-V0020(SOV)																																													
PX-V0041(MOV)	PX-V0042(MOV)																																													
SI-V653(MOV)	SI-V655(MOV)																																													
SI-V654(MOV)	SI-V656(MOV)																																													
VQ-V0012(MOV)	VQ-V0011(E/H)																																													
VQ-V0013(MOV)	VQ-V0014(E/H)																																													
VQ-V0032(AOV)	VQ-V0031(AOV)																																													
VQ-V0033(AOV)	VQ-V0034(AOV)																																													
WI-V0015(MOV)	WI-V0012(AOV)																																													


 Insert No. 12

No. 12

A report exists and concludes that the

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
<p>12. Containment isolation valves outside the containment as listed in Table 2.11.3-1 and as shown in Figure 2.11.3-1, are located as close to the containment as practical, consistent with General Design Criteria 55, 56, and 57.</p>	<p>12. An inspection will be performed to verify the as-built location of outside containment isolation valves.</p> <p style="text-align: center;">↑ or analysis</p>	<p>12. The as-built outside containment isolation valves listed in Table 2.11.3-1 and shown in Figure 2.11.3-1 are located as close to the containment as practical with consideration of the following:</p> <ul style="list-style-type: none"> <li>• Access for inspection of welds</li> <li>• Containment leak testing</li> <li>• Replacement</li> <li>• Valve maintenance</li> </ul>