

JUL 5 1984

Docket Nos. 50-272
50-311

Public Service Electric and Gas Company
ATTN: Mr. R. Uderitz
Vice President - Nuclear
P. O. Box 236
Hancocks Bridge, New Jersey 08038

IE FILE COPY

Gentlemen:

Subject: Management Meeting Scheduled for July 19, 1984

This refers to the bimonthly meeting to be held in the Regional Office on July 19, 1984, to discuss your progress in completing the PSE&G Action Plan for Improving Nuclear Department Operations.

The format of this meeting will depart from that used in our previous bi-monthly meetings on the Action Plan. Specifically, over the past few months, we have observed a number of situations at the Salem Generating Station which recall the basic concerns at issue during the Spring 1983 restart deliberations. These concerns include attention to detail, safety perspective, accountability, inquisitiveness, and attitude.

Enclosed is a listing of recent inspection findings, categorized by general areas, which form the basis for our observations. At the meeting, you are requested to outline the features of your Action Plan which, in your view, will address and solve these concerns. The inspection findings are provided as indicators of perceived problems in the general areas listed. Discussions should focus on the general areas rather than the specific examples. Following these discussions, we also request a general update on each Action Plan item.

Should you have any questions concerning this meeting, we will be pleased to discuss them with you.

Sincerely,

Original Signed By:

Richard W. Starostecki, Director
Division of Project and Resident
Programs

Len

Enclosure: As Stated

8407100256 840705
PDR ADOCK 05000272
PDR
Q

OFFICIAL RECORD COPY

IEO1

1/1

JUL 5 1984


2

cc:


R. L. Mittl, General Manager - Nuclear Assurance and Regulation
J. M. Zupko, Jr., General Manager - Salem Operations
E. A. Liden, Manager - Nuclear Licensing and Regulation
C. P. Johnson, Manager - Quality Assurance Nuclear Operations
P. M. Krishna, Manager - Nuclear Review Board
M. J. Wetterhahn, Esquire
R. Fryling, Jr., Esquire
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Jersey
The Honorable Joseph R. Biden, Jr.
J. H. Rodriguez, Public Advocate of the State of New Jersey

bcc w/encls:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
DPRP Section Chief


RI-DPRP
Norrholm

6/28


DPRP
Kister

6/28


DPRP
Starostecki

6/29

OFFICIAL RECORD COPY

BIMONTHLY MANAGEMENT MEETING AGENDA ITEMS

Problem Areas and Examples (Numbers denote inspection reports)

Review of Changes to Procedures

RHR hot leg to hot leg recirculation (84-08)

Containment ventilation isolation (311/84-22)

Technical Specification Interpretation

Bit operability (84-15)

Containment ventilation isolation (311/84-22 and 83-36)

Corrective Action

MEL updates (84-15 & 84-16)

Loss of B vital bus (84-15)

Steam Generator Safety Valve Setpoints (84-04)

Control of Combustibles (84-13)

Responses to violations required update/supplement (311/83-15,
311/83-18, 272/83-27 and 311/83-30)

Vendor Recommendations for Post Maintenance Testing (84-03)

Review of Operating Activities

Post Trip Reviews (84-15)

Water Hammer (84-15)

Use of containment sump leakage estimates (83-36)

Mode changes with inadequate containment isolation (311/83-30)

Communications

Licensed Operator Responsibilities (84-04)

Equipment Classification per MEL (84-16)

Adherence to Emergency Instructions (311/83-30)

Reporting (83-33)

Document Control

Technical Specification Change Control (84-14)

SORC Review of Vendor Procedures (83-29)