



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

Ref: LCR-84-21

December 7, 1984

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief
Operations Reactors Branch 1
Division of Licensing

Gentlemen:

REQUEST FOR AMENDMENT
FACILITY OPERATING LICENSES
UNIT NOS. 1 AND 2
SALEM GENERATING STATION
DOCKET NOS. 50-272 AND 50-311

In accordance with the Atomic Energy Act of 1954, as amended and the regulations thereunder, we hereby transmit copies of our request for amendment and our analyses of the changes to Facility Operating Licenses DPR-70 and DPR-75 for Salem Generating Station, Unit Nos. 1 and 2.

This amendment request consists of a revision to Technical Specifications, Appendix A, Section 4.5.3.2, regarding safety injection pump operability in Mode 4 while below 312°F. The change will facilitate surveillance testing of ECCS Pumps.

In accordance with the fee requirements of 10CFR170.21, a check in the amount of \$150.00 is enclosed.

Pursuant to the requirements of 10CFR50.91, a copy of this request for amendment has been sent to the State of New Jersey as indicated below.

8412190298 841207
PDR ADDCK 05000272
PDR
P


ine Energy People

*Rec'd w/enc 12/15/84 \$150.00
#01917821*

*Aool
1/1*

This submittal includes three (3) signed originals and forty (40) copies.

Sincerely,



E. A. Liden
Manager - Nuclear
Licensing and Regulation

Enclosure

C Mr. Donald C. Fischer
Licensing Project Manager

Mr. James Linville
Senior Resident Inspector

Mr. Frank Cosolito, Acting Chief
Bureau of Radiation Protection
Department of Environmental Protection
380 Scotch Road
Trenton, New Jersey 08628

Honorable Charles M. Oberly, III
Attorney General of the State of Delaware
Department of Justice
820 North French Street
Wilmington, Delaware 19801

